



Mr. T. Gnanalingam  
Manager  
Murco Service Station  
Harnall Lane East  
Coventry  
CV1 5DX

Your reference PPC/102  
Our reference PPC/102  
8<sup>th</sup> November 2011

Dear Mr. Gnanalingam

**Environmental Permitting (England and Wales) Regulations 2010  
Permit to operate a Prescribed Installation: Permit Ref. PPC/102**

**Operator Address: Murco Service Station, Harnall Lane, Coventry CV3 6EF**

Further to my visit on the 31<sup>st</sup> October and my conversation with you today on the 8<sup>th</sup> November I write to confirm the following.

I can confirm that you have complied with the majority of items on the enforcement notice dated 6<sup>th</sup> September 2011 and I appreciate the progress you have made. I understand from Ailish O'Meara of Suresite that she will be sending your training certificates once you have paid her invoice. However, the following item has still not been completed from the enforcement notice dated 6<sup>th</sup> September:-

1.22 Petrol delivery and vapour return lines shall be tested in accordance with the schedule as appended to this Permit (or such other schedule as may be agreed by the regulator).	There was no recent inspection certificate available on site- it is a requirement that petrol delivery and vapour return lines are tested every 5 years.	Enlist the services of a suitably competent and qualified person to undertake an inspection and test of the petrol delivery and vapour return lines (underground pipes) to meet the requirements of condition 1.22. Obtain a report and test certificate and forward this to the local authority by <b>29<sup>th</sup> September 2011</b> .
---	--	---

Therefore, you now have 7 days to complete item 1.22, if you do not provide a valid test by the 17<sup>th</sup> November. If you fail to do this then the Council may instigate legal proceedings for non-compliance, **this carries a potential maximum £50,000 fine in the magistrates courts** (penalties can be increased in the Crown Court).



Director of Community Services  
Brian Walsh  
Head of Service  
Sara Roach  
Assistant Director - Public Safety and  
Housing

8th November 2011

Please contact me if you have any questions or if there is anything at all that you do not understand or wish to talk to me about.

Yours sincerely

Steven Dewar  
**Environmental Health Officer**

# STAGE 1B TESTING CERTIFICATE OF APPROVAL

## CERTIFICATE NUMBER

CP/6445

## ISSUED TO

Link Murco SS, Harnell Lane East, Hillfields ,  
Coventry, West Midlands, CV1 5AX

**THIS CERTIFICATE HAS BEEN ISSUED BY PETROMAN ENVIRONMENTAL SERVICES LIMITED OF UNIT 5 SNEYD GREEN BUSINESS PARK, SNEYD STREET, SNEYD GREEN, STOKE ON TRENT, ST6 2NP**

**Full Site Address:** Link Murco SS, Harnell Lane East, Hillfields , Coventry, West Midlands, CV1 5AX

**Name of Licence Holder:** Mr Ganalingam  
**Licensing Authority:** Coventry City Council  
**Authorised Testing Company:** Petroman Environmental Services LTD.  
**Authorised Test Engineer:** Adam Murraywhite  
**ID Number:** 28  
**Test Date:** 22/08/2011

The Stage 1B Vapour Recovery System installed at the above site has been tested by the authorised engineer named above using the Petroman Testing Procedure. The results confirm that this Stage 1B Vapour Recovery System has **PASSED**.

We confirm that the PV and VR valves have proven to be in good operational condition and meet the environmental standards required of this equipment.

Pressure/Vacuum Valves Fitted: Release Pressure +35 mbars  
Vacuum Setting -4 mbars

Vapour Recovery Connection Point **PASSED** for condition and sealing capacity.

**This certificate is valid for a period of 1 year and expires on 21/08/2012**

**SIGNED**

For and on behalf of Petroman Environmental Services Limited

# Ideal Tanks & Pumps Ltd..

*INSTALLATIONS & CONSTRUCTIONS*  
*PUMPS & FITTINGS*

---

Registered Office

**THE GAS STATION RUGBY ROAD**  
**HARLESTONE NORTHAMPTON NN7 4ER**

REGISTERED NO. 908631

TEL/FAX (01604) 843359

Directors: P. RUSSELL M. A. ROBINSON

FORTY YEARS OF TANKS AND PUMPS EXPERIENCE

## CERTIFICATE

This is to confirm we have pressure tested whole vapour recovery system at  
Mr Lingham, Link Murco, Harnell Lane East, Hillfields, Coventry, West Midlands,  
CV1 5AX on 25th November 2011 for 30 minutes All Passed OK

To test each of the 3 x tanks fill internals for 30 minutes on spirit tanks only  
All Passed OK