Permit No: PPC 025

OEH Group Limited 253 – 255 Great Lister Street Birmingham West Midlands B7 4BS

REPORT FOR THE PERIODIC MONITORING OF EMISSIONS TO AIR FROM PART B PROCESSES

at

SANDVIK HARD MATERIALS LIMITED
PO BOX 89
TORRINGTON AVENUE
COVENTRY
WARWICKSHIRE
CV4 9XG

PART 1: EXECUTIVE SUMMARY

REPORT NO: OEH/34258/STAK/SS70 CLIENT REF:	Purchase Order No: 1020209
DATE OF VISIT: 15 to 16 August 2005 CONTACT ON SITE:	Phil Moran
DATE OF REPORT: 19 September 2005 DISK REFERENCE :	N:\GenAdmin\$\Divisional Reports\2005\Air
	Quality\Reports\Sandvik\OEH342 58\OEH34258 CS F.doc

DATA PROTECTION ACT REGISTRATION NO: B0479 03 4

CONFIDENTIALITY UNDERTAKING

We undertake that we will not knowingly make use or disclose any confidential information or photographs relating to your business which may have come to our knowledge or attention as a result of our visit on site or otherwise as a result of the work carried out by us in connection with the preparation of this report. If you have any queries or comments regarding this report, please contact the Customer Services, OEH Group Limited Tel: 0121 359 5361.

Report No: OEH34258 CS F

Page 1 of 20

Reported by:



Paul Calland MCERTS No. MM 03212 Senior Environmental Scientist.

Approved by:



Andy Barnes MCERT No. MM 03235 Divisional Manager – Air Quality

for OEH Group Limited

If you have any queries or comments regarding this report, please contact Customer Services, OEH Group Ltd. Tel: 0121 359 5361.

Report No: OEH34258 CS F

TABLE OF CONTENTS

PART	1: EXE	CUTIVE SUMMARY	1
1	MONI	TORING OBJECTIVES	4
	1.1	TERMS OF REFERENCE	5
2	MONI	TORING RESULTS	5
	2.1 2.2 2.3 2.4 2.5 2.6 2.7 2.8 2.9 2.10 2.11	EMISSION POINT REFERENCE: SOUTH SITE – LEV 002 EMISSION POINT REFERENCE: SOUTH SITE – LEV 12A EMISSION POINT REFERENCE: SOUTH SITE – LEV 15 EMISSION POINT REFERENCE: SOUTH SITE – LEV 20 EMISSION POINT REFERENCE: SOUTH SITE – LEV 23 EMISSION POINT REFERENCE: SOUTH SITE – LEV 27 EMISSION POINT REFERENCE: SOUTH SITE – LEV 45 EMISSION POINT REFERENCE: NORTH SITE – LEV 3 EMISSION POINT REFERENCE: NORTH SITE – LEV 8 EMISSION POINT REFERENCE: NORTH SITE – SMALL NEW FILTER (B5 FURNACES) EMISSION POINT REFERENCE: NORTH SITE – LARGE NEW FILTER (B5 BALL MILLS)	5 6 6 7 7 7 8 8 8
3	PLAN	T AND OPERATING INFORMATION	9
4	MONI	TORING DEVIATIONS	9
PART	2: SUP	PORTING INFORMATION	11
5	APPE	NDIX I	14
	5.1 5.2 5.2.1 5.2.2 5.2.3 5.3	FIELD STAFF USED FIELD MONITORING METHODS USED Stack Velocity & Temperature Measurements Particulate Matter Metals (Tungsten and Cobalt) MONITORING EQUIPMENT USED	14 14 14 14 14 14
6	APPE	NDIX II	15
	6.1 6.1.1 6.1.2 6.1.3	ANALYSIS Blank Analysis. Techniques & Detection Limits Accreditation	15 15 15 15
7	APPE	NDIX III	16
	7.1	TOTAL PARTICULATE MATTER & FLOWRATE CALCULATION SPREADSHEETS	16
8	APPE	NDIX IV	17
	8.1	METALS DETERMINATION SPREADSHEET	17
9	APPE	NDIX V	18
	9.1	EQUIPMENT CALIBRATION CERTIFICATES	18
10	APPE	NDIX VI	19
	10.1	Uncertainty Calculations	19
11		NDIX VII	20
	11.1	SAMPLING LOCATION DIAGRAMS	20
Report	No: OEH	34258 CS F	Page 3 of 20

1 MONITORING OBJECTIVES

The monitoring at this installation was carried out as part of the compliance check monitoring of emissions to air in accordance with the requirements of Local Authority Permit/Authorisation Number; PPC 025. The substances requested for monitoring at each emission point are listed in the table below.

		Emission Point	Identification	
Substances to be monitored	LEV 002	LEV 12A	LEV 16	LEV 20
monitored	South Site Vent 30	South Site Vent 28	South Site Vent 37	South Site Vent 19
Total Particulates	√	√	√	√
Cobalt	√	√	√	√
Tungsten	√	√	√	√
		Emission Point	Identification	
Substances to be monitored	LEV 23	LEV 27	LEV 45	LEV 3
monitorea	South Site Vent 26	South Site Vent 23	South Site Vent 24	North Site Vent 7
Total Particulates	√	√	√	√
Cobalt	√	√	√	√
Tungsten	√	√	√	√
		Emission Point	Identification	
Substances to be monitored	LEV 8	North Site - New Small	North Site – New Large	
monitorea	North Site Vent 3	Filter (B5 Furnaces & Cake Breaking)	Filter (B5 Ball Mills)	
Total Particulates	√	√	√	
Cobalt	√	√	√	
Tungsten	√	√	√	

Report No: OEH34258 CS F Page 4 of 20

1.1 Terms of Reference

Sandvik Hard Materials Limited, PO Box 89, Torrington Avenue, Coventry, Warwickshire, CV4 9XG, has commissioned OEH Group Limited to carry out the work described in this report. Monitoring was carried out on 15th and 16th August 2005 by Andy Barnes and Paul Calland at the request of Phil Moran

The work was carried out in accordance with the site specific sampling protocols outlined in OEH Proposal ref: EFH-11757, dated 8^{th} July 2005. The client instructions are set out in Purchase Order 1020209.

OEH Group is accredited under ISO-9000:2000 for the provision of health, safety and environmental consultancy services. The work described in this report was carried out in accord with the Company's Standard Operating Procedures and Level III: Consultancy Work Instructions. Field personnel hold Level 2 MCERTs certification.

2 MONITORING RESULTS

2.1 Emission Point Reference: South Site – LEV 002

Process Status		Processes Running as Normal									
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time					
Particulates	50 mg.m ⁻³	0.42 mg.m ⁻³	NTP	BS EN 13284	15/08/05	09:31 - 10:01					
Tungsten	n/a	0.034 mg.m ⁻³	NTP	BS EN 14385	15/08/05	& 10:05 –					
Cobalt	n/a	0.003 mg.m ⁻³	NTP	BS EN 14385	15/08/05	10:35					
Emission Limit Value	The emission limit value is that stated in the permit, and is expressed as a concentration [mg.Nm ⁻³] or a mass emission [kg.hr ⁻¹]. Otherwise "unknown" is stated.										
Periodic Monitoring Result	value, where	en is expressed available.	in the same te	erms and units a	s the emission	on limit					
Reference Conditions		s stated, all resul e results are not ted.									
Monitoring Method Reference		stated is in accor se M2 or other m									
Accreditation for use of	All Methods a	re Not UKAS Acc	credited (Accre	editation pending	g for particul	ates).					
Method Process Status	The details in monitoring.	dicate the feeds	tock and the lo	oading rate of th	e plant durir	ng					

Report No: OEH34258 CS F

Page 5 of 20

2.2 Emission Point Reference: South Site - LEV 12A

Process Status	Processes Running as Normal								
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time			
Particulates	50 mg.m ⁻³	1.08 mg.m ⁻³	NTP	BS EN 13284	15/08/05	09:15 - 09:45			
Tungsten	n/a	0.140 mg.m ⁻³	NTP	BS EN 14385	15/08/05	09:45 & 09:49 -			
Cobalt	n/a	0.010 mg.m ⁻³	NTP	BS EN 14385	15/08/05	10:19			

2.3 Emission Point Reference: South Site – LEV 15

Process Status	Processes Running as Normal								
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time			
Particulates	50 mg.m ⁻³	0.55 mg.m ⁻³	NTP	BS EN 13284	15/08/05	13:15 -			
Tungsten	n/a	0.139 mg.m ⁻³	NTP	BS EN 14385	15/08/05	14:03 & 14:05 –			
Cobalt	n/a	0.002 mg.m ⁻³	NTP	BS EN 14385	15/08/05	15:05			

2.4 Emission Point Reference: South Site – LEV 20

Process Status		Processes Running as Normal								
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time				
Particulates	50 mg.m ⁻³	0.47 mg.m ⁻³	NTP	BS EN 13284	15/08/05	11:58 - 12:33				
Tungsten	n/a	0.062 mg.m ⁻³	NTP	BS EN 14385	15/08/05	8 12:35 –				
Cobalt	n/a	0.006 mg.m ⁻³	NTP	BS EN 14385	15/08/05	13:10				

Report No: OEH34258 CS F

2.5 Emission Point Reference: South Site – LEV 23

Process Status	Processes Running as Normal								
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time			
Particulates	50 mg.m ⁻³	0.04 mg.m ⁻³	NTP	BS EN 13284	15/08/05	12:18 -			
Tungsten	n/a	0.059 mg.m ⁻³	NTP	BS EN 14385	15/08/05	12:54 & 12:58 –			
Cobalt	n/a	0.004 mg.m ⁻³	NTP	BS EN 14385	15/08/05	13:34			

2.6 Emission Point Reference: South Site – LEV 27

Process Status	Processes Running as Normal								
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time			
Particulates	50 mg.m ⁻³	0.16 mg.m ⁻³	NTP	BS EN 13284	15/08/05	10:58 - 11:28			
Tungsten	n/a	0.097 mg.m ⁻³	NTP	BS EN 14385	15/08/05	11:28 & 11:35 –			
Cobalt	n/a	0.003 mg.m ⁻³	NTP	BS EN 14385	15/08/05	12:05			

2.7 Emission Point Reference: South Site – LEV 45

Process Status	Processes Riinni			ng as Normal		
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time
Particulates	50 mg.m ⁻³	0.17 mg.m ⁻³	NTP	BS EN 13284	15/08/05	13:47 – 14:17
Tungsten	n/a	0.038 mg.m ⁻³	NTP	BS EN 14385	15/08/05	8 14:20 –
Cobalt	n/a	0.005 mg.m ⁻³	NTP	BS EN 14385	15/08/05	15:00

Report No: OEH34258 CS F

2.8 Emission Point Reference: North Site - LEV 3

Process Status	Processes Running as Normal							
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time		
Particulates	50 mg.m ⁻³	1.39 mg.m ⁻³	NTP	BS EN 13284	16/08/05	12:00 -		
Tungsten	n/a	0.090 mg.m ⁻³	NTP	BS EN 14385	16/08/05	12:40 & 12:43 –		
Cobalt	n/a	0.058 mg.m ⁻³	NTP	BS EN 14385	16/08/05	13:23		

2.9 Emission Point Reference: North Site - LEV 8

Process Status	Processes Running as Normal							
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time		
Particulates	50 mg.m ⁻³	0.07 mg.m ⁻³	NTP	BS EN 13284	16/08/05	12:51 -		
Tungsten	n/a	0.022 mg.m ⁻³	NTP	BS EN 14385	16/08/05	13:31 & 13:40 =		
Cobalt	n/a	0.007 mg.m ⁻³	NTP	BS EN 14385	16/08/05	13:40 – 14:22		

2.10 Emission Point Reference: North Site – Small New Filter (B5 Furnaces)

Process Status							
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time	
Particulates	50 mg.m ⁻³	0.17 mg.m ⁻³	NTP	BS EN 13284	16/08/05	09:30 - 10:10	
Tungsten	n/a	0.074 mg.m ⁻³	NTP	BS EN 14385	16/08/05	10:10 & 10:14 –	
Cobalt	n/a	0.001 mg.m ⁻³	NTP	BS EN 14385	16/08/05	10:54	

Report No: OEH34258 CS F

2.11 Emission Point Reference: North Site - Large New Filter (B5 Ball Mills)

Process Status	Processes Running as Normal								
Parameter	Emission Limit Value	Periodic Monitoring Result	Reference Conditions	Method Reference	Sampling Date	Sampling Time			
Particulates	50 mg.m ⁻³	0.09 mg.m ⁻³	NTP	BS EN 13284	16/08/05	11:01 -			
Tungsten	n/a	0.069 mg.m ⁻³	NTP	BS EN 14385	16/08/05	11:37 & 11:41 -			
Cobalt	n/a	0.002 mg.m ⁻³	NTP	BS EN 14385	16/08/05	12:25			

3 PLANT AND OPERATING INFORMATION

Plant and operating conditions prevailing on the date of the survey were described as normal in all cases.

4 MONITORING DEVIATIONS

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Issues
South Site – LEV 16	Total Particulate, Tungsten & Cobalt	Not Sampled	Process served by LEV 16 was not operating (under repairs) – LEV 15 was sampled instead.
South Site – LEV 002	Total Particulate	Only 1 sample line used.	Sample ports fitted incorrectly, increased number of sample points used on 1 line.
South Site – LEV 12A	Total Particulate	Non-isokinetic sampling was used	No stack is fitted so sampling made at filter outlet.
South Site – LEV 15	Total Particulate	Only 1 sample line used.	Sample ports fitted incorrectly, increased number of sample points used on 1 line.
South Site – LEV 45	Total Particulate	Non-isokinetic sampling was used	No stack is fitted so sampling made at wet collector outlet.

Report No: OEH34258 CS F

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Issues				
North Site – LEV 13	Total Particulate	Only 1 sample line used.	Sample ports fitted incorrectly, increased number of sample points used on 1 line.				
North Site – LEV 8	Total Particulate	Non-isokinetic sampling was used	No stack is fitted so sampling made at filter outlets.				
North Site – New Small Filter	Total Particulate	Non-isokinetic sampling was used	No stack is fitted so sampling made at filter outlet.				
Notes:							
Substance Deviations	together with th	State any substance not monitored during the monitoring campaign, together with the reason for the omission from the monitoring campaign. If not applicable state "N/A"					
Monitoring Deviations	State any deviation from the standard method, the consequences, and the reason for the deviation. If not applicable state "N/A"						
Other Relevant Issues	State any other infapplicable state "N		to the monitoring campaign. If not				

Report No: OEH34258 CS F

OEH Group Limited 253- 255 Great Lister Street Birmingham West Midlands B7 4BS

REPORT FOR THE PERIODIC MONITORING OF

EMISSIONS TO AIR FROM PART B PROCESSES

at

SANDVIK HARD MATERIALS LIMITED
PO BOX 89
TORRINGTON AVENUE
COVENTRY
WARWICKSHIRE
CV4 9XG

PART 2: SUPPORTING INFORMATION

REPORT NO: OEH/34258/STAK/SS70 CLIENT REF: Purchase Order No: 1020209


DATE OF VISIT: 15 to 16 August 2005 CONTACT ON SITE: Phil Moran

DATE OF REPORT: 19 September 2005 DISK REFERENCE: N:\GenAdmin\$\Divisional Reports\2005\Air Quality\Reports\Sandvik\OEH34258 CS F.doc

DATA PROTECTION ACT REGISTRATION NO: B0479 03 4

Report No: OEH34258 CS F Page 11 of 20

Reported by:



Paul Calland MCERTS No. MM 03212 Senior Environmental Scientist.

Approved by:



Andy Barnes
MCERT No. MM 03235
Divisional Manager – Air Quality

for OEH Group Limited

If you have any queries or comments regarding this report, please contact Customer Services, OEH Group Ltd. Tel: 0121 359 5361.

Report No: OEH34258 CS F

TABLE OF CONTENTS

PART	1: EXE	CUTIVE SUMMARY	1
1	MON	TORING OBJECTIVES	4
	1.1	TERMS OF REFERENCE	5
2	MON	TORING RESULTS	5
	2.1 2.2	EMISSION POINT REFERENCE: SOUTH SITE — LEV 002 EMISSION POINT REFERENCE: SOUTH SITE — LEV 12A	5 6
	2.3	EMISSION POINT REFERENCE: SOUTH SITE - LEV 15	6
	2.4 2.5	EMISSION POINT REFERENCE: SOUTH SITE – LEV 20 EMISSION POINT REFERENCE: SOUTH SITE – LEV 23	6 7
	2.6	EMISSION POINT REFERENCE: SOUTH SITE - LEV 27	7
	2.7	EMISSION POINT REFERENCE: SOUTH SITE - LEV 45	7
	2.8 2.9	EMISSION POINT REFERENCE: NORTH SITE - LEV 3	8
	2.9	EMISSION POINT REFERENCE: NORTH SITE – LEV 8 EMISSION POINT REFERENCE: NORTH SITE – SMALL NEW FILTER (B5 FURNACES)	8) 8
	2.11	EMISSION POINT REFERENCE: NORTH SITE - LARGE NEW FILTER (B5 BALL MILLS	
3	PLAN	T AND OPERATING INFORMATION	9
4	MON	ITORING DEVIATIONS	9
PART	2: SUP	PORTING INFORMATION	11
5	APPE	NDIX I	14
	5.1	FIELD STAFF USED	14
	5.2 5.2.1		14 14
	5.2.1	•	14
	5.2.3	Metals (Tungsten and Cobalt)	14
	5.3	MONITORING EQUIPMENT USED	14
6	APPE	NDIX II	15
	6.1	Analysis	15
	6.1.1 6.1.2	·	15 15
	6.1.3	,	15
7	APPE	NDIX III	16
	7.1	TOTAL PARTICULATE MATTER & FLOWRATE CALCULATION SPREADSHEETS	16
8	APPE	NDIX IV	17
	8.1	METALS DETERMINATION SPREADSHEET	17
9	APPE	NDIX V	18
	9.1	EQUIPMENT CALIBRATION CERTIFICATES	18
10	APPE	NDIX VI	19
	10.1	UNCERTAINTY CALCULATIONS	19
11	APPE	NDIX VII	20
	11.1	SAMPLING LOCATION DIAGRAMS	20
Repor	t No: OEH	134258 CS F	Page 13 of 20

5 APPENDIX I

5.1 Field Staff Used

Name MCERTS Registration No:		MCERTS Qualifications	Function	
Andrew Barnes	MM 03235	Level 2, TE1, TE3 & TE4	Team Leader	
Paul Calland	MM 03212	Level 2 & TE1 & TE4	Assistant	

5.2 Field Monitoring Methods Used

5.2.1 Stack Velocity & Temperature Measurements

Stack velocity was measured using a pitot tube, conforming to the design specifications of ISO 3966-1977, coupled to an electronic manometer. Temperature measurements were taken using a K-type thermocouple connected to an electronic thermometer. Measurements were made using OEH technical procedure AQSOP 200, which is designed to fulfil the requirements of ISO10780:1994.

5.2.2 Particulate Matter

Periodic extractive sampling for particulate matter was conducted using two off Stackmite sampling trains, with the in-stack filter configuration. Measurements were made using OEH technical procedure AQSOP 201, which is designed to fulfil the requirements of BS EN 13284-1:2002 & Environment Agency MID1.

5.2.3 Metals (Tungsten and Cobalt)

Periodic extractive sampling for particulate and vapour phase metals was conducted using the Stackmite sampling trains above, backed up by an impinger train containing solutions of nitric acid/ hydrogen peroxide. Measurements were made using a procedure designed to fulfil the requirements of BS EN 14385:2004.

5.3 Monitoring Equipment Used

Equipment	Serial Number	Description/ Type	Calibration Certificate	Calibration Expires
Stackmite unit(s)	AQ 001	1008/1854	In House	31/10/2005
Stackmite unit(s)	AQ 003	386769	In House	04/11/05
Thermometer	AQ 004	6497	In House	27/04/06
Pitot tube	AQ 095	Airflow 1.8m	N8907/05	04/05/2006
Manometer	AQ 064	30208024	LCM4426/05/7	15/04/2006
Calipers	AQ 168	04414420	113451	03/05/2006
Tape Measure	AQ 049	5 metre	In House	28/04/2006

Report No: OEH34258 CS F

Page 14 of 20

6 APPENDIX II

6.1 Analysis

6.1.1 Blank Analysis.

The following table gives details of the blank filter and impinger solution analysis results.

Blank Media	Sample Number	Blank Values				
		Particulate	Cobalt	Tungsten		
Filter	GF 10163	<20 µg	<1 µg	<1 µg		
Impinger Solution	OH 797/ 798	n/a	<1 µg	<1 µg		

6.1.2 Techniques & Detection Limits

Analyte	Analysis Technique	Detection Limit	Analytical Precision, %	Method Reference
TPM	Gravimetric	20 μg	1	LSOP 202
Metals	Atomic Absorption	1 μg	1	LSOP 300

6.1.3 Accreditation

Service Category	ISO- 9002	UKAS ¹
Consultancy	Yes	No
Analysis		
- Dusts (air filter samples); Lab Method LSOP 202.	Yes	Yes
- Metals Lab Method LSOP 300/ 301	Yes	Yes
¹ UKAS lab number 1821	·	
Stack sampling team is a member of the Source Testing	Association	

Report No: OEH34258 CS F Page 15 of 20

- 7 APPENDIX III
- 7.1 Total Particulate Matter & Flowrate Calculation Spreadsheets

Report No: OEH34258 CS F Page 16 of 20

Plant Type	South Site - LEV 002	Stack Area (m ²)	0.283
Job Number	OEH 34258	Meter Temp (C)	30
Client Name	Sandvik	Stack Diameter (cm)	60
Date	15th August 2005	Pitot Factor	1.00
		Pitot Factor (sqrt)	1.00
		Stack Pressure (Pa)	11
		Ambient Pressure (kPa)	101.3
		Nozzle Size (mm)	5.00

Traverse Point	A1	A2	A3	A4	A5	A6	A7	A8	A9	A10
Distance From Near Wall (D)	0.065	0.150	0.250	0.350	0.450	0.550	0.650	0.750	0.850	0.935
Pitot Reading (Pa)	45	55	58	60	65	70	65	62	55	45
Temperature (°C)	25	25	25	25	25	25	25	25	25	25
Duct Velocity (m/s)	8.7	9.6	9.9	10.1	10.5	10.9	10.5	10.2	9.6	8.7

Absolute Mean Duct Velocity (m/s)	9.9
Absolute Flow Rate (m³/hr)	10057
Normalised Flow Rate (Nm3/hr)	9214

Sampling Run 1 Time: 09:31 - 10:01

	5.55.55.55					
Sampling Point	A2	A2	A7	A9	Initial Meter Reading (I)	476183
Sampling Rate (I/min)	11.5	12.1	12.6	11.5	Final Meter Reading (I)	476528
Sampling Duration (mins)	7.5	7.5	7.5	7.5	Volume Sampled (I)	345
Filter No	10187	10187	10187	10187	Isokineticity Error (%)	-3.6
Volume Sampled (m³)	Meter	0.345	Expected	0.358	(Maximum Allowed Error = -5	to +15%)
Corrected Volume =			0.31	Nm³ (a	t NTP)	

Sampling Run 2 Time: 10:05 - 10:35

Jamping Run Z	i iiiie.	TOIOS	- TO:22			
Sampling Point	A2	A2	A7	A9	Initial Meter Reading (I)	476530
Sampling Rate (I/min)	11.5	12.1	12.6	11.5	Final Meter Reading (I)	476875
Sampling Duration (mins)	7.5	7.5	7.5	7.5	Volume Sampled (I)	345
Filter No	10189	10189	10189	10189	Isokineticity Error (%)	-3.6
Volume Sampled (m³)	Meter	0.345	Expected	0.358	(Maximum Allowed Error = -5	to +15%)
Carracted Values -				Nm3 /n		See Disease See Co

Corrected Volume = 0.31 Nm³ (at NTP)

FILTER WEIGHTS

Test Number	Filter No	Pre-Weight (mg)	Post-Weight (mg)	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	10187	56.43	56.62	0.00	0.00	0.19
2	10189	56.31	56.38	0.00	0.00	0.07

WASHINGS WEIGHTS

TEST RESULTS

		Test 2	
Particulate Concentration(mg/Nm³)	0.61	0.23	0.42
Mass Emission (g/hr)	5.6	2.1	3.9

stkpsi Issue 1 [11/2001] Filename: 34258 App 1 LEV 002

Date: 13/09/2005

Plant Type	South Site - LEV 12A	Stack Area (m²)	0.488
Job Number	OEH 34258	Meter Temp (C)	30
Client Name	Sandvik	Grille Dimensions (cm)	65 x 75
Date	15th August 2005	Pitot Factor	
		Pitot Factor (sqrt)	
		Stack Pressure (Pa)	0
		Ambient Pressure (kPa)	101.3
		Nozzle Size (mm)	5.00

There is no stack fitted and so sampling made non-isokinetically from outlet grille of filter

No accurate flow measurements are possible

Sampling Run 1	Time:	09:15 - 09:45
Sampling Point	CP	Initial Meter Reading (I) 989748
Sampling Rate (I/min)	14.0	Final Meter Reading (I) 990183
Sampling Duration (mins)	30	Volume Sampled (I) 435
Filter No	10188	
Volume Sampled (m³)	Meter	0.435 Expectec 0.420
Corrected Volume =		0.39 Nm³ (at NTP)

Time:	09:49 - 10:19
CP	
	Time:

Sampling Point	CP	Initial Meter Reading (I)	990183
Sampling Rate (I/min)	14.0	Final Meter Reading (I)	990618
Sampling Duration (mins)	30	Volume Sampled (I)	435
Filter No	10190	181	

Volume Sampled (m³) Meter 0.435 Expectec 0.420

Corrected Volume = 0.39 Nm³ (at NTP)

FILTER WEIGHTS WASHINGS WEIGHTS

Test Number	Filter No	Pre-Weight (mg	Post-Weight (mg)	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	10188	54.99	55.80	0.00	0.00	0.81
2	10190	55.31	55.35	0.00	0.00	0.04

TEST RESULTS

	Test 1	Test 2	Mean
Particulate Concentration(mg/Nm³)	2.07	0.10	1.08
Mass Emission (g/hr)	-	-	

stkpsi Issue 1 [11/2001] Filename: 34258 App 1 LEV 12a Date: 13/09/2005

Plant Type	South Site - LEV 15	Stack Area (m ²)	0.126
Job Number	OEH 34258	Meter Temp (C)	30
Client Name	Sandvik	Stack Diameter (cm)	40
Date	15th August 2005	Pitot Factor	1.00
		Pitot Factor (sqrt)	1.00
		Stack Pressure (Pa)	5
		Ambient Pressure (kPa)	101.3
		Nozzle Size (mm)	7.00

			The second second							
Traverse Point	A1	A2	A3	A4	A5	A6	A7	A8	A9	A10
Distance From Near Wall (D)	0.065	0.150	0.250	0.350	0.450	0.550	0.650	0.750	0.850	0.935
Pitot Reading (Pa)	5	5	5	5	5	6	5	5	5	5
Temperature (°C)	25	25	25	25	25	25	25	25	25	25
Duct Velocity (m/s)	2.9	2.9	2.9	2.9	2,9	3.2	2.9	2.9	2.9	2.9

Absolute Mean Duct Velocity (m/s)	2.9
Absolute Flow Rate (m³/hr)	1328
Normalised Flow Rate (Nm³/hr)	1217

Sampling Run 1 Time: 13:15 - 14:03

Samping Kun I	illie.	19.19	- T4'03			
Sampling Point	A2	A4	A7	A9	Initial Meter Reading (I)	991382
Sampling Rate (I/min)	8.5	8.5	8.5	8.5	Final Meter Reading (I)	991802
Sampling Duration (mins)	12	12	12	12	Volume Sampled (I)	420
Filter No	10193	10193	10193	10193	Isokineticity Error (%)	2.9
Volume Sampled (m³)	Meter	0.420	Expected	0.408	(Maximum Allowed Error = -5	to +15%)

0.38 Nm³ (at NTP) Corrected Volume =

Sampling Run 2 Time: 14:05 - 15:05

outilbuild trail w		21100	20100			
Sampling Point	A2	A4	A7	A9	Initial Meter Reading (I)	991802
Sampling Rate (I/min)	8.5	8.5	8.5	8.5	Final Meter Reading (I)	992352
Sampling Duration (mins)	15	15	15	15	Volume Sampled (I)	550
Filter No	10194	10194	10194	10194	Isokineticity Error (%)	7.8
Volume Sampled (m³)	Meter	0.550	Expected	0.510	(Maximum Allowed Error = -5	to +15%)

Corrected Volume = 0.50 Nm³ (at NTP)

FILTER WEIGHTS

WASHINGS WEIGHTS

Test Number	Filter No	Pre-Weight (mg	Post-Weight (mg	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	10193	56.61	56.81	0.00	0.00	0.20
2	10194	56.40	56.68	0.00	0.00	0.28

TEST RESULTS

	Test 1	Test 2	Mean
Particulate Concentration(mg/Nm³)	0.53	0.57	0.55
Mass Emission (g/hr)	0.6	0.7	0.7

stkpsi Filename: 34258 App 1 LEV 15 Issue 1 [11/2001]

Date: 13/09/2005

Plant Type	South Site - LEV 20	Stack Area (m²)	0.071
Job Number	OEH 34258	Meter Temp (C)	30
Client Name	Sandvik	Stack Diameter (cm)	30
Date	15th August 2005	Pitot Factor	1.00
		Pitot Factor (sqrt)	1.00
		Stack Pressure (Pa)	130
		Ambient Pressure (kPa)	101.3
		Nozzle Size (mm)	4.00

Traverse Point	A1	A2	A3	A4	A5	A6	A7	A8	A9	A10
Distance From Near Wall (D)	0.065	0.150	0.250	0.350	0.450	0.550	0.650	0.750	0.850	0.935
Pitot Reading (Pa)	115	113	112	115	113	113	110	111	109	105
Temperature (°C)	30	30	30	30	30	30	30	30	30	30
Duct Velocity (m/s)	14.1	13.9	13.9	14.1	13.9	13.9	13.7	13.8	13.7	13.4
Traverse Point	B1	B2	B3	B4	B5	B6	B7	B8	B9	B10
Distance From Near Wall (D)	0.065	0.150	0.250	0.350	0.450	0.550	0.650	0.750	0.850	0.935
Pitot Reading (Pa)	116	114	115	115	114	113	112	113	110	103
Temperature (°C)	30	30	30	30	30	30	30	30	30	30
Duct Velocity (m/s)	14.1	14.0	14.1	14.1	14.0	13.9	13.9	13.9	13.7	13.3

Absolute Mean Duct Velocity (m/s)	13.9
Absolute Flow Rate (m³/hr)	3532
Normalised Flow Rate (Nm3/hr)	3186

Sampling Run 1 Time: 11:58 - 12:33

Sampling Point	CP]	Initial Meter Reading (I)	990627
Sampling Rate (I/min)	10.6]	Final Meter Reading (I)	991004
Sampling Duration (mins)	35	1	Volume Sampled (I)	377
Filter No	10191	1	Isokineticity Error (%)	1.6
Volume Sampled (m³)	Meter	0.377 Expectec 0.37	(Maximum Allowed Error =	5 to +15%)
THE RESERVE OF THE PARTY OF THE				(3/)

Corrected Volume = 0.34 Nm³ (at NTP)

Sampling Run 2 Time: 12:35 - 13:10

Sampling Point	CP		Initial Meter Reading (I)	991005
Sampling Rate (I/min)	10.6		Final Meter Reading (I)	991382
Sampling Duration (mins)	35	1	Volume Sampled (I)	377
Filter No	10192		Isokineticity Error (%)	1.6
Volume Sampled (m³)	Meter	0.377 Expectec 0.33	71 (Maximum Allowed Error = -5	to +15%)

Corrected Volume = 0.34 Nm³ (at NTP)

FILTER WEIGHTS

WASHINGS WEIGHTS

Test Number	Filter No	Pre-Weight (mg	Post-Weight (mg	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	10191	56.40	56.60	0.00	0.00	0.20
2	10192	56.45	56.57	0.00	0.00	0.12

TEST RESULTS

	Test 1	Test 2	Mean
Particulate Concentration(mg/Nm³)	0.59	0.35	0.47
Mass Emission (g/hr)	1.9	1.1	1.5

stkpsi Issue 1 [11/2001]

Filename: 34258 App 1 LEV 20

Date: 13/09/2005

Plant Type	South Site - LEV 23	Stack Area (m²)	0.018
Job Number	OEH 34258	Meter Temp (C)	30
Client Name	Sandvik	Stack Diameter (cm)	15
Date	15th August 2005	Pitot Factor	1.00
		Pitot Factor (sqrt)	1.00
		Stack Pressure (Pa)	30
		Ambient Pressure (kPa)	101.3
		Nozzle Size (mm)	5.00

Traverse Point	A1	A2	A3	A4	A5
Distance From Near Wall (D)	0.150	0.250	0.500	0.750	0.850
Pitot Reading (Pa)	95	99	100	97	94
Temperature (°C)	70	70	70	70	70
Duct Velocity (m/s)	13.6	13.9	13.9	13.7	13.5
Traverse Point	B1	B2	В3	B4	B5
Distance From Near Wall (D)	0.150	0.250	0.500	0.750	0.850
Pitot Reading (Pa)	98	99	100	98	93
Temperature (°C)	70	70	70	70	70
Duct Velocity (m/s)	13.8	13.9	13.9	13.8	13.4

Absolute Mean Duct Velocity (m/s)	13.8
Absolute Flow Rate (m³/hr)	875
Normalised Flow Rate (Nm³/hr)	697

Sampling Run 1 Time: 12:18 - 12:54

		mminute march		
Sampling Point	СР]	Initial Meter Reading (I)	477940
Sampling Rate (I/min)	14.5	1	Final Meter Reading (I)	478470
Sampling Duration (mins)	36		Volume Sampled (I)	530
Filter No	10147		Isokineticity Error (%)	1.5
Volume Sampled (m³)	Meter	0.530 Expectec 0.5	522 (Maximum Allowed Error = -5	
0 1111				, ,

Corrected Volume = 0.48 Nm³ (at NTP)

Sampling Run 2 Time: 12:58 - 13:34

CP	1	Initial Meter Reading (I)	478470
14.5	1		479000
36	1	Volume Sampled (I)	530
10148	1	Isokineticity Error (%)	1.5
Meter	0.530 Expectec 0.5	22 (Maximum Allowed Error = -5	
	14.5 36 10148	14.5 36 10148	14.5 Final Meter Reading (I) 36 Volume Sampled (I) 10148 Isokineticity Error (%)

Corrected Volume = 0.48 Nm³ (at NTP)

FILTER WEIGHTS

WASHINGS WEIGHTS

Test Number	Filter No	Pre-Weight (mg	Post-Weight (mg)	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	10147	53.80	53.82	0.00		0.02
2	10148	54.29	54.31	0.00	0.00	0.02

TEST RESULTS

	Test 1	Test 2	Mean
Particulate Concentration(mg/Nm³)			
Mass Emission (g/hr)	0.03	0.03	0.03

stkpsi Issue 1 [11/2001]

Filename: 34258 App 1 LEV 23 Date: 13/09/2005

South Site - LEV 27	Stack Area (m ²)	0.018
OEH 34258	Meter Temp (C)	30
Sandvik	Stack Diameter (cm)	15
15th August 2005	Pitot Factor	1.00
	Pitot Factor (sqrt)	1.00
	Stack Pressure (Pa)	1250
	Ambient Pressure (kPa)	101.3
	Nozzle Size (mm)	3.00
	OEH 34258 Sandvik	OEH 34258 Sandvik Stack Diameter (cm) Pitot Factor Pitot Factor (sqrt) Stack Pressure (Pa) Ambient Pressure (kPa)

Traverse Point	A1	A2	A3	A4	A5
Distance From Near Wall (D)	0.150	0.250	0.500	0.750	0.850
Pitot Reading (Pa)	835	842	850	863	856
Temperature (°C)	45	45	45	45	45
Duct Velocity (m/s)	38.8	39.0	39.1	39.4	39.3

Absolute Mean Duct Velocity (m/s)	39.1
Absolute Flow Rate (m³/hr)	2490
Normalised Flow Rate (Nm³/hr)	2164

Sampling Run 1 Time: 10:58 - 11:28

		20100 22120		
Sampling Point	CP]	Initial Meter Reading (I)	476875
Sampling Rate (I/min)	16.0		Final Meter Reading (I)	477355
Sampling Duration (mins)	30		Volume Sampled (I)	480
Filter No	9993		Isokineticity Error (%)	0.0
Volume Sampled (m³)	Meter	0.480 Expectec 0.4	80 (Maximum Allowed Error =	5 to +15%)

Corrected Volume = 0.43 Nm³ (at NTP)

Sampling Run 2 Time: 11:35 - 12:05

Sampling Point	CP	1	Initial Meter Reading (I)	477355
Sampling Rate (I/min)	16.0	1	Final Meter Reading (I)	477835
Sampling Duration (mins)	30	1	Volume Sampled (I)	480
Filter No	9994		Isokineticity Error (%)	0.0
Volume Sampled (m³)	Meter	0.480 Expectec 0.480	(Maximum Allowed Error = -	5 to +15%)

Corrected Volume = 0.43 Nm³ (at NTP)

FILTER WEIGHTS WASHINGS WEIGHTS

Test Number	Filter No	Pre-Weight (mg)	Post-Weight (mg)	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	9993	54.03	54.15	0.00		0.12
2	9994	55.18	55.20	0.00	0.00	0.02

TEST RESULTS

		Test 2	
Particulate Concentration(mg/Nm³)	0.28	0.05	0.16
Mass Emission (g/hr)	0.60	0.10	0.35

stkpsi Issue 1 [11/2001] Filename: 34258 App 1 LEV 27 Date: 13/09/2005

Plant Type Job Number Client Name Date	South Site - LEV 45 OEH 34258 Sandvik 15th August 2005	Stack Area (m²) Meter Temp (C) Grille Dimensions (cm) Pitot Factor Pitot Factor (sqrt)	30
		Stack Pressure (Pa) Ambient Pressure (kPa) Nozzle Size (mm)	0 101.3 5.00

There is no stack fitted and so sampling made non-isokinetically from outlet grille of wet collector No accurate flow measurements are possible

Sampling Run 1	Time:	13:47	- 14:17			
Sampling Point	СР	1			Initial Meter Reading (I)	479001
Sampling Rate (I/min)	15.0				Final Meter Reading (I)	479451
Sampling Duration (mins)	30	1			Volume Sampled (I)	450
Filter No	10150				4	
Volume Sampled (m³)	Meter	0.450	Expected	0.450		
Corrected Volume =			0.41	Nm³ (at	NTP)	

Sampling Run 2	Time:	14:20 - 15:00
Sampling Point	CP	Initial Meter Reading (I) 479451
Sampling Rate (I/min)	15.0	Final Meter Reading (I) 480021
Sampling Duration (mins)	40	Volume Sampled (I) 570
Filter No	10151	
Volume Sampled (m³)	Meter	0.570 Expectec 0.600
Corrected Volume =		0.51 Nm³ (at NTP)

WASHINGS WEIGHTS FILTER WEIGHTS

Test Number	Filter No	Pre-Weight (mg)	Post-Weight (mg	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	10150	55.80	55.87	0.00	0.00	0.07
2	10151	55.93	56.02	0.00	0.00	0.09

TEST RESULTS

	Test 1	Test 2	Mean
Particulate Concentration(mg/Nm³)	0.17	0.18	0.17
Mass Emission (g/hr)	-	-	-

Filename: 34258 App 1 LEV 45

Date: 13/09/2005

Plant Type	North Site - LEV 3	Stack Area (m ²)	0.165	
Job Number	OEH 34258	Meter Temp (C)	30	
Client Name	Sandvik	Stack Dimensions (cm)	55 x 30	
Date	16th August 2005	Pitot Factor	1.00	
		Pitot Factor (sqrt)	1.00	
		Stack Pressure (Pa)	250	
		Ambient Pressure (kPa)	101.3	
		Nozzle Size (mm)	5.00	

Traverse Point	A1	A2	A3	A4	A5	A6	A7	A8	A9	A10
Distance From Near Wall (D)	0.065	0.125	0.250	0.375	0.450	0.550	0.625	0.750	0.875	0.935
Pitot Reading (Pa)	61	58	59	63	64	65	65	63	62	55
Temperature (°C)	30	30	30	30	30	30	30	30	30	30
Duct Velocity (m/s)	10.2	10.0	10.1	10.4	10.5	10.6	10.6	10.4	10.3	9.7

Absolute Mean Duct Velocity (m/s)	10.3
Absolute Flow Rate (m³/hr)	6104
Normalised Flow Rate (Nm³/hr)	5513

Sampling Run 1 Time: 12:00 - 12:40

Sampling Point	A2	A4	A7	A9	Initial Meter Reading (I)	994604	
Sampling Rate (I/min)	12.0	12.8	13.0	12.6	Final Meter Reading (I)	995090	
Sampling Duration (mins)	10	10 10 10 10 Volume Sampled (I)	10 10 10 10 Volume Sampled	Volume Sampled (I)	486		
Filter No	10141	10141	10141	10141	Isokineticity Error (%)	-3.6	
Volume Sampled (m³)	Meter	0.486	Expected	0.504	(Maximum Allowed Error = -5	to +15%)	

0.44 Nm³ (at NTP) Corrected Volume =

Sampling Run 2 Time: 12:43 - 13:23

eamping italia	1111101	~~!!!	20120			
Sampling Point	A2	A4	A7	A9	Initial Meter Reading (I)	995091
Sampling Rate (I/min)	12.0	12.8	13.0	12.6	Final Meter Reading (I)	995601
Sampling Duration (mins)	10	10	10	10	Volume Sampled (I)	510
Filter No	10142	10142	10142	10142	Isokineticity Error (%)	1.2
Volume Sampled (m³)	Meter	0.510	Expected	0.504	(Maximum Allowed Error = -5	to +15%)

0.46 Nm³ (at NTP) Corrected Volume =

> **FILTER WEIGHTS WASHINGS WEIGHTS**

Test Number	Filter No	Pre-Weight (mg	Post-Weight (mg)	Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1	10141		54.49	0.00		0.68
2	10142	54.10	54.66	0.00	0.00	0.56

TEST RESULTS

	Test 1	Test 2	Mean
Particulate Concentration(mg/Nm³)	1.55	1.22	1.39
Mass Emission (g/hr)	8.6	6.7	7.6

stkpsi Issue 1 [11/2001] Filename: 34258 App 1 LEV 3 Date: 13/09/2005

Plant Type Job Number Client Name Date	North Site - LEV 8 OEH 34258 Sandvik 16th August 2005	Stack Area (m²) Meter Temp (C) Grille Dimensions (cm) Pitot Factor Pitot Factor (sqrt) Stack Pressure (Pa) Ambient Pressure (kPa) Nozzle Size (mm)	0 101.3
		NUZZIE SIZE (MM)	5.00

There is no stack fitted and so sampling made non-isokinetically from outlet grilles of the filters There are two filters units connected to the same extraction, one test was made from each.

No accurate flow measurements are possible

Sampling Run 1	Time:	12:51 - 13:31			
Sampling Point	CP (RHS)	•		Initial Meter Reading (I)	482125
Sampling Rate (I/min)	14.0]		Final Meter Reading (I)	482650
Sampling Duration (mins)	40	1		Volume Sampled (I)	525
Filter No	10161			rolanio campica (i)	323
Volume Sampled (m³)	Meter	0.525 Expected	0.560		
Corrected Volume =			Nm³ (at	NTP)	

Sampling Run 2	Time:	13:40 - 14:22	
Sampling Point	CP (LHS)	Initial Meter Reading (I)	482652
Sampling Rate (I/min)	14.0	Final Meter Reading (I)	483200
Sampling Duration (mins)	40	Volume Sampled (I)	
Filter No	10162		548
Volume Sampled (m³)	Meter	0.548 Expectec 0.560	
Corrected Volume =		0.49 Nm³ (at NTP)	

FILTER WEIGHTS WASHINGS WEIGHTS

0.49 Nm3 (at NTP)

				AAWSHITHOS AA	EIGHIO	
Test Number	Filter No	Pre-Weight (mg	Post-Weight (mg	Pre-Weight (mg	Post-Weight (mg)	Gain (mg)
1	10161	55.16	55.20	0.00		0.04
2	10162	55.67	55.70	0.00		-
				0.00	0.00	0.03

TEST RESULTS Mean Test 1 Test 2 Particulate Concentration(mg/Nm³) 0.08 0.06 0.07 Mass Emission (g/hr)

stkpsi Issue 1 [11/2001]

Filename: 34258 App 1 LEV 8

Date: 13/09/2005

Plant Type Job Number Client Name Date North Site - New Filter OEH 34258 Sandvik 16th August 2005 Large Filter Unit With Stack - Ball Mills in B5	Stack Area (m²) Meter Temp (C) Stack Diameter (cm) Pitot Factor Pitot Factor (sqrt) Stack Pressure (Pa) Ambient Pressure (kPa) Nozzle Size (mm)	0.126 30 40 1.00 1.00 50 101.3 6.00	
---	---	--	--

								1	10	A 4 A
E Dainh	A1	A2	A3	A4	A5	A6	A7	A8	A9	A10
Traverse Point			0.250	0.350	0.450	0.550	0.650	0.750	0.850	0.935
Distance From Near Wall (D)	0.065	0.150				32	31	30	30	25
Pitot Reading (Pa)	26	30	. 30	30	31				30	30
Temperature (°C)	30	30	30	30	30	30	30	30		
	6.7	7.2	7.2	7.2	7.3	7.4	7.3	7.2	7.2	6.6
Duct Velocity (m/s)			B3	B4	B5	B6	B7	B8	B9	B10
Traverse Point	B1	B2	177.7				0,650	0.750	0.850	0.935
Distance From Near Wall (D)	0.065	0.150	0.250	0.350	0.450	0.550				25
Pitot Reading (Pa)	28	30	29	28	30	31	32	31	30	
	30	30	30	30	30	30	30	30	30	30
Temperature (°C)				6.9	7.2	7.3	7.4	7.3	7.2	6.6
Duct Velocity (m/s)	6.9	7.2	7.1	0.9	7.2	7.10				

Absolute Mean Duct Velocity (m/s)	7.1
Absolute Flow Rate (m³/hr)	3217
Normalised Flow Rate (Nm³/hr)	2900

1 Time: 11:01 - 11:37

Sampling Run 1	Time:	TTIOT	TYIN		CONTRACTOR	481160
Sampling Point	A2	A9	B2		Initial Meter Reading (I)	
Sampling Rate (I/min)	12.2	12.2	12.2		Final Meter Reading (I)	481585
Sampling Nate (1/11/17) Sampling Duration (mins)	9	9	9		Volume Sampled (I)	425
The state of the s	10159	10159	10159	10159	Isokineticity Error (%)	-3.2
Filter No	Meter	0.425	Expected	0.439	(Maximum Allowed Error = -5 to -	+15%)
Volume Sampled (m³) Corrected Volume =	Meter	U. ILU	0.38	Nm³ (a	t NTP)	
Corrected volume =					The second of th	20

001100100

Sampling Run 2	Time:	11:41	- 12:25			404 505
Sampling Point	A2	A9	B2		Initial Meter Reading (I)	481585
Sampling Rate (I/min)	12.2	12.2	12.2		Final Meter Reading (I)	482125
Sampling Duration (mins)	11	11	11		Volume Sampled (I)	540
Filter No	10160	10160	10160	10160	Isokineticity Error (%)	0.6
Volume Sampled (m³)	Meter	0.540			(Maximum Allowed Error = -5 to) +15%)
Corrected Volume =			0.49	Nm³ (a	t NTP)	40 Rf

FILTER WEIGHTS WASHINGS WEIGHTS

	LILIEK	AAFTGIIIA			Doot Weight (mg)	Cain (mg)
Test Number	Filter No	Pre-Weight (mg	Post-Weight (mg	g Pre-Weight (mg)	Post-Weight (mg)	Gain (mg)
1 test realises	10159		55,60	0.00	0.00	0.04
1			56.38	0.00	0.00	0.04
2	10160	150.34	130,30	0.00		

TEST RESULTS

	Test 1	Test 2	Mean
Particulate Concentration(mg/Nm³)	0.10	0.08	0.09
Mass Emission (g/hr)	0.3	0.2	0.3

Filename: 34258 App 1 B5 Large New Date: 13/09/2005

stkpsi Issue 1 [11/2001]

- 8 APPENDIX IV
- 8.1 Metals Determination Spreadsheet

Report No: OEH34258 CS F Page 17 of 20

OEH Group Limited - Metals Determination Spreadsheet

Client: Sandvik Hard Materials - Coventry - Part B Processes

Ctack Deference	Tect Number	Filter Ref	Volume (I)	Soln Ref	Total Cobalt (µg)	Cobalt Conc (mg.m-3)	Total Tungsten (µg)	Tungsten Conc (mg.m-3)
Stack Kelerence					,	6000	•	0.003
South Site	1	10187	310	Sc //c/	•	5000	4 (0 10
LEV 002	2	10189	310	759/ 60	1	0.003	20	0.065
	Mean					0.003		0.034
Comble Cibo	*	10188	330	761/62	9	0.015	IS.	0.131
			0 0	763164	٠	500.0	288	0,149
LEV 12A	7	OFTOT	060	100/	1	0.010	;	0.140
	Mean						00	ACC 0
South Site		10193	380	769/ 70		0.003	68 -	0,234
1 EV 15	2	10194	200	771/72	-	0.002	22	0.044
	Mean					0.002		0.139
South Site	1	10191	340	765/ 66	ന	600'0	41	0.121
15/30		10192	340	267/ 68	-	0,003	- -1	0.003
ì	Mean			•		9000		0.062
South Site	-	10147	480	841/42	-1	0.002	16	0.033
1 EV 23		10148	480	843/ 44	m	9000	47	0,085
	Mean	 				0.004		0.059
Courth Site		9993	430	799/ 800	2	0.005	47	0.109
1 EV 27	. ^	9994	430	801/02	y-4	0.002	፠	0,084
	Mean					0,003		0,097
South Site	-	10150	410	845/46	2	500.0	02	0.049
1 FV 45	2	10151	510	847/48	m	0.006	4.	0.027
ì	Mean	,		•	-	0,005		0.038
North Cite		10141	94	781/82	24	0.055	34	2,0077
I EV 3		10142	460	783/84	88	0.061	47	0.102
ì	Mean	! í				0.058		060'0
North Site		10161	470	857/ 58	5	0.011	20	0.043
I EV &	2	10162	490	859/ 60	2	0.004	i	0.002
i	Mean				****	0.007		0.022
North Site	-	10157	490	849/ 50		0.002	10	0.020
Small New	2	10158	530	851/52	O 译辑	0.000	89	0.128
Eilter	Mean					0.001		0.074
North Site		10159	380	853/ 54	+	0.003	25	990'0
large New	2 2	10160	490	855/ 56	H	0.002	35	0.071
	M					0.002		0.069

- 9 APPENDIX V
- 9.1 Equipment Calibration Certificates

Report No: OEH34258 CS F Page 18 of 20

8010A

CERTIFICATE OF CALIBRATION

Issued by: RS Components Ltd

Date of Issue:

03-May-2005

Certificate No. 113451



R5 Calibration

Calibration and Repair Service Venture Close, Lammas Rd, Corby, Northants NN17 5UB

Tel: 01536 405545 Fax: 01536 401590 Page 1 of 2 Pages

Approved signatory



Client

OEH GROUP LTD.

BIRMINGHAM

B7 4BS

Instrument:

Mitutoyo 150 mm Digital Caliper

Procedure ID.

MLCP01

Serial No.

04414420

Client ID

AQ168

Date Received

29-Apr-2005

Date of Calibration

03-May-2005

Remarks

The reported results are for the instrument as received.

The measured results were found to be within the tolerances specified by the manufacturer.

Uncertainties

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a level of confidence of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories.

This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

Dane 1 of 1

Issue No. 1

Team Date In June AQ001 July 2005

A 0 00 i

Stackmite Reference:

Test Date:

AQSOP 10:1

01/08/2005

AQ 046 Reference Gas: Meter No:

Reference Gas Meter Certificate: N 112 5959F

Reference Gas Meter Calibration Date: 20/08/2004

Section 1: Calibration Record

	,	W					
		Test Stackmite Gas Reference Gas Meter Temperature (°C)	Finish	24.7	25.4	25.5	25.6
		Refere	Start	23.5	25.1	25.4	25.5
08:40		Test Stackmite Gas Meter Temperature (°C)	Finish	39.4	41.7	42.2	42.2
		Test Stackm Meter Temp (°C)	Start	37.8	40.6	41.7	41.7
		Rotameter Flow, ipm	Reference (Calculated)	20.04	15.07	96.6	4.95
	08:40	Rotameter	Stackmite	20	15	10	5
	Finish:	sas Meter s, litres	(MTIP)	829	621	410	272
	rt: 08:10 Finish:	Reference Gas Meter Readings, litres	Finish	52197	52878	53333	53637
_	Start:		Start	51295	52200	5,2885	53340
	Warm up Period Sta	Test Stackmite Gas Meter Reading, litres	Finish A (NTP)	828	617	409	272
	Warm u	Nackmite Gas P Reading, litres	Finish	494125	494840	495322	495644
		Test Sta	Start	493130	494131	494850	495330
	*	S	٧	45	45	45	09
	Leak Check (Y/N) Y	Time Period, min	Finish	09:30	10:20	11:20	12:25
	eak Che	Tin	Stairt	08:45	09:35	10:25	11:25
		Flow Setting, Ipm	in .	20	15	10	ស

Section 2: Calculations

Indicated rotameter flow, lym Stackmite flow setting, Ipm Actual rotameter flow, Ipm

Stackmite gas meter volume, I Reference gas meter volume, I % Difference Test:Reference

% Difference Test:Reference

1.01% 0.22% 271.6 4 95 272 0.45% -0.16% 96'6 409.8 Ç 10 -0,44% -0.65% 620.6 15.07 617 딘 -0.22% -0.11% 828.8 20,04 828 20 S

The overall uncertainty of measurements was

2.52 | %

multiplied by a coverage factor of k=2.00, providing a level of confidence of The reported expanded uncertainty is based on a standard uncertainty approximately 95%.

All must be < +/-2%

PASS

All must be < +/-2%

PASS

Callibrated By:

Signature:

THE RESIDENCE

Issue No. 1

AQ003 July 2005

40 003 05/08/2005

Stackmite Reference:

Test Date:

AQSOP 101

Reference Gas Meter Certificate: N 112 5959F AQ 046 Reference Gas Meter No:

Reference Gas Meter Calibration Date: 20/08/2004

Section 1: Calibration Record

		ture	ish	9	1	ω,	6
		rence Ga empera (•C)	Fin	23.6	24	24.	24.9
	1. · · · · · · · · · · · · · · · · · · ·	Refer Meter To	Start	23.2	23.5	23.9	24.1
		Test Stackmite Gas Reference Gas Meter Temperature Meter Temperature (°C)	Finish	26,0	27.0	28.0	28.0
	, denie de l'année de	Test Stack Meter Tem (<(Start	25.0	25.0	26.0	27.0
		Rotameter Flow, Iprn	Reference (Calculated)	20.10	14.93	9.94	4.98
08.30	08:30	Rotameter	Stackmilte	20	1.5	10	2
	Finish:	Reference Gas Meter Readings, litres	(MITIP)	555	618	457	297
	07:45	ference Gas Met Readings, litres	Finish	56291	58977	5948.7	50805
	Start:	Test Stackmite Gas Meter Reference Gas Meka Reading, litres	Start	57638	53305	53930	59501
	p Period		Finish Δ (NTP)	552	623	461	300
	Warm u		Finish	1012320	1012717	1013237	1013580
		Test Sta	Start	1012216 1012320	1012035	1012730	1013250 1013580
	⋆	Ę	∇ 1	30	4	20	65
_	Leak Check (Y/N) Y	Check (Y/N) Time Period, min	Finish	20:60	09:55	10:50	12:00
	eak Chec	Time	Sart	08:35	06:30	10:00	10:55
	j	Flow Setting, Inca		20	1.5	10	ΕV

Section 2: Calculations

Indicated rotameter flow, ipm Stackmite gas meter volume, I % Difference Test: Reference Stackmite flow seltling, Ipin Actual rotameter flow, Ipm

Reference gas meter volume, I

% Difference Test: Reference

0.31% 0.84% 297.3 4.98 300 0.60% 1.03% 90.0 456,7 461 10 10 0.45% 14,93 618.1 0.74% 623 ដ 13 -0.50% -0.54% 20,10 555.4 552 2C 2

The overall uncertainty of measurements was

2.52 %

multiplied by a coverage factor of k=2.00, providing a level of confidence of The reported expanded uncertainty is based on a standard uncertainty approximately 95%.

All must be < +/- 2%

PASS

√III must be < +/- 2%

PASS

Calibrated By:

Signature:

EQUIPMENT CALIBRATIONTHERMOCOUPLE READERS

Test Thermocouple Reader Reference:	AQ 004
Calibration Date:	28/04/05
Reference Thermocouple Simulator No:	AQ 67
Calibrated Date:	11/05/04
Simulator Calibration Certificate No:	22350

Simulator Temperature (degrees C)	Test Reader Response (degrees C)	% Difference (Test:Ref) (Maximum Allowed +/- 1.0%) (Kelvin)	Pass/Fail
0	-0.1	-0.04	Pass
100	99.7	-0.08	Pass
500	499.4	-0.08	Pass
1000	999.5	-0.04	Pass

The overall uncertainty of measurements was


0.14	un	its 🖰	/c

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor of k=2.00, providing a level of confidence of approximately 95%.

Calibrated By:	
Signature:	

CERTIFICATE OF CALIBRATION

ISSUED BY



DATE OF ISSUE: 04 May 2005

CERTIFICATE NUMBER: N8907/05





Littlebrook Calibration & Manufacturing Ltd

Littlebrook Complex Manor Way Dartford Kent, DA1 5PU

Telephone (01322) 280038

Facsimile (01322) 284835

APPROVED SIGNATORY

LCM REF: LCM4426/05/1

CUSTOMER DETAILS

Company Address : OEH Group Limited

: 253-255 Great Lister Street

Birmingham, B7 4BS

Order number

: 4295

UNIT CALIBRATED

Manufacturer

: Airflow Developments

Model

: L-Type Pitot tube

Range

: 3 to 30 m/s

Serial number

: AQ095

Date unit received

: 12/04/2005

Date calibrated

: 04/05/2005

LABORATORY CONDITIONS

: Temperature 23°C ± 2°C

CALIBRATION PROCEDURES

: PROC0025

The uncertainties reported relate only to the measured values and do not imply any long-term performance for the instrument.

UKAS Calibration For Air Velocity.

Approved Signatory (Print): A M Sidgwick

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to the units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. UKAS is one of the signatories to the Multilateral Agreement of the European co-operation for Accreditation (EA) for the mutual recognition of calibration certificates issued by accredited laboratories.

CERTIFICATE OF CALIBRATION

ISSUED BY



HOORY

DATE OF ISSUE: 05 May 2005

CERTIFICATE NUMBER: N8913/05



Littlebrook Calibration & Manufacturing Ltd

Littlebrook Complex Manor Way Dartford Kent, DA1 5PU

Telephone (01322) 280038

Facsimile (01322) 284835

PAGE 1 OF 3 PAGES



LCM REF: LCM4426/05/7

CUSTOMER DETAILS

Company

: OEH Group Ltd

Address

: 253-255.Great Lister Street

Birmingham B7 4BS

Order number

: 4295

UNIT CALIBRATED

Manufacturer

: Testo

Model

: 512 Digital Manometer

Range

: 0 to 20 mbar differential

Serial number

: 30208024 (AQ064)

Date unit received

: 12/04/2005

Date calibrated

: 15/04/2005

LABORATORY CONDITIONS

: Temperature 20.1°C ± 1.5°C

CALIBRATION PROCEDURE

: PROC0023

The uncertainties reported relate only to the measured values and do not imply any long-term performance for the instrument.

UKAS Calibration For Pressure.

Approved Signatory (Print): J L Whalin

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to the units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. UKAS is one of the signatories to the Multilateral Agreement of the European co-operation for Accreditation (EA) for the mutual recognition of calibration certificates issued by accredited laboratories.

Test Tape Reference:	AQ 49	Reference Ruler No:	AQ 45
Calibration Date:	28/04/2005	Calibration Date:	18/04/2005
		Reference Ruler Certificate No:	113111

Test Tape Interval, mm	Test Tape Nominal Length, mm	Reference Ruler Reading, mm	% Difference (Test:Ref) (Maximum Allowed +/- 0.5%)	Pass/Fail
0 - 10	10	10	0.00	Pass
0 - 50	50	50	0.00	Pass
0 - 100	100	100	0.00	Pass
0 - 250	250	250	0.00	Pass
0 - 500	500	500	0.00	Pass
0 - 750	750	750	0.00	Pass
0 - 1000	1000	1000	0.00	Pass
1000 - 1010	10	10	0.00	Pass
1000 - 1050	50	50	0.00	Pass
1000 - 1100	100	100	0.00	Pass
1000 - 1250	250	250	0.00	Pass
1000 - 1500	500	500	0.00	Pass
1000 - 1750	750	750	0.00	Pass
1000 - 2000	1000	1000	0.00	Pass
2000 - 2010	10	10	0.00	Pass
2000 - 2050	50	50	0.00	Pass
2000 - 2100	100	100	0.00	Pass
2000 - 2250	250	250	0.00	Pass
2000 - 2500	500	500	0.00	Pass
2000 - 2750	750	750	0.00	Pass
2000 - 3000	1000	1000	0.00	Pass
The overall uncertaint	y of measuren	nents was	0.00	units 2/

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor of k=2.00, providing a level of confidence of approximately 95%.

Calibrated By:	
Signature:	

Permit No: PPC 025

Operator and Installation: Sandvik - Coventry OEH Group Limited

- 10 APPENDIX VI
- 10.1 Uncertainty Calculations

Report No: OEH34258 CS F

Reference: PPC 025/Sandvik - Coventry/2005/visit 1 of 1

Uncertainty of Measurement Method for Total Particulate Matter Sampling at Sandvik

The following method for determining the total uncertainty of the Total particulate matter sampling has been devised based on the "QGN001 R1 - Guidance on Assessing Measurement Uncertainty in Stack Monitoring" – Second Edition – Issued September 2004.

This guidance sets outs three possible approaches to assessing uncertainty as follows:

Approach A: Carry out tests on a certified reference material.

Approach B: Carry out repeat measurements using paired instruments.

Approach C: Build an uncertainty budget from estimates of component uncertainties.

QGN001 R1 contains a decision tree for determining which of the three approaches above would be most appropriate.

Following the questions on the decision tree leads down the path stated below:

Can the measurement be carried out using a standard method? - Yes
Does the standard state a measurement uncertainty? - No
Can tests on reference material be carried out? - No (not for entire method)
Can experimental assessment be carried out? - No (not for entire method)

Decision – We must build up an uncertainty budget based on manufacturer's specifications, calibration certificates e.t.c. (Approach C)

Approach C

In this approach, an uncertainty budget is built from the *component* uncertainties and then these are combined to obtain an estimate of the *overall* uncertainty. Quantifying the component uncertainties can prove challenging and it is useful to concentrate on those making the most significant contribution: by convention, those components smaller than one-third of the largest need not be evaluated in detail. Once a shortlist is obtained, thought needs to be given on the most appropriate way to quantify the individual component uncertainties. Some of the uncertainties can be evaluated from sources such as suppliers information (e.g. instrument specifications, calibration certificates, tolerances), QA/QC data (e.g. control charts), inter-laboratory studies and proficiency-testing schemes. (In certain circumstances, the standard deviation of the results obtained from repeated rounds provides a good estimate of uncertainty.)

In our case we have the following list of uncertainties stated on calibration certificates from external suppliers.

Equipment Type	Expanded Uncertainty (as per certificate)	Standard Uncertainty (= expanded uncertainty/2)
Calipers	± 0.015 mm	0.13% at 6mm Nozzle
Ruler	± 0.015 mm	0.0015% at 500mm
Dry Gas Meter	± 0.35 %	0.175%
Manometer	± 0.05 % + 1pa	0.025%
Pitots	± 0.15 % + 0.25 pa	0.075%

The following equipment is calibrated in house and uncertainties have been calculated based on repeated measurements.

Equipment Type	Expanded Uncertainty	Standard Uncertainty (= expanded uncertainty/2)
Stackmite Gas Meters	2.52 %	1.26 %
Thermocouple Readers	0.14 %	0.07 %
Nozzies	0.18 %	0.09 %
Tape Measures	<0.01 %	<0.01 %
Barometers	0.28 %	0.14 %

We must also include the uncertainty contribution from the weighing procedure.

 $\sqrt{((30.18/2)^2 + (52.97/2)^2)} = \sqrt{(227.71+701.46)} = \sqrt{(929.17)} = 30.48\% = \text{standard uncertainty at method}$

Expanded uncertainty for entire method = 61.0% at weighing LOD

At reasonable levels of particulate, the filter weighing expanded uncertainty is 3.22 % and the probe wash sample expended uncertainty is 5.88 %. The weighings contribution to the total uncertainty of the method will be as follows:

 $\sqrt{((3.22/2)^2 + (5.88/2)^2)} = \sqrt{(2.59 + 8.64)} = \sqrt{(11.23)} = 3.35\%$ = standard uncertainty with significant weight gain.

Expanded uncertainty of weighings only = 6.70% at moderate levels of particulate.

The only other contributor to the total uncertainty at % levels at or above 1/3rd of the greatest contributor is that from the stackmite meter calibrations – the expanded uncertainty of these is 2.52%. So for the entire method we only need to include the following contributory uncertainties.

Filter weighings. Probe Wash Samples. Stackmite Gas Meter Calibrations.

The calculation is as follows:

 $\sqrt{((3.22/2)^2 + (5.88/2)^2 + (2.52/2)^2)} = \sqrt{(2.59 + 8.64 + 1.59)} = \sqrt{(12.82)} = 3.58\% = standard$ uncertainty with significant weight gain.


Expanded uncertainty for entire method = 7.2% at moderate levels of particulate.

- 11 APPENDIX VII
- 11.1 Sampling Location Diagrams


Report No: OEH34258 CS F

Reference: PPC 025/Sandvik - Coventry/2005/visit 1 of 1


Sampling Location Diagram — LEV 002 — Sandvik Coventry




Sampling Location Diagram — LEV 3 — Sandvik Coventry




Sampling Location Diagram — LEV 8 — Sandvik Coventry




Sampling Location Diagram — LEV 12A — Sandvik Coventry




Sampling Location Diagram — LEV 23 — Sandvik Coventry




Sampling Location Diagram — LEV 27 — Sandvik Coventry



Sampling Location Diagram — LEV 45 — Sandvik Coventry



Sampling Location Diagram — New Filter (B5 Furnaces) — Sandvik Coventry



Sampling Location Diagram — New Filter (B5 Ball Mills — Sandvik Coventry

