

# **COVRAD HEAT TRANSFER LTD**

**Report on Air Emission Monitoring at  
Covrad Heat Transfer Ltd  
Canley, Coventry  
December 2006**

**Stack Emission Monitoring Report – Executive Summary  
Ref. FTA 5889**



1709



1709

**Report for Periodic Monitoring of Emissions to Atmosphere**

Part 1: **Executive Summary**

Operator: **Covrad Heat Transfer Ltd**

Installation: **Canley, Coventry**

Emission Points: **Red Oxide Booth  
Industrial Spray Booth 1  
Industrial Spray Booth 2  
Assembly Shop Spray Booth**

Monitoring Dates: **5<sup>th</sup> – 7<sup>th</sup> December 2006**



1709



1709

Contract Reference: **FTA 5889**

Operator: **Covrad Heat Transfer Ltd**

Address: **Sir Henry Parkes Road  
Canley  
Coventry  
CV5 6BN**

Monitoring Organisation: **RPS Health, Safety & Environment**

Address: **Steadings Barn, Pury Hill Business Park, nr Alderton,  
Towcester, Northamptonshire, NN12 7LS**

Report Date: **15<sup>th</sup> January 2007**

Report Approved By: **Brett Durden**

Position: **Technical Director**

MCERTS Registration No.: **MM 03 167**

Signature: 

RPS Health, Safety and Environment has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

## CONTENTS

### Part 1: Executive Summary

Monitoring Objectives .....	3
Monitoring Results .....	4
Operating Information.....	8
Monitoring Deviations .....	9

## Monitoring Objectives

At the request of Mr R. Holmes of Covrad Heat Transfer Ltd., RPS Health, Safety and Environment conducted air emission monitoring at the Canley site, Coventry in December 2006.

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for comparison with the limits specified in the air emission criteria for this site.

The parameters requested for monitoring at each emission point and the actual monitoring conducted are detailed below.

**Table 1**

Parameters Requested to be Monitored	Emission Points							
	Red Oxide Booth	Industrial Spray Booth 1		Industrial Spray Booth 2		Assembly Shop Spray Booth		
		Left Exhaust	Right Exhaust	Left Exhaust	Right Exhaust	Exhaust #1	Exhaust #2	Exhaust #3
Total Particulate Matter	4	4	4	4	4	4	4	4
Specific Requirements	Normal Operating Conditions							

*Notes:*

4 Represents the actual parameters monitored

8 Represent parameters requested but not actually monitored

## Monitoring Results

Table 2 – Monitoring Results from the Red Oxide Booth Exhaust at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 2/3K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	8.1	mg/m <sup>3</sup>	± 0.88	wet gas, without correction for oxygen	5-Dec-06	10:19 – 11:20	BS-EN 13284-1 2002	MCERTS	Normal

## Notes:

# The uncertainty associated with the quoted result is at the 95% confidence interval

y Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes

Table 3 – Monitoring Results from the Industrial Spray Booth 1 - Left Exhaust at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 2/3K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	1.7	mg/m <sup>3</sup>	± 0.19	wet gas, without correction for oxygen	6-Dec-06	10:52 – 11:54	BS-EN 13284-1 2002	MCERTS	Normal

## Notes:

# The uncertainty associated with the quoted result is at the 95% confidence interval

y Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes

**Table 4 – Monitoring Results from the Industrial Spray Booth 1 - Right Exhaust at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 273K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	1.8	mg/m <sup>3</sup>	± 0.20	wet gas, without correction for oxygen	6-Dec-06	12:03 – 13:05	BS-EN 13284-1 2002	MCERTS	Normal

**Notes:**

# The uncertainty associated with the quoted result is at the 95% confidence interval

y Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes

**Table 5 – Monitoring Results from the Industrial Spray Booth 2 - Left Exhaust at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 273K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	7.7	mg/m <sup>3</sup>	-	wet gas, without correction for oxygen	7-Dec-06	10:22 – 11:22	BS-EN 13284-1 2002	MCERTS	Normal

**Notes:**

# The uncertainty associated with the quoted result is at the 95% confidence interval

y Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes

**Table 6 – Monitoring Results from the Industrial Spray Booth 2 - Right Exhaust at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 273K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	3.6	mg/m <sup>3</sup>	-	wet gas, without correction for oxygen	6-Dec-06	14:50 – 15:50	BS-EN 13284-1 2002	MCERTS	Normal

**Notes:**# *The uncertainty associated with the quoted result is at the 95% confidence interval*\* *Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes***Table 7 – Monitoring Results from the Assembly Shop Spray Booth Exhaust #1 at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 273K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	9.7	mg/m <sup>3</sup>	± 1.1	wet gas, without correction for oxygen	5-Dec-06	14:54 – 15:55	BS-EN 13284-1 2002	MCERTS	Normal

**Notes:**# *The uncertainty associated with the quoted result is at the 95% confidence interval*\* *Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes*

**Table 8 – Monitoring Results from the Assembly Shop Spray Booth Exhaust #2 at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 273K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	1.3	mg/m <sup>3</sup>	± 0.14	wet gas, without correction for oxygen	7-Dec-06	14:16 – 15:17	BS-EN 13284-1 2002	MCERTS	Normal

**Notes:**

# The uncertainty associated with the quoted result is at the 95% confidence interval

y Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes

**Table 9 – Monitoring Results from the Assembly Shop Spray Booth Exhaust #3 at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

Substance Monitored	Emission Limit Value <sup>y</sup>	Periodic Monitoring Result	Units	Uncertainty (mg/m <sup>3</sup> ) #	Reference Conditions 273K, 101.3kPa....	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	0.89	mg/m <sup>3</sup>	± 0.097	wet gas, without correction for oxygen	7-Dec-06	13:39 – 14:41	BS-EN 13284-1 2002	MCERTS	Normal

**Notes:**

# The uncertainty associated with the quoted result is at the 95% confidence interval

y Emission Limit Value taken from Secretary of State Process Guidance Note 6/23(04) – Guidance for Coating of Metal and Plastic Processes

**Operating Information**

**Table 10 – Operating Information During Monitoring of the Specified Spray Booth Exhausts at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

Parameter	Red Oxide Booth	Industrial Spray Booth 1		Industrial Spray Booth 2		Assembly Shop Spray Booth		
		Left Exhaust	Right Exhaust	Left Exhaust	Right Exhaust	Exhaust #1	Exhaust #2	Exhaust #3
Sample Date	5-Dec-06	6-Dec-06	6-Dec-06	7-Dec-06	6-Dec-06	5-Dec-06	7-Dec-06	5-Dec-06
Process Type	Manual spraying of red oxide based primer onto radiator parts	Manual spraying of solvent free paint onto radiator parts	Manual spraying of solvent free paint onto radiator parts	Manual spraying of solvent free paint onto radiator parts	Manual spraying of solvent free paint onto radiator parts	Manual spraying of solvent free paint onto radiator parts and completed units	Manual spraying of solvent free paint onto radiator parts and completed units	Manual spraying of solvent free paint onto radiator parts and completed units
Process Duration	Variable depending on size of part	Variable depending on size of part	Variable depending on size of part	Variable depending on size of part	Variable depending on size of part	Variable depending on size of part	Variable depending on size of part	Variable depending on size of part
If 'Batch', was monitoring carried out over the whole batch?	Yes – several parts sprayed during monitoring period	Yes – several parts sprayed during monitoring period	Yes – several parts sprayed during monitoring period	Yes – several parts sprayed during monitoring period	Yes – several parts sprayed during monitoring period	Yes – several parts sprayed during monitoring period	Yes – several parts sprayed during monitoring period	Yes – several parts sprayed during monitoring period
If 'No', give details	-	-	-	-	-	-	-	-
Abatement/Operational?	Filters - Yes	Filters - Yes	Filters - Yes	Filters - Yes	Filters - Yes	Filters - Yes	Filters - Yes	Filters - Yes
Feedstock	Radiator Components and parts	Radiator Components and parts	Radiator Components and parts	Radiator Components and parts	Radiator Components and parts	Radiator Components and parts	Radiator Components and parts	Radiator Components and parts
Throughput	Varies	Varies	Varies	Varies	Varies	Varies	Varies	Varies

**Monitoring Deviations****Table 11 – Monitoring Deviations During Monitoring of the Specified Spray Booth Exhausts at Covrad Heat Transfer Ltd., Canley, Coventry in December 2006**

<b>Substance Deviations</b>	<b>Monitoring Deviations</b>	<b>Other Relevant Issues</b>
None	<b>Industrial Spray Booth 2 Exhausts 1 &amp; 2</b> – Only one sample line was available for monitoring due to platform and exhaust constraints. BS EN 13284 requires two sample lines be monitored and if not possible then uncertainty cannot be quoted. Time at available sample points was increased accordingly.	

**REPORT FOR PERIODIC MONITORING OF THE  
INDUSTRIAL, NEW, RED OXIDE BOOTHS AND TRIKE  
BATH.**

**COVRDAD HEAT TRANSFER LTD, COVENTRY.**

**FEBRUARY 2006**

**Report for Periodic Monitoring of Emissions to Atmosphere**

Part 1: **Executive Summary**

Operator: **Covrad Heat Transfer Ltd**

Installation: **Covrad Heat Transfer Ltd, Coventry,  
Warwickshire.**

Emission Point: **Industrial, New, Redox Booth and Trike  
bath**

Monitoring Date(s): **9<sup>th</sup> – 11<sup>th</sup> January 2006**

Contract Reference: **FYS3926**

Operator: **Covrad Heat Transfer**

Address: **Sir Henry Parks Road  
Canley  
Coventry  
CV5 6BN**

Monitoring Organisation: **RPS Health, Safety & Environment**

Address: **Unit 1, Lowfields Business Park, Old Power  
Way, Elland, HX5 9DE**

Report Date: **February 2006**

Report Approved By: **Antony Sumner**

Position: **Quality Manager-Stack Emissions**

MCERTS Registration Number: **MM 03 233**

Signature:

A rectangular box containing a solid black redaction, with a handwritten mark resembling a checkmark or the letter 'v' to the left of the box.

RPS Health, Safety and Environment has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

## **CONTENTS**

### **Part 1: Executive Summary**

**Section 1 – Monitoring Objectives**

**Section 2 – Monitoring Results**

**Section 3 – Monitoring Deviations**

### **Part 2: Supporting Information**

**Appendix 1 – General information**

**Appendix 2 – Raw Sampling Data, Analysis Data & Uncertainty.**

## Monitoring Objectives

At the request of Mr Bob Holmes of Covrad Heat Transfer Ltd, RPS Health, Safety and Environment conducted stack emission monitoring at the Coventry site, Warwickshire in January 2006.

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for comparison with the limits specified in the authorisation for this site, as issued by Warwickshire Council in accordance with process guidance note (PG 6/23) (04) “Coating of metals and plastics”

The parameters requested for monitoring at each emission point and the actual monitoring conducted are detailed below.

**Table 1.1**

Parameters Requested to be Monitored	Emission Point
	Stack 1
	Industrial Spray Booth 1
Total Particulate Matter	√
High Concentration VOC (as total organic carbon)	√
<b>Specific Requirements</b>	Normal Operating Conditions

**Table 1.2**

Parameters Requested to be Monitored	Emission Point
	Stack 2
	Industrial Spray Booth 1
Total Particulate Matter	√
High Concentration VOC (as total organic carbon)	√
<b>Specific Requirements</b>	Normal Operating Conditions

*Notes:*

- √ Represents the actual parameters monitored
- X Required by authorisation but not monitored at this visit (See Section 4)

*assembly shop*

**Table 1.6**

Parameters Requested to be Monitored	Emission Point
	Stack 2
	New Booth 1
Total Particulate Matter	√
High Concentration VOC (as total organic carbon)	√
<b>Specific Requirements</b>	Normal Operating Conditions

**Table 1.7**

Parameters Requested to be Monitored	Emission Point
	Stack 3
	New Booth 1
Total Particulate Matter	√
High Concentration VOC (as total organic carbon)	√
<b>Specific Requirements</b>	Normal Operating Conditions

*assembly shop*

**Table 1.8**

Parameters Requested to be Monitored	Emission Point
	Red Oxide
Total Particulate Matter	√
High Concentration VOC (as total organic carbon)	√
<b>Specific Requirements</b>	Normal Operating Conditions

*Notes:*

- √ Represents the actual parameters monitored
- X Required by authorisation but not monitored at this visit (See Section 4)

Table 1.9

→ these  
are 2 trike  
tanks?

Parameters Requested to be Monitored	Emission Point
	Large Degreaser (Trike)
High Concentration VOC (as total organic carbon)	√
Specific Requirements	Normal Operating Conditions

Notes:

- √ Represents the actual parameters monitored
- X Required by authorisation but not monitored at this visit (See Section 4)

**Monitoring Results**

**Table 2.1 – Monitoring Results from the (Stack 1 Industrial Spray Booth Left Internal)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	0.7	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3 no correction required for O <sub>2</sub> .	10/01/2006	13:40-14:12	BS ISO 9096:2003	MCERTS	Normal
	N/A	6	g/hr							
Total Particulate Matter Run 2	50*	4.5	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3 no correction required for O <sub>2</sub> .	10/01/2006	14:30-15:32	BS ISO 9096:2003	MCERTS	Normal
	N/A	39	g/hr							
High Concentration VOC (as total organic carbon)	50*	51.97	mg/m <sup>3</sup>	4.7	Dry, 273K, 101.3 no correction required for O <sub>2</sub> .	10/01/2006	12:00-12:30	BS EN 13526:2002	MCERTS	Normal
	N/A	800	g/hr							

**Notes:**

- # *The uncertainty associated with the quoted result is at the 95% confidence interval*
- \* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*

**Table 2.2 – Monitoring Results from the (Stack 2 Industrial Spray Right Internal)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	0.5	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3 no correction required for O <sub>2</sub>	9/01/2006	13:35-14:07	BS ISO 9096:2003	MCERTS	Normal
	N/A	7	g/hr							
Total Particulate Matter Run 2	50*	0.8	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3 no correction required for O <sub>2</sub>	9/01/2006	12:00-12:30	BS ISO 9096:2003	MCERTS	Normal
	N/A	12	g/hr							
High Concentration VOC (as total organic carbon)	50*	10.86	mg/m <sup>3</sup>	14.5	Dry, 273K, 101.3 no correction required for O <sub>2</sub>	10/01/2006	12:43-13:13	BS EN 13526:2002	MCERTS	Normal
	N/A	260	g/hr							

**Notes:**

# *The uncertainty associated with the quoted result is at the 95% confidence interval*

\* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*

**Table 2.3 – Monitoring Results from the (Stack 1 Industrial Spray Left External)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	4.1	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3 no correction required for O <sub>2</sub>	9/01/2006	12:10-12:42	BS ISO 9096:2003	MCERTS	Normal
	N/A	3.6	g/hr							
Total Particulate Matter Run 2	50*	0.6	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3 no correction required for O <sub>2</sub>	9/01/2006	13:35-14:07	BS ISO 9096:2003	MCERTS	Normal
	N/A	5	g/hr							
High Concentration VOC (as total organic carbon)	50*	82.10	mg/m <sup>3</sup>	4.2	Dry, 273K, 101.3 no correction required for O <sub>2</sub>	11/01/2006	12:10-12:40	BS EN 13526:2002	MCERTS	Normal
	N/A	1230	g/hr							

**Notes:**

- # *The uncertainty associated with the quoted result is at the 95% confidence interval*
- \* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*

**Table 2.4 – Monitoring Results from the (Stack 2 Industrial Spray Right External)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	2.3	mg/m <sup>3</sup>	N/A	Dry; 273K, 101.3kPa no correction required for O <sub>2</sub> .	10/9/2004	13:35- 14:07	BS ISO 9096:2003	MCERTS	Normal
	N/A	22	g/hr							
Total Particulate Matter Run 2	50*	1.2	mg/m <sup>3</sup>	N/A	Dry; 273K, 101.3kPa no correction required for O <sub>2</sub> .	10/9/2004	12:00- 12:30	BS ISO 9096:2003	MCERTS	Normal
	N/A	11	g/hr							
High Concentration VOC (as total organic carbon)	50*	184.39	mg/m <sup>3</sup>	9.1	Dry; 273K, 101.3kPa no correction required for O <sub>2</sub> .	11/01/2006	12:10- 12:40	BS EN 13526:2002	MCERTS	Normal
	N/A	3010	g/hr							

**Notes:**

# *The uncertainty associated with the quoted result is at the 95% confidence interval*

\* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*

**Table 2.5 – Monitoring Results from the (Stack 1 New Spray Booth)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%) #	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	19.1	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3kPa, no correction required for O <sub>2</sub> .	10/9/2004	13:35-14:07	BS ISO 9096:2003	MCERTS	Normal
	N/A	273	g/hr							
Total Particulate Matter Run 2	50*	4.7	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3kPa, no correction required for O <sub>2</sub> .	10/9/2004	12:00-12:30	BS ISO 9096:2003	MCERTS	Normal
	N/A	6.4	g/hr							
High Concentration VOOC (as total organic carbon)	50*	12.30	mg/m <sup>3</sup>	12.96	Dry, 273K, 101.3kPa, no correction required for O <sub>2</sub> .	11/01/2006	11:55-12:25	BS EN 13526:2002	MCERTS	Normal
	N/A	170	g/hr							

**Notes:**

# *The uncertainty associated with the quoted result is at the 95% confidence interval*

\* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*

**Table 2.6 – Monitoring Results from the (Stack 2 New Spray Booth)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	8.1	mg/m <sup>3</sup>	N/A	Dry; 273K, 101.3kPa, no correction required for O <sub>2</sub> .	10/9/2004	13:35-14:07	BS ISO 9096:2003	MCERTS	Normal
	N/A	29	g/hr							
Total Particulate Matter Run 2	50*	1.4	mg/m <sup>3</sup>	N/A	Dry; 273K, 101.3kPa, no correction required for O <sub>2</sub> .	10/9/2004	12:00-12:30	BS ISO 9096:2003	MCERTS	Normal
	N/A	29	g/hr							
High Concentration VOC (as total organic carbon)	50*	4.20	mg/m <sup>3</sup>	5.2	Dry; 273K, 101.3kPa, no correction required for O <sub>2</sub> .	11/01/2006	10:22-10:52	BS EN 13526:2002	MCERTS	Normal
	N/A	80	g/hr							

**Notes:**

# *The uncertainty associated with the quoted result is at the 95% confidence interval*

\* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*

**Table 2.7 – Monitoring Results from the (Stack 3 New Spray Booth)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	0.6	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3kPa, no correction required for O <sub>2</sub> ..	10/9/2004	13:35-14:07	BS ISO 9096:2003	MCERTS	Normal
	N/A	11	g/hr							
Total Particulate Matter Run 2	50*	0.7	mg/m <sup>3</sup>	N/A	Dry, 273K, 101.3kPa, no correction required for O <sub>2</sub> ..	10/9/2004	12:00-12:30	BS ISO 9096:2003	MCERTS	Normal
	N/A	11	g/hr							
High Concentration VOC (as total organic carbon)	50*	16.91	mg/m <sup>3</sup>		Dry, 273K, 101.3kPa, no correction required for O <sub>2</sub> ..	10/01/2006	11:16-11:46	BS EN 13526:2002	MCERTS	Normal
	N/A	280	g/hr	9.8						

**Notes:**

# *The uncertainty associated with the quoted result is at the 95% confidence interval*

\* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*

**Table 2.9 – Monitoring Results from the (Large degreaser (Trike))**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%) #	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
High Concentration VOC (as total organic carbon)	50*	123.10	mg/m <sup>3</sup>	12.95	Dry, 273K, 101.3kPa, no correction required for O <sub>2</sub> .	9/01/2006	14:10-15:10	BS EN 13526:2002	MCERTS	Normal
	N/A	80	g/hr							

Notes:

\* As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"

**Monitoring Deviations**

**Table 3.1 – Monitoring deviations during monitoring of the Stack 1 Industrial Spray Booth 1, January 2006**

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	Sampling location does not meet requirement as laid down in EA document M1.

**Table 3.2 – Monitoring deviations during monitoring of the Stack 2 Industrial Spray Booth 1, January 2006**

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	Sampling location does not meet requirement as laid down in EA document M1.

Table 3.3 – Monitoring deviations during monitoring of the Stack 1 Industrial Spray Booth 2, January 2006

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	N/A

Table 3.4 – Monitoring deviations during monitoring of the Stack 2 Industrial Spray Booth 2, January 2006

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	N/A

**Table 3.5 – Monitoring deviations during monitoring of the Stack 1, New Spray Booth , January 2006**

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	Sampling location does not meet requirement as laid down in EA document M1.

**Table 3.6 – Monitoring deviations during monitoring of the Stack 2, New Spray Booth , January 2006**

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	Sampling location does not meet requirement as laid down in EA document M1.

**Table 3.7 – Monitoring deviations during monitoring of the Stack 3, New Spray Booth, January 2006**

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	N/A

**Table 3.8 – Monitoring deviations during monitoring of the Red oxide, January 2006**

Substance Deviations	Monitoring Deviations	Other Relevant Issues
N/A	N/A	Sampling location does not meet requirement as laid down in EA document M1.

**Table 3.9 – Monitoring deviations during monitoring of the large degreaser (Trike), January 2006**

<b>Substance Deviations</b>	<b>Monitoring Deviations</b>	<b>Other Relevant Issues</b>
N/A	N/A	N/A

**Report for Periodic Monitoring of Emissions to Atmosphere**

**Part 2: Supporting Information**

**Operator: Covrad Heat Transfer Ltd**

**Installation: Covrad Heat Transfer Ltd, Coventry, Warwickshire.**

**Emission Point: Industrial, New, Redox Booth and Trike bath**

**Monitoring Date(s): 9<sup>th</sup> – 11<sup>th</sup> January 2006**

**Contract Reference: FYS3926**

**Operator: Covrad Heat Transfer**

**Address: Sir Henry Parks Road  
Canley  
Coventry  
CV5 6BN**

**Monitoring Organisation: RPS Health, Safety & Environment**

**Address: Unit 1, Lowfields Business Park, Old Power  
Way, Elland, HX5 9DE**


**Report Date: February 2006**

**Report Approved By: Antony Sumner**

**Position: Quality Manager-Stack Emissions**

**MCERTS Registration Number: MM 03 233**

Signature:



RPS Health, Safety and Environment has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

## **CONTENTS**

### **Part 1: Executive Summary**

**Section 1 – Monitoring Objectives**

**Section 2 – Monitoring Results**

**Section 3 – Monitoring Deviations**

### **Part 2: Supporting Information**

**Appendix 1 – General Information**

**Appendix 2 – Raw Sampling Data, Analysis Data & Uncertainty.**

## APPENDIX 1: General Information

### Monitoring Organisation Method Details

Table 5

Emission Parameter	Standard Method	Monitoring Procedure No.	Analysis	Analysis Procedure No.	Analytical Laboratory	Analysis Accreditation
Practical Considerations Prior to Monitoring	N/A	RPSCE/1/1	N/A	N/A	N/A	N/A
Gas Flows	BS-EN 13284-1:2001	RPSCE/1/2	N/A	N/A	N/A	N/A
Gas Temperatures	BS-EN 13284-1:2001	RPSCE/1/2	N/A	N/A	N/A	N/A
High Concentration TOC (as total organic carbon)	BS EN 13526:2002	RPSCE/1/4c	FID	N/A	N/A	N/A
High Concentration Total Particulate Matter	BS ISO 9096:2003	RPSCE/1/7d	Gravimetric	D9	RPS Laboratories, Manchester	UKAS

Table 6 – Checklist Used

Equipment Checklist Used	File Location Address
FYS3926	FYS3926 Electronic and Work folder

**APPENDIX 2: Appendix 2 – Raw Sampling Data, Analysis Data & Uncertainty.**

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Industrial booth left Ext  
Job / Report Reference: FYS3926

Date: 09/1/06  
Run: 1

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	8.4	2.898	19.5	8	2.828	19.5
2	8	2.828	19.5	7.6	2.757	19.5
3	7.8	2.793	19.5	7.5	2.739	19.5
4	7.4	2.720	19.5	6.6	2.569	19.5
5	6.6	2.569	19.5	6.6	2.569	19.5
6	6.4	2.530	19.5	6.6	2.569	19.5
7	7.6	2.757	19.5	7.9	2.811	19.5
8	7.9	2.811	19.5	8	2.828	19.5
9	8	2.828	19.5	8.4	2.898	19.5
10	8.6	2.933	19.5	8.4	2.898	19.5
Minimum	6.4	2.530	19.5	6.6	2.569	19.5
Maximum	8.6	2.933	19.5	8.4	2.898	19.5
Mean	7.7	2.767	19.5	7.6	2.747	19.5
Sum	76.7	27.667	195	75.6	27.467	195
Total Sum				152.3	55.134	390

Max. pitot press. =	8.6
Min. pitot press. =	6.4
Ratio Max:Min =	1.3 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd In-stack Filter?  No Bar. Press. mm Hg 751.53 K-Factor 3.02 Leak Rate (fm / %) <2

Site Name: Coventry Yes  Cp 0.82 Dn used 8 Leak Rate (start / %) <2

Sampling Point Ref: Industrial booth left E Outstack Filter?  GHSP Bw% 2 Nozzle No. 8 Stop Time 12:32 Box/Probe setting 100 +/- 5 °C

Date: 09/1/06 Operators 2

Run: 1

Job / Report Reference: FV353926

Sample Filter Weights

Filter	Reference	Laboratory	Increase mg
394109	RPS	1.34	
Probe Washings	RPS	2.48	

Sample Filter Blank Weights

Filter	Reference	Laboratory	Increase mg
394109	RPS	0.04	
Probe Wash	RPS	0.5	

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
Total			0.0

Sample Point	Clock Time min	Pict Δ p, m/s-1	Stack Temp, °C	Orifice m/s-1		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Root Δ p.
				Desired	Actual								
A	0	7.6	20	22.952	23	361808	20	N/A	N/A	N/A	-10	N/A	2.757
	4	7.6	20	22.952	23		20	N/A	N/A	N/A	-10	N/A	2.757
	8	7.6	20	22.952	23		20	N/A	N/A	N/A	-10	N/A	2.757
	12	7.6	20	22.952	23		20	N/A	N/A	N/A	-10	N/A	2.757
	16	8.4	20	25.368	25		20	N/A	N/A	N/A	-10	N/A	2.898
	20	8.4	20	25.368	25		20	N/A	N/A	N/A	-10	N/A	2.898
Endpoint	28	8.4	20	25.368	25		20	N/A	N/A	N/A	-11	N/A	2.898
	32	8.4	20	24.2	24.0	362811	20	N/A	N/A	N/A	-10.4	N/A	2.828

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 1

Sampling Point Ref: Industrial booth left Ext	Run: 1
Meter Volume Sampled, acm	1.003
Sample Run Start Time	12:30
Sample Run End Time	12:32
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	0.926
Meter Volume at Wet STP, scm	0.926
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	9.423
Stack Flow Rate, acms	2.664
Stack Flow Rate, scms dry,STP	2.453
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>110.3</b>
Total Mass of Particulate, mg	3.8
Percentage of Total Particulate Collected on Filter	35.1
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>4.1</b>
Particulate Mass rate, kg/hour	0.036
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.58
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Industrial booth left Ext  
Job / Report Reference: FYS3926

Date: 09/1/06  
Run: 2

Stack Static press. mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	$\Delta p_i$ mm H <sub>2</sub> O	Root $\Delta p$	Stack Temp °C	$\Delta p_i$ mm H <sub>2</sub> O	Root $\Delta p$	Stack Temp °C
1	10.1	3.178	20	9.8	3.130	20
2	9.9	3.146	20	8.9	2.983	20
3	9.8	3.130	20	8.8	2.966	20
4	9.6	3.098	20	7.5	2.739	20
5	8.8	2.966	20	5.8	2.408	20
6	8.7	2.950	20	6.5	2.550	20
7	8.5	2.915	20	7.4	2.720	20
8	7.2	2.683	20	8	2.828	20
9	6.8	2.608	20	7	2.646	20
10	5.5	2.345	20	6.4	2.530	20
Minimum	5.5	2.345	20	5.8	2.408	20
Maximum	10.1	3.178	20	9.8	3.130	20
Mean	8.5	2.902	20.0	7.6	2.750	20.0
Sum	84.9	29.021	200	76.1	27.501	200
Total Sum				161	56.522	400

Max. pitot press. =	10.1
Min. pitot press. =	5.5
Ratio Max:Min =	1.8 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd In-stack Filter?  No  Bar. Press mm Hg  K Factor   
 Site Name: Coventry  Yes  No  Dr. used   
 Sampling Point Ref: Industrial booth left E Outstack Filter?  Yes  No  Nozzle No.   
 Detector: 09/105 Operators  CHSP  BWS%   
 Run: 2  
 Job / Report Reference: FYS33926

**Sample Filter Weights**

Reference	Laboratory	Increase, mg
394099	RPS	0.04
Probe Washings	RPS	0.5

**Sample Filter Blank Weights**

Reference	Laboratory	Increase, mg
394109	RPS	0.04
Probe Wash	RPS	0.5

**Impinger Weights**

Weights	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Pilot A.P. m/s-1	Stack Temp. °C	Office m/s-1		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp. °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Read A.P.	
				Desired	Actual									
A	0	8.9	20	26.878	27	350927	20	N/A	160	160	-10	N/A	2.983	
	4	8.9	20	26.878	27		20	N/A	160	160	-10	N/A	2.983	
	8	8.9	20	26.878	27		20	N/A	160	160	-10	N/A	2.983	
	12	8.9	20	26.878	27		20	N/A	160	160	-10	N/A	2.983	
	16	7	20	20	21.14	21		20	N/A	160	160	-10	N/A	2.846
	20	7	20	20	21.14	21		20	N/A	160	160	-10	N/A	2.846
	24	7	20	20	21.14	21		20	N/A	160	160	-11	N/A	2.846
Endpoint	32		20	21.14	21	361599	20	N/A	160	160	-12	N/A	2.846	
	32.00	7.990	20.0	24.0	24.0	1.0	20.0	N/A	160.0	160.0	-10.4	N/A	2.815	

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 2

Sampling Point Ref: Industrial booth left Ext	Run: 2
Meter Volume Sampled, acm	0.972
Sample Run Start Time	13:40
Sample Run End Time	14:12
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	0.897
Meter Volume at Wet STP, scm	0.897
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	9.380
Stack Flow Rate, acms	2.652
Stack Flow Rate, scms dry,STP	2.442
Nozzle Diameter, mm	8.00
% Isokinetic Variation	107.4
Total Mass of Particulate, mg	0.5
Percentage of Total Particulate Collected on Filter	7.4
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.6</b>
Particulate Mass rate, kg/hour	0.005
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.60
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 09/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: Industrial Left EXT

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>82.10</b>	1.23	<b>89.92</b>	1.35
<b>Max</b>	<b>262.39</b>	3.95	<b>287.38</b>	4.32
<b>Min</b>	<b>9.84</b>	0.15	<b>10.78</b>	0.16
<b>Moisture, %</b>				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene,mg/m <sup>3</sup>	O2 FACTOR
12:10	6	9.84	10.78	1.00
12:11	6	9.84	10.78	1.00
12:12	6	9.84	10.78	1.00
12:13	6	9.84	10.78	1.00
12:14	6	9.84	10.78	1.00
12:15	6	9.84	10.78	1.00
12:16	7	11.48	12.57	1.00
12:17	6	9.84	10.78	1.00
12:18	6	9.84	10.78	1.00
12:19	6	9.84	10.78	1.00
12:20	90	147.59	161.65	1.00
12:21	120	196.79	215.54	1.00
12:22	100	163.99	179.61	1.00
12:23	150	245.99	269.42	1.00
12:24	120	196.79	215.54	1.00
12:25	160	262.39	287.38	1.00
12:26	130	213.19	233.50	1.00
12:27	120	196.79	215.54	1.00
12:28	160	262.39	287.38	1.00
12:29	130	213.19	233.50	1.00
12:30	120	196.79	215.54	1.00
12:31	100	163.99	179.61	1.00
12:32	60	98.40	107.77	1.00
12:33	40	65.60	71.85	1.00
12:34	30	49.20	53.88	1.00
12:35	10	16.40	17.96	1.00
12:36	6	9.84	10.78	1.00
12:37	6	9.84	10.78	1.00
12:38	10	16.40	17.96	1.00
12:39	10	16.40	17.96	1.00
12:40	10	16.40	17.96	1.00

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Sampling Point Ref: Industrial booth Left INT  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 1

Stack Static press.mm H <sub>2</sub> O:		0.2		Stack Diameter (m)		0.6
				Stack Area (m <sup>2</sup> ):		0.282744
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	10.1	3.178	20	9.8	3.130	20
2	9.9	3.146	20	8.9	2.983	20
3	9.8	3.130	20	8.8	2.966	20
4	9.6	3.098	20	7.5	2.739	20
5	8.8	2.966	20	5.8	2.408	20
6	8.7	2.950	20	6.5	2.550	20
7	8.5	2.915	20	7.4	2.720	20
8	7.2	2.683	20	8	2.828	20
9	6.8	2.608	20	7	2.646	20
10	5.5	2.345	20	6.4	2.530	20
Minimum	5.5	2.345	20	5.8	2.408	20
Maximum	10.1	3.178	20	9.8	3.130	20
Mean	8.5	2.902	20.0	7.6	2.750	20.0
Sum	84.9	29.021	200	76.1	27.501	200
Total Sum				161	56.522	400

Max. pitot press. =	10.1
Min. pitot press. =	5.5
Ratio Max:Min =	1.8 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer L In-stack Filter?  No Bar. Press. mm Hg  K Factor  Ambient Temp.

Site Name: Coventry Sampling Point Ref: Industrial booth Left 1 Outstack Filter?  Yes  Cp  Dn used  8 Start Time  Leak Rate (lm / %)

Date: 09/1/06 Operators  BWS%  Nozzle No.  Stop Time  Leak Rate (start / %)

Run: 1 Job / Report Reference: FVS3926  GH/SP  BWS%   Box/Probe setting

Sample Filter Weights

Reference	Laboratory	Increase, mg
394098	RPS	0.12
Probe Washings	RPS	0.5

Sample Filter Blank Weights

Reference	Laboratory	Increase, mg
394109	RPS	0.04
Probe Wash	RPS	0.5

Impinger Weights

Impinger 1	Initial	Final	Increase, g
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
Total			0.0

Sample Point	Clock Time min	Pilot A, P. m/s-1	Stack Temp. °C	Office m/s-1		Gas Meter Reading m³	Temp at Gas Meter Outlet °C	Condenser Temp. °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Rod A, P.
				Desired	Actual								
A	0	9.9	20	29.898	29.9	359595	20	N/A	160	160	-10	N/A	3.146
	4	9.9	20	29.898	29.9		20	N/A	160	160	-10	N/A	3.146
	8	9.9	20	29.898	29.9		20	N/A	160	160	-10	N/A	3.146
	12	9.9	20	29.898	29.9		20	N/A	160	160	-10	N/A	3.146
	16	6.8	20	20.535	20.5		20	N/A	160	160	-10	N/A	2.608
	20	6.8	20	20.536	20.5		20	N/A	160	160	-10	N/A	2.608
	24	6.8	20	20.536	20.5		20	N/A	160	160	-11	N/A	2.608
28	6.8	20	20.535	20.5		20	N/A	160	160	-12	N/A	2.608	
Endpoint:	32		20			360623	20	N/A	160	160	-10.4	N/A	2.877
	32:00	8.350	20.0	25.2	25.2	1.0	20.0	N/A	160.0	160.0	-10.4	N/A	2.877

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 09/1/06  
 Run: 1

Sampling Point Ref: Industrial booth Left INT	Run: 1
Meter Volume Sampled, acm	0.968
Sample Run Start Time	13:40
Sample Run End Time	14:12
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	0.894
Meter Volume at Wet STP, scm	0.894
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	9.588
Stack Flow Rate, acms	2.711
Stack Flow Rate, scms dry, STP	2.496
Nozzle Diameter, mm	8.00
% Isokinetic Variation	104.6
Total Mass of Particulate, mg	0.6
Percentage of Total Particulate Collected on Filter	19.4
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.7</b>
Particulate Mass rate, kg/hour	0.006
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.60
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Industrial booth Left INT  
Job / Report Reference: FYS3926

Date: 09/1/06  
Run: 2

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	8.4	2.898	19.5	8	2.828	19.5
2	8	2.828	19.5	7.6	2.757	19.5
3	7.8	2.793	19.5	7.5	2.739	19.5
4	7.4	2.720	19.5	6.6	2.569	19.5
5	6.6	2.569	19.5	6.6	2.569	19.5
6	6.4	2.530	19.5	6.6	2.569	19.5
7	7.6	2.757	19.5	7.9	2.811	19.5
8	7.9	2.811	19.5	8	2.828	19.5
9	8	2.828	19.5	8.4	2.898	19.5
10	8.6	2.933	19.5	8.4	2.898	19.5
Minimum	6.4	2.530	19.5	6.6	2.569	19.5
Maximum	8.6	2.933	19.5	8.4	2.898	19.5
Mean	7.7	2.767	19.5	7.6	2.747	19.5
Sum	76.7	27.667	195	75.6	27.467	195
Total Sum				152.3	55.134	390

Max. pitot press. =	8.6
Min. pitot press. =	6.4
Ratio Max:Min =	1.3 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd In-stack Filter?  No Bar. Press. mm Hg  K Factor  Ambient Temp.  Leak Rate (fm / %)

Site Name: Coventry Sampling Point Ref: Industrial booth left 1 Outstack Filter?  Yes Cp  On used  8 Start Time  Leak Rate (start / %)

Date: 09/7/06 Run: 2 Operators  Bwvs%  Nozzle No.  Stop Time  Box/Probe setting  Job / Report Reference: FYS3926

**Sample Filter Weights**

Reference	Laboratory	Increase, mg
Filter 394105	RPS	1.07
Probe Washings 394599	RPS	2.48

**Sample Filter Blank Weights**

Reference	Laboratory	Increase, mg
Filter 394109	RPS	0.04
Probe Wash 394600	RPS	0.5

**Impinger Weights**

Weights	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Pilot A, P, m/s-1	Stack Temp, °C	Orifice m/s-1		Gas Meter Reading m³	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Road A, P, 2.828
				Desired	Actual								
A	0	8	20	24.16	24.1	361000	20	N/A	N/A	N/A	-10	N/A	2.828
	4	8	20	24.16	24.1		20	N/A	N/A	N/A	-10	N/A	2.828
	8	8	20	24.16	24.1		20	N/A	N/A	N/A	-10	N/A	2.828
	12	8	20	20	24.16		20	N/A	N/A	N/A	-10	N/A	2.828
	16	8	20	20	24.16		20	N/A	N/A	N/A	-10	N/A	2.828
	20	8	20	20	24.16		20	N/A	N/A	N/A	-10	N/A	2.828
	24	8	20	20	24.16		20	N/A	N/A	N/A	-11	N/A	2.828
Endpoint	32	8	20	24.16	24.1	361864	20	N/A	N/A	N/A	-12	N/A	2.828
	32.00	8.000	20.0	24.2	24.1	0.9	20.0	N/A	N/A	N/A	-10.4	N/A	2.828

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 2

Sampling Point Ref: Industrial booth Left INT	Run: 2
Meter Volume Sampled, acm	0.864
Sample Run Start Time	12:30
Sample Run End Time	12:32
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	0.797
Meter Volume at Wet STP, scm	0.797
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	9.426
Stack Flow Rate, acms	2.665
Stack Flow Rate, scms dry,STP	2.454
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>95.0</b>
Total Mass of Particulate, mg	3.6
Percentage of Total Particulate Collected on Filter	30.1
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>4.5</b>
Particulate Mass rate, kg/hour	0.039
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.68
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 09/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: Industrial Left INT

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>51.97</b>	<b>0.80</b>	<b>56.91</b>	<b>0.87</b>
<b>Max</b>	<b>196.79</b>	<b>3.01</b>	<b>215.54</b>	<b>3.30</b>
<b>Min</b>	<b>8.20</b>	<b>0.13</b>	<b>8.98</b>	<b>0.14</b>
<b>Moisture, %</b>				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene, mg/m <sup>3</sup>	O2 FACTOR
14:06	6	9.84	10.78	1.00
14:07	90	147.59	161.65	1.00
14:08	100	163.99	179.61	1.00
14:09	120	196.79	215.54	1.00
14:10	30	49.20	53.88	1.00
14:11	25	41.00	44.90	1.00
14:12	30	49.20	53.88	1.00
14:13	20	32.80	35.92	1.00
14:14	20	32.80	35.92	1.00
14:15	10	16.40	17.96	1.00
14:16	10	16.40	17.96	1.00
14:17	15	24.60	26.94	1.00
14:18	10	16.40	17.96	1.00
14:19	10	16.40	17.96	1.00
14:20	5	8.20	8.98	1.00
14:21	6	9.84	10.78	1.00
14:22	6	9.84	10.78	1.00
14:23	90	147.59	161.65	1.00
14:24	80	131.20	143.69	1.00
14:25	120	196.79	215.54	1.00
14:26	130	213.19	233.50	1.00
14:27	90	147.59	161.65	1.00
14:28	60	98.40	107.77	1.00
14:29	30	49.20	53.88	1.00
14:30	20	32.80	35.92	1.00
14:31	30	49.20	53.88	1.00
14:32	5	8.20	8.98	1.00
14:33	6	9.84	10.78	1.00
14:34	6	9.84	10.78	1.00
14:35	6	9.84	10.78	1.00
14:36	6	9.84	10.78	1.00

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Industrial booth Right EXT  
Job / Report Reference: FYS3926

Date: 10/1/06  
Run: 1

Stack Static press. mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	11.4	3.376	19.5	11.5	3.391	19.5
2	11.2	3.347	19.5	11.31	3.363	19.5
3	10.9	3.302	19.5	11.1	3.332	19.5
4	10.5	3.240	19.5	10.8	3.286	19.5
5	9.6	3.098	19.5	10.2	3.194	19.5
6	9.4	3.066	19.5	9.9	3.146	19.5
7	8.8	2.966	19.5	9.6	3.098	19.5
8	8.2	2.864	19.5	9.2	3.033	19.5
9	7.8	2.793	19.5	8.8	2.966	19.5
10	7.8	2.793	19.5	8.6	2.933	19.5
Minimum	7.8	2.793	19.5	8.6	2.933	19.5
Maximum	11.4	3.376	19.5	11.5	3.391	19.5
Mean	9.6	3.084	19.5	10.1	3.174	19.5
Sum	95.6	30.845	195	101.01	31.743	195
Total Sum				196.61	62.588	390

Max. pitot press. =	11.5
Min. pitot press. =	7.8
Ratio Max:Min =	1.5 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Lt. In-stack Filler?  No  Bar Press. mm Hg   
 Site Name: Coventry  Yes  Cp   
 Sampling Point Ref: Industrial booth Right Outstack Filler?  Yes  No  K Factor   
 Date: 07/105  GH/SP  Bw%   Dn used   
 Run: 1  Operators   Nezzle No.   
 Job / Report Reference: FV53926

**Sample Filler Weights**

Reference	Laboratory	Increase, mg
394101	RPS	0.63
394599	RPS	0.5

**Sample Filler Blank Weights**

Reference	Laboratory	Increase, mg
394108	RPS	0.04
394600	RPS	0.5

**Impinger Weights**

Weights	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Pitd Δ p, m/s-1	Stack Temp, °C	Orifice m/s-1		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Start Temp, °C	Root Δ p,
				Desired	Actual								
A	0	11.2	20	18.928	18.9	362510	20	N/A	N/A	N/A	-10	N/A	3.347
	4	11.2	20	18.928	18.9		20	N/A	N/A	N/A	-10	N/A	3.347
	8	11.2	20	18.928	18.9		20	N/A	N/A	N/A	-10	N/A	3.347
	12	11.2	20	18.928	18.9		20	N/A	N/A	N/A	-10	N/A	3.347
	16	7.8	20	13.182	13.1		20	N/A	N/A	N/A	-10	N/A	2.793
	20	7.8	20	13.182	13.1		20	N/A	N/A	N/A	-10	N/A	2.793
	24	7.8	20	13.182	13.1		20	N/A	N/A	N/A	-11	N/A	2.793
	28	7.8	20	13.182	13.1		20	N/A	N/A	N/A	-12	N/A	2.793
Endpoint	32		20			363038	20	N/A	N/A	N/A	-10.4	N/A	3.070
	32.00	9.500	20.0	16.1	16.0	0.5	20.0	N/A	N/A	N/A	-10.4	N/A	3.070

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 10/1/06  
 Run: 1

Sampling Point Ref: Industrial booth Right EXT	Run: 1
Meter Volume Sampled, acm	0.528
Sample Run Start Time	14:15
Sample Run End Time	14:47
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	0.487
Meter Volume at Wet STP, scm	0.487
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	10.231
Stack Flow Rate, acms	2.893
Stack Flow Rate, scms dry, STP	2.664
Nozzle Diameter, mm	6.00
<b>% Isokinetic Variation</b>	<b>95.0</b>
Total Mass of Particulate, mg	1.1
Percentage of Total Particulate Collected on Filter	55.8
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>2.3</b>
Particulate Mass rate, kg/hour	0.022
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	1.11
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Industrial booth Right EXT  
Job / Report Reference: FYS3926

Date: 10/1/06  
Run: 2

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	11.4	3.376	19.5	11.5	3.391	19.5
2	11.2	3.347	19.5	11.31	3.363	19.5
3	10.9	3.302	19.5	11.1	3.332	19.5
4	10.5	3.240	19.5	10.8	3.286	19.5
5	9.6	3.098	19.5	10.2	3.194	19.5
6	9.4	3.066	19.5	9.9	3.146	19.5
7	8.8	2.966	19.5	9.6	3.098	19.5
8	8.2	2.864	19.5	9.2	3.033	19.5
9	7.8	2.793	19.5	8.8	2.966	19.5
10	7.8	2.793	19.5	8.6	2.933	19.5
Minimum	7.8	2.793	19.5	8.6	2.933	19.5
Maximum	11.4	3.376	19.5	11.5	3.391	19.5
Mean	9.6	3.084	19.5	10.1	3.174	19.5
Sum	95.6	30.845	195	101.01	31.743	195
Total Sum				196.61	62.588	390

Max. pitot press. =	11.5
Min. pitot press. =	7.8
Ratio Max:Min =	1.5 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Lh In-stack Filter?  No  Bar. Press mm Hg   
 Site Name: Coventry  Yes  Cp   
 Sampling Point Ref: Industrial booth Right Outstack Filter?  No  Dn used   
 Date: 10/1/08  GH/SP  Bws%   
 Run: 2  Nozzle No.   
 Job / Report Reference: FYS2926

Ambient Temp.   
 Start Time   
 Stop Time   
 Leak Rate (fin / %)   
 Leak Rate (start / %)   
 Box/Probe setting

**Sample Filter Weights**

Reference	Laboratory	Increase, mg
Filter 394102	RPS	0.09
Probe Washings 394559	RPS	0.5

**Sample Filter Blank Weighings**

Reference	Laboratory	Increase, mg
Filter 394108	RPS	0.04
Probe Wash 394500	RPS	0.5

**Impinger Weights**

Impinger	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Wind A.P. m/s-1	Stack Temp. °C	Office m/s-1		Gas Meter Reading m³	Temp at Gas Meter Outlet °C	Condenser Temp. °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Rood A.P.
				Desired	Actual								
A	0	11.2	20	18.928	18.9	363036	20	N/A	N/A	N/A	-10	N/A	3.347
	4	11.2	20	18.928	18.9		20	N/A	N/A	N/A	-10	N/A	3.347
	8	11.2	20	18.928	18.9		20	N/A	N/A	N/A	-10	N/A	3.347
	12	11.2	20	18.928	18.9		20	N/A	N/A	N/A	-10	N/A	3.347
	16	7.8	20	20	13.182	13.1		20	N/A	N/A	-10	N/A	2.793
	20	7.8	20	13.182	13.1		20	N/A	N/A	N/A	-10	N/A	2.793
	24	7.8	20	13.182	13.1		20	N/A	N/A	N/A	-11	N/A	2.793
	28	7.8	20	13.182	13.1		20	N/A	N/A	N/A	-12	N/A	2.793
Endpoint:	32		20		16.1	363072	20	N/A	N/A	N/A	-18.4	N/A	3.070
	32.00	8.500	20.0	16.1	16.0	0.5	20.6	N/A	N/A	N/A			

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date:10/1/06  
 Run: 2

Sampling Point Ref: Industrial booth Right EXT	Run: 2
Meter Volume Sampled, acm	0.536
Sample Run Start Time	14:15
Sample Run End Time	14:47
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	0.494
Meter Volume at Wet STP, scm	0.494
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	10.231
Stack Flow Rate, acms	2.893
Stack Flow Rate, scms dry,STP	2.664
Nozzle Diameter, mm	6.00
<b>% Isokinetic Variation</b>	<b>96.5</b>
Total Mass of Particulate, mg	0.6
Percentage of Total Particulate Collected on Filter	15.3
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>1.2</b>
Particulate Mass rate, kg/hour	0.011
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	1.09
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 10/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: Industrial right EXT

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>184.39</b>	<b>3.01</b>	<b>201.95</b>	<b>3.30</b>
<b>Max</b>	<b>409.99</b>	<b>6.69</b>	<b>449.03</b>	<b>7.33</b>
<b>Min</b>	<b>9.84</b>	<b>0.16</b>	<b>10.78</b>	<b>0.18</b>
<b>Moisture, %</b>				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene,mg/m <sup>3</sup>	O2 FACTOR
14:38	6	9.84	10.78	1.00
14:39	6	9.84	10.78	1.00
14:40	7	11.48	12.57	1.00
14:41	60	98.40	107.77	1.00
14:42	100	163.99	179.61	1.00
14:43	150	245.99	269.42	1.00
14:44	250	409.99	449.03	1.00
14:45	250	409.99	449.03	1.00
14:46	250	409.99	449.03	1.00
14:47	200	327.99	359.23	1.00
14:48	100	163.99	179.61	1.00
14:49	100	163.99	179.61	1.00
14:50	80	131.20	143.69	1.00
14:51	100	163.99	179.61	1.00
14:52	60	98.40	107.77	1.00
14:53	80	131.20	143.69	1.00
14:54	20	32.80	35.92	1.00
14:55	10	16.40	17.96	1.00
14:56	10	16.40	17.96	1.00
14:57	10	16.40	17.96	1.00
14:58	10	16.40	17.96	1.00
14:59	10	16.40	17.96	1.00
15:00	10	16.40	17.96	1.00
15:01	8	13.12	14.37	1.00
15:02	8	13.12	14.37	1.00
15:03	8	13.12	14.37	1.00
15:04	8	13.12	14.37	1.00
15:05	8	13.12	14.37	1.00
15:06	8	13.12	14.37	1.00
15:07	8	13.12	14.37	1.00
15:08	8	13.12	14.37	1.00

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Sampling Point Ref: Industrial booth right INT  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 1

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	$\Delta p$ , mm H <sub>2</sub> O	Root $\Delta p$	Stack Temp °C	$\Delta p$ , mm H <sub>2</sub> O	Root $\Delta p$	Stack Temp °C
1	9.1	3.017	20	7.1	2.665	20
2	8.8	2.966	20	9.8	3.130	20
3	7.2	2.683	20	9.1	3.017	20
4	5	2.236	20	8.5	2.915	20
5	3.7	1.924	20	8.2	2.864	20
6	4.6	2.145	20	7.1	2.665	20
7	3.4	1.844	20	6.5	2.550	20
8	5.2	2.280	20	6.6	2.569	20
9	5.3	2.302	20	7.8	2.793	20
10	8.6	2.933	20	8.4	2.898	20
Minimum	3.4	1.844	20	6.5	2.550	20
Maximum	9.1	3.017	20	9.8	3.130	20
Mean	6.1	2.433	20.0	7.9	2.807	20.0
Sum	60.9	24.330	200	79.1	28.065	200
Total Sum				140	52.395	400

Max. pitot press. =	9.8
Min. pitot press. =	3.4
Ratio Max:Min =	2.9 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Lh In-stack Filter?  No  Bar. Press. mm Hg  K Factor   
 Site Name: Coventry  Yes  No  Cp  Dn used   
 Sampling Point Ref: Industrial booth right Outstack Filter?  Yes  No  GHS/P Bws%  Nozzle No.   
 Date: 09/1/06  
 Run: 1  
 Job / Report Reference: FV53926

**Sample Filter Weights**

Reference	Laboratory	Increase, mg
394103	RPS	0.15
394599	RPS	0.5

**Sample Filter Blank Weights**

Reference	Laboratory	Increase, mg
394108	RPS	0.04
394600	RPS	0.5

**Weights**

Impinger	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Pilot Δ p. m/s-1	Stack Temp. °C	Orifice m/s-1		Gas Meter Reading m³	Temp at Gas Meter Outlet °C	Condenser Temp. °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Roof Δ p.
				Desired	Actual								
A	0	26.5	20	80.03	80	358822	20	N/A	N/A	N/A	-10	N/A	5.148
	4	26.5	20	80.03	80		20	N/A	N/A	N/A	-10	N/A	5.148
	8	26.5	20	80.03	80		20	N/A	N/A	N/A	-10	N/A	5.148
	12	26.5	20	90.03	80		20	N/A	N/A	N/A	-10	N/A	5.148
	16	26.5	20	90.03	80		20	N/A	N/A	N/A	-10	N/A	4.000
	20	26.5	20	90.03	80		20	N/A	N/A	N/A	-10	N/A	4.000
Endpoint	24	16	20	48.32	48	358255	20	N/A	N/A	N/A	-11	N/A	4.000
	28	16	20	48.32	48	358255	20	N/A	N/A	N/A	-12	N/A	4.000
	32	21.250	20.0	64.2	64.0	1.4	20.0	N/A	N/A	N/A	-10.4	N/A	4.574

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 1

Sampling Point Ref: Industrial booth right INT	Run: 1
Meter Volume Sampled, acm	1.433
Sample Run Start Time	13:35
Sample Run End Time	14:07
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	1.328
Meter Volume at Wet STP, scm	1.328
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	15.243
Stack Flow Rate, acms	4.310
Stack Flow Rate, scms dry,STP	3.969
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>97.8</b>
Total Mass of Particulate, mg	0.7
Percentage of Total Particulate Collected on Filter	23.1
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.5</b>
Particulate Mass rate, kg/hour	0.007
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.41
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Industrial booth right INT  
Job / Report Reference: FYS3926

Date: 09/1/06  
Run: 2

Stack Static press. mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	$\Delta p$ , mm H <sub>2</sub> O	Root $\Delta p$	Stack Temp °C	$\Delta p$ , mm H <sub>2</sub> O	Root $\Delta p$	Stack Temp °C
1	9.1	3.017	20	7.1	2.665	20
2	8.8	2.966	20	9.8	3.130	20
3	7.2	2.683	20	9.1	3.017	20
4	5	2.236	20	8.5	2.915	20
5	3.7	1.924	20	8.2	2.864	20
6	4.6	2.145	20	7.1	2.665	20
7	3.4	1.844	20	6.5	2.550	20
8	5.2	2.280	20	6.6	2.569	20
9	5.3	2.302	20	7.8	2.793	20
10	8.6	2.933	20	8.4	2.898	20
Minimum	3.4	1.844	20	6.5	2.550	20
Maximum	9.1	3.017	20	9.8	3.130	20
Mean	6.1	2.433	20.0	7.9	2.807	20.0
Sum	60.9	24.330	200	79.1	28.065	200
Total Sum				140	52.395	400

Max. pitot press. =	9.8
Min. pitot press. =	3.4
Ratio Max:Min =	2.9 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd In-stack Filter?  No Bar: Press.mm Hg  Leak Rate (in / %)

Site Name: Coventry Sampling Point Ref: Industrial booth right Outstack Filter?  Yes  Op  Start Time  Leak Rate (start / %)

Date: 08/1/06 Run: 2 Operators  Bw%  Nozzle No.  Stop Time  Box/Probe setting

Job / Report Reference: FV53928

**Sample Filter Weights**

Reference	Laboratory	Increase, mg
Filter 394104	RPS	0.6
Probe Washings 394599	RPS	0.5

**Sample Filter Blank Weights**

Reference	Laboratory	Increase, mg
Filter 394108	RPS	0.04
Probe Wash 394600	RPS	0.5

**Impinger Weights**

Impinger	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Pilot Δ P, m/s-1	Stack Temp, °C	Orifice m/s-1		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Foot Δ P.	
				Desired	Actual									
A	0	26.5	20	80.03	80	359255	20	N/A	N/A	N/A	-10	N/A	5.148	
	4	26.5	20	80.03	80		20	N/A	N/A	N/A	-10	N/A	5.148	
	8	26.5	20	80.03	80		20	N/A	N/A	N/A	-10	N/A	5.148	
	12	26.5	20	80.03	80		20	N/A	N/A	N/A	-10	N/A	5.148	
	16	16	16	20	48.32		48	20	N/A	N/A	N/A	-10	N/A	4.000
	20	16	16	20	48.32		48	20	N/A	N/A	N/A	-11	N/A	4.000
Endpoint	28	16	20	48.32	48	359255	20	N/A	N/A	N/A	-12	N/A	4.000	
	32	21.250	20.0	64.2	64.0		1.4	20.0	N/A	N/A	N/A	-10.4	N/A	4.574

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 09/1/06  
 Run: 2

Sampling Point Ref: Industrial booth right INT	Run: 2
Meter Volume Sampled, acm	1.400
Sample Run Start Time	13:35
Sample Run End Time	14:07
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	1.297
Meter Volume at Wet STP, scm	1.297
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	15.243
Stack Flow Rate, acms	4.310
Stack Flow Rate, scms dry, STP	3.969
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>95.6</b>
Total Mass of Particulate, mg	1.1
Percentage of Total Particulate Collected on Filter	54.5
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.8</b>
Particulate Mass rate, kg/hour	0.012
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.42
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 10/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: Industrial right INT

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>10.86</b>	<b>0.26</b>	<b>11.90</b>	<b>0.29</b>
<b>Max</b>	<b>16.40</b>	<b>0.40</b>	<b>17.96</b>	<b>0.44</b>
<b>Min</b>	<b>8.20</b>	<b>0.20</b>	<b>8.98</b>	<b>0.22</b>
<b>Moisture, %</b>				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene,mg/m <sup>3</sup>	O2 FACTOR
12:43	5	8.20	8.98	1.00
12:44	5	8.20	8.98	1.00
12:45	6	9.84	10.78	1.00
12:46	6	9.84	10.78	1.00
12:47	7	11.48	12.57	1.00
12:48	7	11.48	12.57	1.00
12:49	8	13.12	14.37	1.00
12:50	7	11.48	12.57	1.00
12:51	7	11.48	12.57	1.00
12:52	6	9.84	10.78	1.00
12:53	6	9.84	10.78	1.00
12:54	6	9.84	10.78	1.00
12:55	5	8.20	8.98	1.00
12:56	9	14.76	16.17	1.00
12:57	10	16.40	17.96	1.00
12:58	6	9.84	10.78	1.00
12:59	5	8.20	8.98	1.00
13:00	5	8.20	8.98	1.00
13:01	5	8.20	8.98	1.00
13:02	6	9.84	10.78	1.00
13:03	6	9.84	10.78	1.00
13:04	6	9.84	10.78	1.00
13:05	6	9.84	10.78	1.00
13:06	7	11.48	12.57	1.00
13:07	7	11.48	12.57	1.00
13:08	6	9.84	10.78	1.00
13:09	6	9.84	10.78	1.00
13:10	6	9.84	10.78	1.00
13:11	6	9.84	10.78	1.00
13:12	6	9.84	10.78	1.00
13:13	6	9.84	10.78	1.00

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Industrial booth Left INT  
Job / Report Reference: FYS3926

Date:09/1/06  
Run: 1

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.6			
		Stack Area (m <sup>2</sup> ):	0.282744			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	10.1	3.178	20	9.8	3.130	20
2	9.9	3.146	20	8.9	2.983	20
3	9.8	3.130	20	8.8	2.966	20
4	9.6	3.098	20	7.5	2.739	20
5	8.8	2.966	20	5.8	2.408	20
6	8.7	2.950	20	6.5	2.550	20
7	8.5	2.915	20	7.4	2.720	20
8	7.2	2.683	20	8	2.828	20
9	6.8	2.608	20	7	2.646	20
10	5.5	2.345	20	6.4	2.530	20
Minimum	5.5	2.345	20	5.8	2.408	20
Maximum	10.1	3.178	20	9.8	3.130	20
Mean	8.5	2.902	20.0	7.6	2.750	20.0
Sum	84.9	29.021	200	76.1	27.501	200
Total Sum				161	56.522	400

Max. pitot press. =	10.1
Min. pitot press. =	5.5
Ratio Max:Min =	1.8 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Lt In-stack Filter?  No  Bar. Press. mm Hg   
 Site Name: Coventry  Yes  Cp   
 Sampling Point Ref: Industrial booth Left 1 Outstack Filter?  Yes  No   
 Date: 09/1/06 Operators  GHSP  Bw%   
 Run: 1  GHSP  Bw%   
 Job / Report Reference: FVS3926 Nozzle No.

Sample Filter Weights

Filter	Reference	Laboratory	Increase, mg
394099	RPS	RPS	0.12
Probe Washings	394098	RPS	0.5

Sample Filter Blank Weights

Filter	Reference	Laboratory	Increase, mg
Probe Wash	394109	RPS	0.04
	394600	RPS	0.5

Weights

Impinger 1	Initial	Final	Increase, g
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Impinger Weights

Initial	Final	Increase, g
		0.0
		0.0
		0.0
		0.0
		0.0
<b>Total</b>		<b>0.0</b>

Ambient Temp.   
 Start Time   
 Stop Time   
 Leak Rate (l/m / %)   
 Leak Rate (start / %)   
 Box/Probe setting

Sample Point	Clock Time min	Pilot A.P. m/s-1	Stack Temp. °C	Office m/s-1		Gas Meter Reading m³	Temp at Gas Meter Outlet °C	Condenser Temp. °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Root A.P.
				Desired	Actual								
A	0	9.8	20	29.898	29.9	359855	20	N/A	160	160	-10	N/A	3.146
	4	9.9	20	29.898	29.9		20	N/A	160	160	-10	N/A	3.146
	8	9.9	20	29.898	29.9		20	N/A	160	160	-10	N/A	3.146
	12	9.9	20	29.898	29.9		20	N/A	160	160	-10	N/A	3.146
	16	6.8	20	20.536	20.5		20	N/A	160	160	-10	N/A	2.608
	20	6.8	20	20.536	20.5		20	N/A	160	160	-10	N/A	2.608
	24	6.8	20	20.536	20.5		20	N/A	160	160	-11	N/A	2.608
Endpoint	32	8.8	20	20.536	20.5	360823	20	N/A	160	160	-12	N/A	2.608
	32.00	8.350	20.0	25.2	25.2	1.0	20.0	N/A	160.0	160.0	-10.4	N/A	2.877

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 09/1/06  
 Run: 1

Sampling Point Ref: Industrial booth Left INT	Run: 1
Meter Volume Sampled, acm	0.968
Sample Run Start Time	13:40
Sample Run End Time	14:12
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	20.0
Meter Volume at STP, scm	0.894
Meter Volume at Wet STP, scm	0.894
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	9.588
Stack Flow Rate, acms	2.711
Stack Flow Rate, scms dry, STP	2.496
Nozzle Diameter, mm	8.00
% Isokinetic Variation	104.6
Total Mass of Particulate, mg	0.6
Percentage of Total Particulate Collected on Filter	19.4
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.7</b>
Particulate Mass rate, kg/hour	0.006
Emission Limit value	50.000

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.60
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: New booth 1  
Job / Report Reference: FYS3926

Date:10/1/06  
Run: 2

Stack Static press.mm H<sub>2</sub>O: 0.2  
Stack Diameter (m): 0.79  
Stack Area (m<sup>2</sup>): 0.49016814

Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	9.1	3.017	20	7.1	2.665	20
2	8.8	2.966	20	9.8	3.130	20
3	7.2	2.683	20	9.1	3.017	20
4	5	2.236	20	8.5	2.915	20
5	3.7	1.924	20	8.2	2.864	20
6	4.6	2.145	20	7.1	2.665	20
7	3.4	1.844	20	6.5	2.550	20
8	5.2	2.280	20	6.6	2.569	20
9	5.3	2.302	20	7.8	2.793	20
10	8.6	2.933	20	8.4	2.898	20
Minimum	3.4	1.844	20	6.5	2.550	20
Maximum	9.1	3.017	20	9.8	3.130	20
Mean	6.1	2.433	20.0	7.9	2.807	20.0
Sum	60.9	24.330	200	79.1	28.065	200
Total Sum				140	52.395	400

Max. pitot press. =	9.8
Min. pitot press. =	3.4
Ratio Max:Min =	2.9 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Lt In-stack Filter?  No  Yes  
 Site Name: Coventry  Bar. Press/mm Hg: 751.53  
 Sampling Point Ref: New booth 1  Yes  No  Cp  
 Date: 10/1/06  Operators  GHSP  BWS%  
 Run: 2  Nozzle No.: 8  
 Job / Report Reference: FV53926

**Sample Filter Weights**

Filter Reference	394987	Laboratory	RPS	Increase, mg	0.1
Probe Washings	394599	Laboratory	RPS	Increase, mg	3.23

**Sample Filter Blank Weights**

Filter Reference	394587	Laboratory	RPS	Increase, mg	0.1
Probe Wash	394600	Laboratory	RPS	Increase, mg	0.5

**Impinger Weights**

Weights	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Pilot Δ P, m/s-1	Stack Temp, °C	Orifice m/s-1		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Read Δ P, m/s-1
				Desired	Actual								
1	0	7	19	58.17	58	420994	19	N/A	160	160	-11	N/A	2.646
2	4	7	19	58.17	58		19	N/A	160	160	-11	N/A	2.646
3	8	7.8	19	64.818	65		21	N/A	160	160	-9	N/A	2.793
4	12	7.8	19	64.818	65		21	N/A	160	160	-9	N/A	2.793
3	18	7.8	19	64.818	65		21	N/A	160	160	-9	N/A	2.793
4	20	7.8	19	64.818	65		22	N/A	160	160	-9	N/A	3.000
4	24	9	19	74.79	75		22	N/A	160	160	-10	N/A	3.000
4	28	9	19	74.79	75		22	N/A	160	160	-10	N/A	3.000
Endpoint	32		18			421648	22	N/A	160	160	-9.6	N/A	0.000
	32.00	7.900	18.9	65.6	65.8	0.8	20.9	N/A	160.0	160.0	-9.6	N/A	2.498

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 10/1/06  
 Run: 2

Sampling Point Ref: New booth 1	Run: 2
Meter Volume Sampled, acm	0.765
Sample Run Start Time	14:02
Sample Run End Time	14:34
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	18.9
Meter Volume at STP, scm	0.707
Meter Volume at Wet STP, scm	0.707
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	8.302
Stack Flow Rate, acms	4.069
Stack Flow Rate, scms dry, STP	3.762
Nozzle Diameter, mm	8.00
% Isokinetic Variation	95.2
Total Mass of Particulate, mg	3.3
Percentage of Total Particulate Collected on Filter	3.0
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>4.7</b>
Particulate Mass rate, kg/hour	0.064
Emission Limit value	50.000

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.85
Total Weight Gain, mg (Sample Train Blank)	0.6
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 10/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: New Booth 1

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>12.30</b>	<b>0.17</b>	<b>13.47</b>	<b>0.19</b>
<b>Max</b>	<b>22.96</b>	<b>0.32</b>	<b>25.15</b>	<b>0.35</b>
<b>Min</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>
<b>Moisture, %</b>				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene,mg/m <sup>3</sup>	O2 FACTOR
11:55	12	19.68	21.55	1.00
11:56	14	22.96	25.15	1.00
11:57	10	16.40	17.96	1.00
11:58	8	13.12	14.37	1.00
11:59	6	9.84	10.78	1.00
12:00	6	9.84	10.78	1.00
12:01	8	13.12	14.37	1.00
12:02	10	16.40	17.96	1.00
12:03	6	9.84	10.78	1.00
12:04	6	9.84	10.78	1.00
12:05	6	9.84	10.78	1.00
12:06	4	6.56	7.18	1.00
12:07	4	6.56	7.18	1.00
12:08	0	0.00	0.00	1.00
12:09	8	13.12	14.37	1.00
12:10	12	19.68	21.55	1.00
12:11	22	36.08	39.51	1.00
12:12	26	42.64	46.70	1.00
12:13	20	32.80	35.92	1.00
12:14	14	22.96	25.15	1.00
12:15	8	13.12	14.37	1.00
12:16	4	6.56	7.18	1.00
12:17	12	19.68	21.55	1.00
12:18	10	16.40	17.96	1.00
12:19	8	13.12	14.37	1.00
12:20	4	6.56	7.18	1.00
12:21	4	6.56	7.18	1.00
12:22	4	6.56	7.18	1.00
12:23	4	6.56	7.18	1.00
12:24	8	13.12	14.37	1.00
12:25	2	3.28	3.59	1.00

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Sampling Point Ref: New booth 2  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 1

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.79			
		Stack Area (m <sup>2</sup> ):	0.49016814			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	9.1	3.017	20	7.1	2.665	20
2	8.8	2.966	20	9.8	3.130	20
3	7.2	2.683	20	9.1	3.017	20
4	5	2.236	20	8.5	2.915	20
5	3.7	1.924	20	8.2	2.864	20
6	4.6	2.145	20	7.1	2.665	20
7	3.4	1.844	20	6.5	2.550	20
8	5.2	2.280	20	6.6	2.569	20
9	5.3	2.302	20	7.8	2.793	20
10	8.6	2.933	20	8.4	2.898	20
Minimum	3.4	1.844	20	6.5	2.550	20
Maximum	9.1	3.017	20	9.8	3.130	20
Mean	6.1	2.433	20.0	7.9	2.807	20.0
Sum	60.9	24.330	200	79.1	28.065	200
Total Sum				140	52.395	400

Max. pitot press. =	9.8
Min. pitot press. =	3.4
Ratio Max:Min =	2.9 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Lt In-stack Filter?  No  Bar. Press. mm Hg  K Factor   
 Site Name: Coventry Outstack Filter?  Yes  No  Cp  Dn used  7  7  
 Sampling Point Ref: New booth 2 Date: 09/1/05 Operators  Bws%  Nezzle No.   
 Run: 1 Job / Report Reference: FYS3926

**Sample Filter Weights**

Reference	Laboratory	Increase, mg
Filter 394099	RPS	0.1
Probe Washings 394599	RPS	1.13

**Sample Filter Blank Weights**

Reference	Laboratory	Increase, mg
Filter 394108	RPS	0.04
Probe Wash 394600	RPS	0.5

**Impinger Weights**

Initial	Final	Increase, g
Impinger 1		0.0
Impinger 2		0.0
Impinger 3		0.0
Impinger 4		0.0
Impinger 5		0.0
Silica Gel		0.0
<b>Total</b>		<b>0.0</b>

Sample Point	Clock Time min	Pilot A.P. m/s-1	Stack Temp. °C	Office m/s-1		Gas Meter Reading m³	Temp at Gas Meter Outlet °C	Condenser Temp. °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Root A.P.
				Desired	Actual								
1	0	20	18	107.6	107	418731	19	N/A	160	160	-1.1	N/A	4.472
	4	17	18	91.46	92		19	N/A	160	160	-1.1	N/A	4.123
2	8	17	18	91.46	92		19	N/A	160	160	-9	N/A	4.123
	12	13.8	17	74.244	74		19	N/A	160	160	-9	N/A	3.715
3	16	13.8	17	74.244	74		19	N/A	160	160	-9	N/A	3.715
	20	13.2	17	71.018	71		19	N/A	160	160	-9	N/A	3.633
4	24	13.2	17	71.018	71		19	N/A	160	160	-9	N/A	3.633
	28	8.3	17	44.654	45		19	N/A	160	160	-10	N/A	2.881
Endpoint	32	8.3	17	78.2	78.3	417830	20	N/A	160	160	-9.6	N/A	2.881
	32.00	13.84	17.3	78.2	78.3	0.9	19.1	N/A	160.0	160.0	-9.6	N/A	3.666

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date:09/1/06  
 Run: 1

Sampling Point Ref: New booth 2	Run: 1
Meter Volume Sampled, acm	0.899
Sample Run Start Time	9:38
Sample Run End Time	2:38
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	17.3
Meter Volume at STP, scm	0.837
Meter Volume at Wet STP, scm	0.837
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	12.229
Stack Flow Rate, acms	5.994
Stack Flow Rate, scms dry,STP	5.570
Nozzle Diameter, mm	7.00
<b>% Isokinetic Variation</b>	<b>99.4</b>
Total Mass of Particulate, mg	1.2
Percentage of Total Particulate Collected on Filter	8.1
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>1.5</b>
Particulate Mass rate, kg/hour	0.029
Emission Limit value	<b>50.000</b>

<b>Sample Train Blank Results</b>	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.65
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: New booth 2  
Job / Report Reference: FYS3926

Date: 09/1/06  
Run: 2

Stack Static press. mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.79			
		Stack Area (m <sup>2</sup> ):	0.49016814			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	9.1	3.017	20	7.1	2.665	20
2	8.8	2.966	20	9.8	3.130	20
3	7.2	2.683	20	9.1	3.017	20
4	5	2.236	20	8.5	2.915	20
5	3.7	1.924	20	8.2	2.864	20
6	4.6	2.145	20	7.1	2.665	20
7	3.4	1.844	20	6.5	2.550	20
8	5.2	2.280	20	6.6	2.569	20
9	5.3	2.302	20	7.8	2.793	20
10	8.6	2.933	20	8.4	2.898	20
Minimum	3.4	1.844	20	6.5	2.550	20
Maximum	9.1	3.017	20	9.8	3.130	20
Mean	6.1	2.433	20.0	7.9	2.807	20.0
Sum	60.9	24.330	200	79.1	28.065	200
Total Sum				140	52.395	400

Max. pitot press. =	9.8
Min. pitot press. =	3.4
Ratio Max:Min =	2.9 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1: Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd In-stack Filter?  No Bar. Press mm Hg  K Factor  Leak Rate (in / %)

Site Name: Coventry Outstack Filter?  Yes Cp  Dn used  7 Leak Rate (start / %)

Sampling Point Ref: New booth 2 Operators GH/SP  Bw%  Nozzle No.  Stop Time  Box/Probe setting

Run: 2 Job / Report Reference: FV33926

Sample Filter Weights

Filter Reference	394080	Laboratory	RPS	Increase, mg	0.1
Probe Washings	394589	RPS			1.13

Sample Filter Bank Weights

Filter Reference	394108	Laboratory	RPS	Increase, mg	0.04
Probe Wash	394600	RPS			0.5

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
Total			0.0

Sample Point	Clock Time min	Pilot Δ p, m/s <sup>-1</sup>	Stack Temp, °C	Orifice m/s <sup>-1</sup>		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Root Δ p,
				Desired	Actual								
1	0	9.8	18	52.724	52	417830	19	N/A	180	180	-11	N/A	3.130
	4	9.8	18	52.724	52		19	N/A	180	180	-11	N/A	3.130
2	8	19.2	18	103.296	103		19	N/A	180	180	-9	N/A	4.382
	12	19.2	17	103.296	103		19	N/A	180	180	-9	N/A	4.382
3	16	16.3	17	87.684	88		19	N/A	180	180	-9	N/A	4.037
	20	16.2	17	87.156	88		19	N/A	180	180	-9	N/A	4.025
4	24	20	17	107.8	108		19	N/A	180	180	-9	N/A	4.472
	28	20	17	107.8	108		19	N/A	180	180	-10	N/A	4.472
Endpoint	32	8.3	17			418600	20	N/A	180	180	-9.8	N/A	2.881
	32.00	15.422	17.3			1.8	19.1	N/A	180.0	180.0	-9.8	N/A	3.879

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 09/1/06  
 Run: 2

Sampling Point Ref: New booth 2	Run: 2
Meter Volume Sampled, acm	0.970
Sample Run Start Time	10:40
Sample Run End Time	11:12
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	17.3
Meter Volume at STP, scm	0.904
Meter Volume at Wet STP, scm	0.904
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	12.869
Stack Flow Rate, acms	6.308
Stack Flow Rate, scms dry, STP	5.862
Nozzle Diameter, mm	7.00
<b>% Isokinetic Variation</b>	<b>102.0</b>
Total Mass of Particulate, mg	1.2
Percentage of Total Particulate Collected on Filter	8.1
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>1.4</b>
Particulate Mass rate, kg/hour	0.029
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.60
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 10/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: New Booth 2

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>4.20</b>	<b>0.08</b>	<b>4.60</b>	<b>0.09</b>
<b>Max</b>	<b>14.76</b>	<b>0.29</b>	<b>16.17</b>	<b>0.31</b>
<b>Min</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>
<b>Moisture, %</b>				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene,mg/m <sup>3</sup>	O2 FACTOR
10:22	0	0.00	0.00	1.00
10:23	0	0.00	0.00	1.00
10:24	4	6.56	7.18	1.00
10:25	9	14.76	16.17	1.00
10:26	7	11.48	12.57	1.00
10:27	7	11.48	12.57	1.00
10:28	8	13.12	14.37	1.00
10:29	2	3.28	3.59	1.00
10:30	0	0.00	0.00	1.00
10:31	0	0.00	0.00	1.00
10:32	0	0.00	0.00	1.00
10:33	0	0.00	0.00	1.00
10:34	1	1.64	1.80	1.00
10:35	0	0.00	0.00	1.00
10:36	0	0.00	0.00	1.00
10:37	3	4.92	5.39	1.00
10:38	5	8.20	8.98	1.00
10:39	6	9.84	10.78	1.00
10:40	5	8.20	8.98	1.00
10:41	2	3.28	3.59	1.00
10:42	0	0.00	0.00	1.00
10:43	0	0.00	0.00	1.00
10:44	0	0.00	0.00	1.00
10:45	0	0.00	0.00	1.00
10:46	4	6.56	7.18	1.00
10:47	8	13.12	14.37	1.00
10:48	10	16.40	17.96	1.00
10:49	8	13.12	14.37	1.00
10:50	3	4.92	5.39	1.00
10:51	0	0.00	0.00	1.00
10:52	0	0.00	0.00	1.00

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Sampling Point Ref: New booth 3  
 Job / Report Reference: FYS3926

Date: 10/1/06  
 Run: 1

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.79			
		Stack Area (m <sup>2</sup> ):	0.49016814			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	9.1	3.017	20	7.1	2.665	20
2	8.8	2.966	20	9.8	3.130	20
3	7.2	2.683	20	9.1	3.017	20
4	5	2.236	20	8.5	2.915	20
5	3.7	1.924	20	8.2	2.864	20
6	4.6	2.145	20	7.1	2.665	20
7	3.4	1.844	20	6.5	2.550	20
8	5.2	2.280	20	6.6	2.569	20
9	5.3	2.302	20	7.8	2.793	20
10	8.6	2.933	20	8.4	2.898	20
Minimum	3.4	1.844	20	6.5	2.550	20
Maximum	9.1	3.017	20	9.8	3.130	20
Mean	6.1	2.433	20.0	7.9	2.807	20.0
Sum	60.9	24.330	200	79.1	28.065	200
Total Sum				140	52.395	400

Max. pitot press. =	9.8
Min. pitot press. =	3.4
Ratio Max:Min =	2.9 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd In-stack Filter?  No Bar. Press. mm Hg  K Factor  Leak Rate (fm / %)

Site Name: Coventry Outstack Filter?  Yes Cp  Dh used  Leak Rate (start / %)

Sampling Point Ref: New booth 3 Date: 10/10/06 Operators: GH/SP Bws%  Nozzle No.  Bow/Probe setting

Run: 1 Job / Report Reference: FVSS926

Sample Filter Weights

Reference	Laboratory	Increase, mg
394991	RPS	0.1
Probe Washings	RPS	0.5

Sample Filter Blank Weighings

Reference	Laboratory	Increase, mg
394597	RPS	0.1
Probe Wash	RPS	0.5

Weights

Impinger 1	Initial	Final	Increase, g
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
Total			0.0

Sample Point	Clock Time min	Wind Δ P, m/s-1	Stack Temp, °C	Office m/s-1		Gas Meter Reading m³	Temp at Gas Meter/Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Root Δ P,
				Desired	Actual								
1	0	14	17	116.34	117	418930	19	N/A	160	160	-11	N/A	3.742
2	4	14	17	116.34	117		19	N/A	160	160	-11	N/A	3.742
3	8	9.8	17	81.438	82		19	N/A	160	160	-9	N/A	3.130
4	12	9.8	17	81.438	82		19	N/A	160	160	-9	N/A	3.130
3	16	12.8	17	106.368	106		19	N/A	160	160	-9	N/A	3.578
4	20	12.8	17	106.368	106		19	N/A	160	160	-9	N/A	3.578
Endpoint	28	14.2	17	118.002	118		19	N/A	160	160	-10	N/A	3.768
Endpoint	32	12.700	17.0	105.5	105.8	418960	20	N/A	160	160.0	-9.6	N/A	0.000
Endpoint	32.00	12.700	17.0	105.5	105.8	1.0	19.1	N/A	160.0	160.0	-9.6	N/A	3.169

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 10/1/06  
 Run: 1

Sampling Point Ref: New booth 3	Run: 1
Meter Volume Sampled, acm	1.030
Sample Run Start Time	11:20
Sample Run End Time	11:52
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	17.0
Meter Volume at STP, scm	0.961
Meter Volume at Wet STP, scm	0.961
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	10.476
Stack Flow Rate, acms	5.135
Stack Flow Rate, scms dry, STP	4.777
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>102.0</b>
Total Mass of Particulate, mg	0.6
Percentage of Total Particulate Collected on Filter	16.7
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.6</b>
Particulate Mass rate, kg/hour	0.011
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.62
Total Weight Gain, mg (Sample Train Blank)	0.6
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: New booth 3  
Job / Report Reference: FYS3926

Date: 10/1/06  
Run: 2

Stack Static press. mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.79			
		Stack Area (m <sup>2</sup> ):	0.49016814			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	9.1	3.017	20	7.1	2.665	20
2	8.8	2.966	20	9.8	3.130	20
3	7.2	2.683	20	9.1	3.017	20
4	5	2.236	20	8.5	2.915	20
5	3.7	1.924	20	8.2	2.864	20
6	4.6	2.145	20	7.1	2.665	20
7	3.4	1.844	20	6.5	2.550	20
8	5.2	2.280	20	6.6	2.569	20
9	5.3	2.302	20	7.8	2.793	20
10	8.6	2.933	20	8.4	2.898	20
Minimum	3.4	1.844	20	6.5	2.550	20
Maximum	9.1	3.017	20	9.8	3.130	20
Mean	6.1	2.433	20.0	7.9	2.807	20.0
Sum	60.9	24.330	200	79.1	28.065	200
Total Sum				140	52.395	400

Max. pitot press. =	9.8
Min. pitot press. =	3.4
Ratio Max:Min =	2.9 :1

Gas Data	
Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

Oxygen Correction	
Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 10/1/06  
 Run: 2

Sampling Point Ref: New booth 3	Run: 2
Meter Volume Sampled, acm	0.984
Sample Run Start Time	11:20
Sample Run End Time	11:52
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	18.0
Meter Volume at STP, scm	0.918
Meter Volume at Wet STP, scm	0.918
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	10.524
Stack Flow Rate, acms	5.158
Stack Flow Rate, scms dry, STP	4.783
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>97.3</b>
Total Mass of Particulate, mg	0.6
Percentage of Total Particulate Collected on Filter	16.7
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.7</b>
Particulate Mass rate, kg/hour	0.011
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.65
Total Weight Gain, mg (Sample Train Blank)	0.6
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 10/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: New Booth 3

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>16.91</b>	0.28	<b>18.52</b>	0.31
<b>Max</b>	<b>36.08</b>	0.60	<b>39.51</b>	0.66
<b>Min</b>	<b>4.92</b>	0.08	<b>5.39</b>	0.09
<b>Moisture, %</b>				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene,mg/m <sup>3</sup>	O2 FACTOR
11:16	7	11.48	12.57	1.00
11:17	7	11.48	12.57	1.00
11:18	7	11.48	12.57	1.00
11:19	5	8.20	8.98	1.00
11:20	12	19.68	21.55	1.00
11:21	15	24.60	26.94	1.00
11:22	22	36.08	39.51	1.00
11:23	12	19.68	21.55	1.00
11:24	7	11.48	12.57	1.00
11:25	3	4.92	5.39	1.00
11:26	16	26.24	28.74	1.00
11:27	10	16.40	17.96	1.00
11:28	14	22.96	25.15	1.00
11:29	14	22.96	25.15	1.00
11:30	6	9.84	10.78	1.00
11:31	8	13.12	14.37	1.00
11:32	6	9.84	10.78	1.00
11:33	6	9.84	10.78	1.00
11:34	34	55.76	61.07	1.00
11:35	22	36.08	39.51	1.00
11:36	11	18.04	19.76	1.00
11:37	10	16.40	17.96	1.00
11:38	8	13.12	14.37	1.00
11:39	8	13.12	14.37	1.00
11:40	6	9.84	10.78	1.00
11:41	6	9.84	10.78	1.00
11:42	6	9.84	10.78	1.00
11:43	10	16.40	17.96	1.00
11:44	6	9.84	10.78	1.00
11:45	4	6.56	7.18	1.00
11:46	4	6.56	7.18	1.00

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Red Oxide  
Job / Report Reference: FYS3926

Date: 10/1/06  
Run: 1

Stack Static press.mm H <sub>2</sub> O:	0.2	Stack Diameter (m)	0.79			
		Stack Area (m <sup>2</sup> ):	0.49016814			
Traverse Point No.	Port A			Port B		
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C
1	9.8	3.130	19			
2	10.2	3.194	19			
3	10.4	3.225	19			
4	9.8	3.130	19			
5	9.8	3.130	19			
6	8.8	2.966	19			
7	8.2	2.864	19			
8	7.6	2.757	19			
9	7.8	2.793	19			
10	7.8	2.793	19			
Minimum	7.6	2.757	19	0.0	0.000	0
Maximum	10.4	3.225	19	0.0	0.000	0
Mean	9.0	2.998	19.0	#DIV/0!	#DIV/0!	#DIV/0!
Sum	90.2	29.983	190	0	0.000	0
Total Sum				90.2	29.983	190

Max. pitot press. =	10.4
Min. pitot press. =	7.6
Ratio Max:Min =	1.4 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS:EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Lt In-stack Filter?  No  Gar. Press. mm Hg   
 Site Name: Coventry  Yes  Outstack Filter?  No  Op   
 Sampling Point Ref: Red Oxide  CH/SP  Bus%   
 Date: 10/1/06  Nozzle No.   
 Run: 1  Ambient Temp.   
 Job / Report Reference: FYS3926  Stop Time   
 Leak Rate (fm / %)   
 Leak Rate (start / %)   
 Box/Probe setting

**Sample Filter Weighings**

Reference	Laboratory	Increase, mg
394096	RPS	0.99
394098	RPS	0.5

**Sample Filter Blank Weighings**

Reference	Laboratory	Increase, mg
394600	RPS	0.1
394600	RPS	0.5

**Impinger Weighings**

Impinger	Initial	Final	Increase, g
Impinger 1			0.0
Impinger 2			0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel			0.0
<b>Total</b>			<b>0.0</b>

Sample Point	Clock Time min	Filter Δ p, mm H <sub>2</sub> O	Stack Temp, °C	Orifice Δ H, mm H <sub>2</sub> O		Gas Meter Reading m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp, °C	Root Δ p,
				Desired	Actual								
A	0	10.2	19	105.876	106	39460	20	N/A	160	160	-10		3.194
	4	10	19	103.8	104		20	N/A	160	160	-10		3.162
	8	10.2	19	105.876	106		20	N/A	160	160	-10		3.194
	12	10.2	19	105.876	106		20	N/A	160	160	-10		3.194
	16	10	19	103.8	104		20	N/A	160	160	-10		3.162
	20	8.8	19	91.344	91.3		20	N/A	160	160	-10		2.986
	24	10.2	19	105.876	106		20	N/A	160	160	-11		3.194
Endpoint	28	10.1	19	104.836	106		20	N/A	160	160	-12		3.178
Endpoint	32		19			40464	20	N/A	160	160	-10.4	#DIV/0!	
	32:00	9.963	19.0	103.4	103.7	1.0	20.0	N/A	160.0	160.0	-10.4	#DIV/0!	3.156

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 10/1/06  
 Run: 1

Sampling Point Ref: Red Oxide	Run: 1
Meter Volume Sampled, acm	1.004
Sample Run Start Time	13:40
Sample Run End Time	14:12
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	19.0
Meter Volume at STP, scm	0.934
Meter Volume at Wet STP, scm	0.934
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	10.498
Stack Flow Rate, acms	5.146
Stack Flow Rate, scms dry, STP	4.755
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>99.5</b>
Total Mass of Particulate, mg	1.5
Percentage of Total Particulate Collected on Filter	66.4
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>1.6</b>
Particulate Mass rate, kg/hour	0.027
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.64
Total Weight Gain, mg (Sample Train Blank)	0.6
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Ltd  
Site Name: Coventry  
Sampling Point Ref: Red Oxide  
Job / Report Reference: FYS3926

Date: 10/1/06  
Run: 2

Stack Static press.mm H <sub>2</sub> O:		0.2		Stack Diameter (m)		0.79	
				Stack Area (m <sup>2</sup> ):		0.49016814	
Traverse Point No.	Port A			Port B			
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	
1	9.8	3.130	19				
2	10.2	3.194	19				
3	10.4	3.225	19				
4	9.8	3.130	19				
5	9.8	3.130	19				
6	8.8	2.966	19				
7	8.2	2.864	19				
8	7.6	2.757	19				
9	7.8	2.793	19				
10	7.8	2.793	19				
Minimum	7.6	2.757	19	0.0	0.000	0	
Maximum	10.4	3.225	19	0.0	0.000	0	
Mean	9.0	2.998	19.0	#DIV/0!	#DIV/0!	#DIV/0!	
Sum	90.2	29.983	190	0	0.000	0	
Total Sum				90.2	29.983	190	

Max. pitot press. =	10.4
Min. pitot press. =	7.6
Ratio Max:Min =	1.4 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Yes
Duct Gas Flow Negative Velocity: Not Permitted	No
Duct Gas Flow: Ratio of max to min velocity <3:1?	Yes
Working Area > 5m <sup>2</sup> ?	No
Handrails with removable chains / self closing gates across the top of the ladder?	No
Handrails (approx 0,5 and 1,0 m high) and vertical baseboards (approx 0,25m high)?	Yes
Able to bear 400kg load?	Yes
Handrails not restricting access to ports?	No
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	No
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Yes

Company Name: Covrad Heat Transfer Ltd  
 Site Name: Coventry  
 Job / Report Reference: FYS3926

Date: 10/1/06  
 Run: 1

Sampling Point Ref: New booth 1	Run: 1
Meter Volume Sampled, acm	0.929
Sample Run Start Time	14:40
Sample Run End Time	14:12
Total Actual Sampling Time, min	32.0
Barometric Pressure, mm Hg	751.53
Stack Pressure, mm Hg	751.54
Average Stack Temp, °C	18.9
Meter Volume at STP, scm	0.882
Meter Volume at Wet STP, scm	0.882
Stack Moisture Content, %	0.0
Average Stack Velocity, m/sec	8.771
Stack Flow Rate, acms	4.299
Stack Flow Rate, scms dry, STP	3.974
Nozzle Diameter, mm	8.00
<b>% Isokinetic Variation</b>	<b>112.5</b>
Total Mass of Particulate, mg	16.8
Percentage of Total Particulate Collected on Filter	79.6
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>19.1</b>
Particulate Mass rate, kg/hour	0.273
Emission Limit value	<b>50.000</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.68
Total Weight Gain, mg (Sample Train Blank)	0.6
Blank Result Less than 10% of Limit Value	Yes

Company Name: Covrad Heat Transfer Date: 09/01/2006  
 Site Ref: Coventry Run: 1  
 Stack Ref: Red Oxide

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
<b>Average</b>	<b>22.34</b>	<b>0.37</b>	<b>24.47</b>	<b>0.41</b>
<b>Max</b>	<b>39.36</b>	<b>0.66</b>	<b>43.11</b>	<b>0.72</b>
<b>Min</b>	<b>11.48</b>	<b>0.19</b>	<b>12.57</b>	<b>0.21</b>

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene,mg/m <sup>3</sup>	O2 FACTOR
14:30	11	18.04	19.76	1.00
14:31	8	13.12	14.37	1.00
14:32	10	16.40	17.96	1.00
14:33	12	19.68	21.55	1.00
14:34	22	36.08	39.51	1.00
14:35	14	22.96	25.15	1.00
14:36	16	26.24	28.74	1.00
14:37	22	36.08	39.51	1.00
14:38	15	24.60	26.94	1.00
14:39	24	39.36	43.11	1.00
14:40	16	26.24	28.74	1.00
14:41	11	18.04	19.76	1.00
14:42	7	11.48	12.57	1.00
14:43	12	19.68	21.55	1.00
14:44	10	16.40	17.96	1.00
14:45	8	13.12	14.37	1.00
14:46	11	18.04	19.76	1.00
14:47	10	16.40	17.96	1.00
14:48	22	36.08	39.51	1.00
14:49	16	26.24	28.74	1.00
14:50	15	24.60	26.94	1.00
14:51	16	26.24	28.74	1.00
14:52	7	11.48	12.57	1.00
14:53	8	13.12	14.37	1.00
14:54	10	16.40	17.96	1.00
14:55	12	19.68	21.55	1.00
14:56	11	18.04	19.76	1.00
14:57	24	39.36	43.11	1.00
14:58	22	36.08	39.51	1.00
14:59	14	22.96	25.15	1.00
15:00	12	19.68	21.55	1.00
15:01	8	13.12	14.37	1.00

Company Name: Covrad Heat Transfer Date: 09/01/2006  
 Site Ref: Coventry Run: 1  
 Slack Ref: Trike Bath

	VOC as C mg/m <sup>3</sup>	VOC as C kg/hr	VOC as Toluene mg/m <sup>3</sup>	VOC as Toluene kg/hr
Average	123.10	0.08	134.82	0.08
Max	229.59	0.14	251.46	0.16
Min	72.16	0.05	79.03	0.05
Moisture, %				

Time min	VOC, ppm	VOC as C, mg/m <sup>3</sup>	VOC as Toluene, mg/m <sup>3</sup>	O2 FACTOR
14:10	140	229.59	251.46	1.00
14:11	100	163.99	179.61	1.00
14:12	62	101.68	111.36	1.00
14:13	44	72.16	79.03	1.00
14:14	52	85.28	93.40	1.00
14:15	62	101.68	111.36	1.00
14:16	44	72.16	79.03	1.00
14:17	70	114.80	125.73	1.00
14:18	52	85.28	93.40	1.00
14:19	46	75.44	82.62	1.00
14:20	46	75.44	82.62	1.00
14:21	130	213.19	233.50	1.00
14:22	110	180.39	197.57	1.00
14:23	100	163.99	179.61	1.00
14:24	68	111.52	122.14	1.00
14:25	75	123.00	134.71	1.00
14:26	82	134.48	147.28	1.00
14:27	61	100.04	109.56	1.00
14:28	45	73.80	80.83	1.00
14:29	61	100.04	109.56	1.00
14:30	60	98.40	107.77	1.00
14:31	65	106.60	116.75	1.00
14:32	60	98.40	107.77	1.00
14:33	40	65.60	71.85	1.00
14:34	33	54.12	59.27	1.00
14:35	78	127.92	140.10	1.00
14:36	50	82.00	89.81	1.00
14:37	54	88.56	96.99	1.00
14:38	48	78.72	86.21	1.00
14:39	44	72.16	79.03	1.00
14:40	25	41.00	44.90	1.00
14:41	38	62.32	68.25	1.00
14:42	32	52.48	57.48	1.00
14:43	45	73.80	80.83	1.00
14:44	50	82.00	89.81	1.00
14:45	32	52.48	57.48	1.00
14:46	38	62.32	68.25	1.00
14:47	45	73.80	80.83	1.00
14:48	52	85.28	93.40	1.00
14:49	50	82.00	89.81	1.00
14:50	30	49.20	53.88	1.00
14:51	50	82.00	89.81	1.00
14:52	40	65.60	71.85	1.00
14:53	40	65.60	71.85	1.00
14:54	40	65.60	71.85	1.00
14:55	35	57.40	62.86	1.00
14:56	36	59.04	64.66	1.00
14:57	28	45.92	50.29	1.00
14:58	32	52.48	57.48	1.00
14:59	32	52.48	57.48	1.00
15:00	34	55.76	61.07	1.00
15:01	30	49.20	53.88	1.00
15:02	22	36.08	39.51	1.00
15:03	84	137.76	150.87	1.00
15:04	34	55.76	61.07	1.00
15:05	38	62.32	68.25	1.00
15:06	42	68.88	75.44	1.00
15:07	46	75.44	82.62	1.00
15:08	50	82.00	89.81	1.00
15:09	54	88.56	96.99	1.00
15:10	58	95.12	104.18	1.00

**TRICHLOROETHYLENE SAMPLING DATA**

Client	Covrad			Job Number	FYS3926		
Site	Coventry			Date	09-Jan-06		
Stack	Large Degreaser			Operators	SP/GH		
Pollutant	Trichloroethylene			Sample Method	BS EN 13649		
Absorbent(s)	2 x SKC 226-09 Charcoal Tube			Analysis Method	GC		
Gas Velocity	3.90	m/s		Duct dimensions.	0.25	m	
Gas Temp	21	°C		Duct Area	0.05	m <sup>2</sup>	
Act. Vol. Flow	0.19	m <sup>3</sup> /s		S.t.p. Volume Flow	0.18	m <sup>3</sup> /s	

Run	Short Term	Start	Finish	Sample		
Leak Check OK?		Y	Y			
Time		14:18	14:28			
Sample Flow Rate (ml/min)		200	200	Net Total Analyte (mg)	0.850	
DGM Temp (°C)		20	20	Atmos Pressure (kPa)	100.9	
Volume Gas Sampled (l)		0.0022		S.t.p. Volume sampled (m <sup>3</sup> )	0.0021	
No. mins sampling (mins)		11		DGM / Flowmeter error (%)	****	
		As solvent (Trike)	As total carbon		As solvent (Trike)	As total carbon
Mass Emission Rate (g/hr)		263.3	48.1	S.t.p. Emission Conc. (mg/m <sup>3</sup> )	413.0	75.5

Run	Long Term	Start	Finish	Sample		
Leak Check OK?		Y	Y			
Time		13.38	14.32			
Sample Flow Rate (ml/min)		200	200	Net Total Analyte (mg)	3.0	
DGM Temp (°C)		20	20	Atmos. Pressure (kPa)	100.9	
Volume Gas Sampled (l)		10.8		S.t.p. Volume sampled (m <sup>3</sup> )	0.01	
No. mins sampling (mins)		54		DGM / Flowmeter error (%)	****	
		As solvent (Trike)	As total carbon		As solvent (Trike)	As total carbon
Mass Emission Rate (g/hr)		189.3	34.6	S.t.p. Emission Conc. (mg/m <sup>3</sup> )	297.0	54.3

**Table 2.8 – Monitoring Results from the (Red Oxide)**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (%)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter Run 1	50*	1.6	mg/m <sup>3</sup>	N/A	Dry; 273K, 101.3kPa, no correction required for O <sub>2</sub> ..	10/9/2004	13:35-14:07	BS ISO 9096:2003	MCERTS	Normal
	N/A	27	g/hr							
Total Particulate Matter Run 2	50*	1.5	mg/m <sup>3</sup>	N/A	Dry; 273K, 101.3kPa, no correction required for O <sub>2</sub> ..	10/9/2004	12:00-12:30	BS ISO 9096:2003	MCERTS	Normal
	N/A	25	g/hr							
High Concentration VOC (as total organic carbon)	50*	16.91	mg/m <sup>3</sup>		Dry; 273K, 101.3kPa, no correction required for O <sub>2</sub> .	10/01/2006	11:16-11:46	BS EN 13526:2002	MCERTS	Normal
	N/A	280	g/hr	9.8						

**Notes:**

# *The uncertainty associated with the quoted result is at the 95% confidence interval*

\* *As 30 minute mean (Stated in PG 6/23(04)) "Coating of Metals and Plastics"*