



Davies & Co (Engineering) Ltd

Moor Rd
Leeds
LS10 2DD

Tel: 0113 270 4651
Fax: 0113 276 5759
E-mail: info@davies-co-ltd.com

EMISSIONS MONITORING TEST REPORT

**Canley Crematorium
Cannon Hill Road
Coventry
CV4 7DF**

23rd – 25th July 2013

Report Prepared by _____ Date 2nd September 2013
Mr J L Boyce
Emissions Monitoring Team Leader
MCertS level 2 + TE1,2,3,4
MM 06 707

Report Authorised by _____ Date 2nd September 2013
Mr S P Atherton
Business Manager
EA MCertS Level 2 + TE1,2,3,4
MM 03 336

CONTENTS

1. INTRODUCTION

2. PROCEDURES

- 2.1 Total Particulate Matter
- 2.2 Hydrogen Chloride
- 2.3 Mercury
- 2.4 Carbon Monoxide
- 2.5 Volatile Organic Compounds
- 2.6 Oxygen
- 2.7 Moisture
- 2.8 Temperature
- 2.9 Velocity and Volumetric Flow

3. RESULTS

TABLE 1 – Coventry Cremators 1&2 Particulate & HCl Emission Results

TABLE 2 – Coventry Cremators 1&2 Mercury Emission Results

TABLE 3 – Comparison of Cremator 1&2 Test Results with Site Instrumentation

TABLE 4 – Coventry Cremators 3&4 Particulate & HCl Emission Results

TABLE 5 – Coventry Cremators 3&4 Mercury Emission Results

TABLE 6 – Comparison of Cremator 3&4 Test Results with Site Instrumentation

4. COMMENTS

5. QUALITY CONTROL

APPENDIX 1 Data Logs and Calculations

APPENDIX 2 Analysis Reports

APPENDIX 3 Details of Plant Operation during testing.



1. INTRODUCTION

The four cremators and associated flue gas treatment systems at Canley Crematorium, Coventry, were monitored between the 23rd and 25th July 2013 to the requirements given in Process Guidance Note PG5/2 (2012) for emission releases to atmosphere for abated plant.

The work involved monitoring a range of flue gas components with the plant operating normally.

The plant comprises four Cremators designated as the Evans Universal series 300/2 model. The cremators are fitted with three nozzle mix burners utilising gas as the support fuel.

The waste gases from cremators 1 and 2 combine, and are ducted to a common flue gas treatment plant. The treatment plant comprises a shell and tube boiler to cool the flue gases, a reagent feeder station that introduces a blend of activated carbon/sodium bicarbonate to react with the cooled gases, and a bag filter to clean the treated gases. The waste heat from the boiler in the form of warm water is dissipated to atmosphere via a finned tube air blast cooler situated outside the crematory.

The waste Gases from cremators 3 and 4 also combine and are ducted into a 2nd flue gas treatment plant operating in the same manner as with the plant attached to cremators 1 and 2.

Both plants operate under full microprocessor based automatic control that requires little manual intervention.

The cremators and flue gas clean up system were manufactured, installed and commissioned by Facultatieve Technologies Limited to meet the requirements of the Environmental Permitting (England and Wales) Regulations 2007 – (EPR 2007) as relevant to cremators, summarised in the Secretary of State's Process Guidance Note PG 5/2 (2012).

The flue ducting and test points were in accordance with the requirements of EA TGN M1.

Measurements were undertaken to enable comparisons to be made of the operation of the cremators and associated flue gas treatment system with the requirements of the Guidance Note in terms of emission releases to air.

The two plants were tested in normal operation, and "as found". The operating patterns of the cremators are dictated by the number of cremations to be completed during the working day, and the times the Funeral services take place. It follows that either one or both cremators can be operational at any one time during the working day, and these are served by the common abatement plant being tested.

This report details the monitoring procedures used and the results obtained from this test work along with comparisons with the Guidance Note requirements and comments where appropriate.

Relevant procedures were followed to enable quality control to be maintained throughout the test preparation, site test work, laboratory analysis, calculations and reporting.



2. PROCEDURES

2.1 Total Particulate Matter

A flue gas sample was extracted and filtered to collect total particulate matter. A Whatman QM-A filter paper was used with a particle retention of not less than 99.5% at a particle size of 0.3 micron. The flue gas extraction employed techniques given in BS EN 13284 Part 1.

The sampling was conducted using apparatus in accordance with the requirements of BS EN 13284 Part 1.

This consisted of a heated known dimension Pyrex glass nozzle, heated Pyrex glass probe liner, heated Pyrex glass filter housing with Titanium filter support containing quartz microfibre filter (all heaters set to 160°C), PTFE sample line, dreschel absorption bottles, gas dryer (silica gel), sample line to pump, pump, gas meter, rotameter, pitot and impulse lines, electronic manometer, type K thermocouple, balance (for gravimetric moisture) and datalogger. Settings tables were pre-prepared to enable isokinetic flow to be maintained (based on online measurements of flue gas velocity and temperature to set nozzle flow / pump rate (l/min)).

Particulate matter analysis was carried out by weighing the filter and probe rinse collection on a calibrated balance, with the media being dried and weighed prior to and following the test.

The tests reported herein were conducted to prove the performance of the cremators relative to PG5/2(2012).

2.2 Hydrogen Chloride

A flue gas sample was extracted and filtered.

A Whatman QM-A filter paper was used with a particle retention of not less than 99.5% at a particle size of 0.3 micron. The flue gas extraction employed techniques given in BS EN 13284 Part 1, incorporating the modifications given in Clause 2.1 above, to reflect the variable, batch nature of the process.

The gas sample was then passed through an absorption medium of de-ionised water to collect hydrogen chloride.

The method employed was BS EN 1911 Parts 1-3.

Laboratory analysis for hydrogen chloride was carried out on the absorption medium using Ion Chromatography (IC).

2.3 Mercury

A flue gas sample was extracted and filtered to collect solid phase mercury.

A Whatman QM-A filter paper was used with a particle retention of not less than 99.5% at a particle size
JB/DEM0657/25.07.13/Page 4



Davies & Co (Engineering) Ltd

of 0.3 micron. The flue gas extraction employed techniques given in BS EN 13284 Part 1, incorporating the modifications given in Clause 2.1 above, to reflect the variable, batch nature of the process.

The gas sample was then passed through an absorption medium of acidified potassium dichromate to collect vapour phase mercury.

The method employed was BS EN 13211.

The Environment Agency Note Monitoring Guidance Note M2 recommends that a suitable sample averaging period is used to ensure an adequate limit of detection (LOD). As plant operation is variable in terms of the number of cremators in use at any one time, the nature of the charges being introduced to the cremators is unknown, and the expected pollutant concentrations will be low given that the plant is abated, sample durations were adjusted for each test according to circumstances at that time.

Laboratory analysis for solid and vapour phase mercury was carried out on the filter and absorption medium using Inductively Coupled Plasma (ICP-OES) Spectrophotometry.

2.4 Carbon Monoxide

A flue gas sample was continuously extracted, filtered and dried before being passed through a pre-calibrated Siemens Ultramat 23/O₂ infrared analyser for the on-line measurement of carbon monoxide. The analyser has a fixed range of 0-1250 mg/Nm³ and was zeroed with air and calibrated with a nominal 800 ppmv carbon monoxide in balance nitrogen gas.

The method employed was BS ISO 12039.

The analyser output was continuously recorded using a Grant 'Squirrel' data logger.

For these tests a relatively high range analyser was used due to the typical pattern of carbon monoxide concentration emissions from cremators being very low (often indicated as zero) for most of the cycle, but with occasional, high, short duration spikes of CO being emitted. The convention since non-continuous emissions monitoring became a mandatory requirement for cremators during 1990, has been to attempt to monitor the magnitude of spikes, as these are often the main contributor to total CO emissions. If the mean one minute emission of CO was say 200 mg/Nm³, it would be expected that the peak concentration during that one minute averaging period would be considerably higher than this. It follows that utilising a lower range analyser would frequently underestimate CO emissions, despite increasing sensitivity at low CO concentrations.

2.5 Volatile Organic Compounds

A flue gas sample was continuously extracted and filtered before being passed via a heated line through a pre-calibrated Signal 3030PM Flame Ionisation Detection (FID) analyser for the on-line measurement of volatile organic compounds. The analyser was ranged 0-100 ppmv total hydrocarbons and was zeroed with air passed through a catalytic converter and calibrated with a nominal 50 ppmv propane in



balance air gas.

The method employed was BS EN 12619.

The analyser output was continuously recorded using a Grant 'Squirrel' data logger.

Similar comments apply to VOC's as CO, in that the analyser scaling is set to quantify the peaks that are the nature of the emission.

2.6 Oxygen

A flue gas sample was continuously extracted from the same position in the flue as the other pollutants extraction, filtered and dried before being passed through a pre-calibrated Siemens Ultramat 23/O₂ electrochemical cell analyser for the on-line measurement of flue oxygen.

The method employed was BS ISO 12039.

The analyser was calibrated using a standard reference gas in the laboratory before and after the site visit, and with nitrogen "zero" gas and air at the start and end of each day's testing on site. It was assumed that calibration linearity was maintained during sampling, and the post checks indicated that this was the case.

The outputs of the analysers were continuously recorded using a Grant 'Squirrel' data logger.

2.7 Moisture

A flue gas sample was extracted and filtered. The gas sample was then passed through an absorption medium to collect any water vapour.

The method employed was BS EN 14790.

Flue gas moisture was determined gravimetrically by weighing the absorption medium and final gas drier prior to and following the test.

This was carried out alongside testing for hydrogen chloride and mercury.

2.8 Temperature

The cremator secondary chamber exit and flue (filter outlet) temperatures were measured by the use of calibrated Type K thermocouples.

The method employed was BS EN 13284 Part 1.

The gas temperatures were continuously recorded using a Grant 'Squirrel' data logger.



2.9 Velocity and Volumetric Flow

Flue gas velocity was found from inserting a calibrated s-type pitot tube into the flue. The pitot head pressure was then measured using a calibrated electronic manometer.

The method employed was BS EN 13284 Part 1.

The electronic manometer output was continuously recorded using a Grant 'Squirrel' data logger.

Flue gas velocity was then calculated from Bernoulli's equation as the density of the flue gas was known (from measurements of flue gas moisture and temperature).

Flue gas volumetric flow rate was found from the measurement of the flue duct size and hence its area and corrected to normalised conditions (again from measurements of flue gas moisture and temperature).



3. RESULTS

The results are summarised in Tables 1 to 6.

Total Particulate Matter, Hydrogen Chloride, Carbon Monoxide and Volatile Organic Compound determinations are given in Table 1(Cremators 1&2) & Table 4(Cremators 3&4).

Mercury determinations are given in Table 2(Cremators 1&2) & Table 5(Cremators 3&4).

A comparison of test results with site instrumentation is given in table 3(Cremators 1&2) & Table 6 (Cremators 3&4).

Moisture determinations were made on all tests.

Carbon Monoxide, Volatile Organic Compounds, Oxygen, Temperature and Velocity and Volumetric Flow were continuously monitored.

All values in the tables are corrected to the reference conditions of 273K, 101.3kPa, 11%v/v oxygen and dry gas as given in PG5/2(12) where required.

All the data logs and calculations can be seen in Appendix 1.

All the analysis reports can be seen in Appendix 2.

Appendix 3 gives details of plant operation during the various tests.



TABLE 1
Coventry Cremators 1 & 2 Abatement System Outlet
Emissions Monitoring 24 -25th July 2013
Total Particulate Matter & Hydrogen Chloride Sampling

		Test 12 - 2	Test 12 - 3	Test 12 - 4	Average	Requirement to PG5/2 (2012)
Total Particulate Matter	- mg/Nm ³ c.	0.56 ± 1.84	0.00 ± ####	0.04 ± 1.55	0.20	<20
Hydrogen Chloride	- mg/Nm ³ c.	15.65 ± 2.00	30.40 ± 3.49	7.20 ± 0.85	17.75	<30
Carbon Monoxide						
Test Average	- mg/Nm ³ c.	0.12 ± 0.01	7.59 ± 0.38	2.53 ± 0.13	3.41	<100
First 30 min Average	- mg/Nm ³ c.	0.00 ± 0.00	0.56 ± 0.03	0.24 ± 0.01	-	
Second 30 min Average	- mg/Nm ³ c.	0.25 ± 0.01	14.85 ± 0.74	4.90 ± 0.24	-	
First 60 min Average	- mg/Nm ³ c.	0.12 ± 0.01	7.59 ± 0.38	2.53 ± 0.13	-	
Organic Compounds	- mg/Nm ³ c.	0.01 ± 0.00	0.69 ± 0.03	0.12 ± 0.01	0.27	<20

Flue Oxygen	- %v/v dry	14.34 ± 0.10	15.95 ± 0.10	12.52 ± 0.10	14.27	
Flue Moisture	- %v/v	8.1 ± 0.8	8.2 ± 0.8	7.8 ± 0.8	8.0	
	- %w/w	5.2 ± 0.5	5.3 ± 0.5	5.0 ± 0.5	5.1	
Flue Temperature	- Deg C	138 ± 2	127 ± 2	120 ± 2	128	
Volumetric Flow	- Nm ³ /h dry	2698 ± 54	1986 ± 40	2698 ± 54	2461	

Note 1: All emissions as concentration levels are given as mg/Nm³ corrected to 11%v/v oxygen and dry gas

Note 2: All uncertainties (±) are calculated to a 95% confidence interval

Uncertainties estimated using the procedure suggested in the STA Quality Guidance Note QGN001-01



TABLE 2
Coventry Cremators 1 & 2 Abatement System Outlet
Emissions Monitoring 24th July 2013
Mercury Sampling

		Test 12 - 1	Requirement to PG5/2 (2012)
Mercury	- $\mu\text{g}/\text{Nm}^3\text{c.}$	6.10 ± 0.37	<50
Flue Oxygen	- %v/v dry	13.53 \pm 0.10	
Flue Moisture	- %v/v	10.5 \pm 1.1	
	- %w/w	6.8 \pm 0.7	
Flue Temperature	- Deg C	129 \pm 2	
Volumetric Flow	- Nm^3/h dry	2542 \pm 51	

Note 1: All emissions as concentration levels are given as $\mu\text{g}/\text{Nm}^3$ or mg/Nm^3 corrected to 11%v/v oxygen and dry gas

Note 2: All uncertainties (\pm) are calculated to a 95% confidence interval

Uncertainties estimated using the procedure suggested in the STA Quality Guidance Note QGN001-01



TABLE 3**Comparison of Test Results with Site Instrumentation - Cremators 1 & 2**

Cremator	Test	Date	Cremation	Averaging Period (mins)	Carbon Monoxide mg/Nm ³	
					Davies & Co	Site
Number 1	12 - 2	July 24, 2013	3	0 - 30	0	0
Number 1	12 - 3	July 24, 2013	3	30 - 60	0	0
Number 1	12 - 4	July 25, 2013	1	0 - 30	0	0

Note 1: All emission concentration levels are given as mg/Nm³ corrected to 11% oxygen, 273K & dry gas

Note 2: The results are taken as an average from either the 1st or 2nd 30 minute section of the cremation cycle



TABLE 4
Coventry Cremators 3 & 4 Abatement System Outlet
Emissions Monitoring 23rd July 2013
Total Particulate Matter & Hydrogen Chloride Sampling

		Test 34 - 1	Test 34 - 2	Test 34 - 3	Average	Requirement to PG5/2 (2012)
Total Particulate Matter	- mg/Nm ³ c.	0.05 ± 2.21	0.00 ± ####	1.05 ± 3.10	0.37	<20
Hydrogen Chloride	- mg/Nm ³ c.	8.59 ± 2.26	75.48 ± 5.46	43.47 ± 3.44	42.51	<30
Carbon Monoxide						
Test Average	- mg/Nm ³ c.	2.20 ± 0.11	42.68 ± 2.13	5.24 ± 0.26	16.71	<100
First 30 min Average	- mg/Nm ³ c.	4.20 ± 0.21	39.85 ± 1.99	10.31 ± 0.52	-	
Second 30 min Average	- mg/Nm ³ c.	0.13 ± 0.01	45.62 ± 2.28	0.00 ± 0.00	-	
First 60 min Average	- mg/Nm ³ c.	2.20 ± 0.11	42.68 ± 2.13	5.24 ± 0.26	-	
Organic Compounds	- mg/Nm ³ c.	0.00 ± 0.00	2.47 ± 0.12	0.06 ± 0.00	0.84	<20
Flue Oxygen	- %v/v dry	15.53 ± 0.10	17.03 ± 0.10	17.60 ± 0.10	16.72	
Flue Moisture	- %v/v	8.0 ± 0.8	5.7 ± 0.6	2.9 ± 0.3	5.5	
	- %w/w	5.1 ± 0.5	3.6 ± 0.4	1.8 ± 0.2	3.5	
Flue Temperature	- Deg C	92 ± 2	97 ± 2	96 ± 2	95	
Volumetric Flow	- Nm ³ /h dry	4562 ± 91	4676 ± 94	4419 ± 88	4552	

Note 1: All emissions as concentration levels are given as mg/Nm³ corrected to 11%v/v oxygen and dry gas

Note 2: All uncertainties (±) are calculated to a 95% confidence interval

Uncertainties estimated using the procedure suggested in the STA Quality Guidance Note QGN001-01



TABLE 5
Coventry Cremators 3 & 4 Abatement System Outlet
Emissions Monitoring 23rd July 2013
Mercury Sampling

		Test 34-4	Requirement to PG5/2 (2012)
Mercury	- $\mu\text{g}/\text{Nm}^3\text{c.}$	3.79 ± 0.41	<50
Flue Oxygen	- %v/v dry	17.10 \pm 0.10	
Flue Moisture	- %v/v	8.6 \pm 0.9	
	- %w/w	5.5 \pm 0.6	
Flue Temperature	- Deg C	98 \pm 2	
Volumetric Flow	- Nm^3/h dry	3983 \pm 80	

Note 1: All emissions as concentration levels are given as $\mu\text{g}/\text{Nm}^3$ or mg/Nm^3 corrected to 11%v/v oxygen and dry gas

Note 2: All uncertainties (\pm) are calculated to a 95% confidence interval

Uncertainties estimated using the procedure suggested in the STA Quality Guidance Note QGN001-01



TABLE 6**Comparison of Test Results with Site Instrumentation - Cremators 3 & 4**

Cremator	Test	Date	Cremation	Averaging	Carbon Monoxide mg/Nm ³	
				Period (mins)	Davies & Co	Site
Number 3	34 - 1	July 23, 2013	1	0 - 30	0	4
Number 3	34 - 1	July 23, 2013	1	30 - 60	0	0
Number 4	34 - 2	July 23, 2013	2	0 - 30	40	5

Note 1: All emission concentration levels are given as mg/Nm³ corrected to 11% oxygen, 273K & dry gas

Note 2: The results are taken as an average from either the 1st or 2nd 30 minute section of the cremation cycle



4. COMMENTS

The results from these series of tests demonstrate that both plants satisfy the requirements of PG5/2(2012) for the release to air of particulate matter, mercury, carbon monoxide and volatile organic compounds.

The emission to air of HCl from the Cremator 1 & 2 abatement plant was above the limit.

Combustion within the cremator secondary combustion chambers was good as is indicated by the low emissions of CO and VOC's.

No visible chimney emissions were observed throughout the test work other than the expected steam plume during preheat.

PG5/2 (2012) states that the continuous emission monitors (CEMs) should be periodically checked (calibrated) to ensure that the readings being reported are correct.

The PCME particulate monitor primarily functions as a filter leak detector rather than being calibrated to give qualitative results. This instrument is more than capable of satisfying this function.



5. QUALITY CONTROL

All the tests performed were carried out to the methods given in the appropriate listed Standards using calibrated equipment. The gas analysers were calibrated prior to, and during use using suitable, certified calibration gases.

Analysis of the filters and absorbers was carried out in-house and at an external laboratory.

For this test work the following external laboratory was used for the given determinations:

Scientific Analysis Laboratories (SAL) } Hydrogen Chloride
 Mercury



APPENDIX 1

Data Logs and Calculations



Explanation of Data Logs

Data is taken from a Grant Squirrel data logger.

Time is from logger clock.

Flue Gas Temp is direct from test flue thermocouple.

Meter Temp is direct from gas meter.

(The stated meter temperature is that of the sampled gas at the meter, and is not the room ambient temperature. The temperature always increases during a test due to the heat gain from the sample pump that is contained in an enclosed box along with the gas meter, and this is quite normal).

Flue O₂ is from the Siemens Ultramat U23/O₂ analyser.

CO is from the Siemens Ultramat U23/O₂ analyser.

VOC is from the Signal 3030PM FID analyser expressed as carbon equivalent.

Sample Point Pa is from the pitot tube to an Furness Controls electronic manometer.

The room temperature was typically 20°C, and there were no issues with the analysers overheating. Functional and calibration checks at the start and end of each test confirmed correct operation of the analysers.

All values in the tables are corrected to the reference conditions of 273K, 101.3kPa, 11%v/v oxygen and dry gas as given in PG5/2(12) where required.



Site Instrumentation Calibration Data

	Siemens Ultramat 23		Signal 3030PM VOC
	CO	O ₂	
Type of Check		Pre-testing calibration	
Date of Check	23/07/2013	23/07/2013	23/07/2013
Time of Check	08:15	08:15	08:25
Test Reference	Tests 34-1,2,3&4	Tests 34-1,2,3&4	Tests 34-1,2,&3
Zero reading at analyser	0 mg/m ³	0.00%	0.0 ppm
Span reading at analyser	1024 mg/m ³	20.95%	53.4 ppm
Zero check down line	0 mg/m ³	0.10%	0.0 ppm
Span check down line	1021 mg/m ³	20.95%	53.7 ppm
Type of Check		Post-testing calibration	
Date of Check	23/07/2013	23/07/2013	23/07/2013
Time of Check	17:00	17:00	12:30
Test Reference	Tests 34-1,2,3&4	Tests 34-1,2,3&4	Tests 34-1,2,&3
Zero in air at analyser	0 mg/m ³	0.00%	0.3 ppm
Span in air at analyser	1026 mg/m ³	21.03%	54.0 ppm
Type of Check		Pre-testing calibration	
Date of Check	24/07/2013	24/07/2013	24/07/2013
Time of Check	10:20	10:20	14:15
Test Reference	Tests 12-1,2&3	Tests 12-1,2&3	Tests 12-2&3
Zero reading at analyser	0 mg/m ³	0.00%	0.0 ppm
Span reading at analyser	1026 mg/m ³	20.95%	53.5 ppm
Zero check down line	0 mg/m ³	0.20%	0.0 ppm
Span check down line	1021 mg/m ³	20.95%	53.2 ppm
Type of Check		Post-testing calibration	
Date of Check	24/07/2013	24/07/2013	24/07/2013
Time of Check	16:50	16:50	17:00
Test Reference	Tests 12-1,2&3	Tests 12-1,2&3	Tests 12-2&3
Zero in air at analyser	0 mg/m ³	0.00%	0.3 ppm
Span in air at analyser	1028 mg/m ³	21.01%	53.9 ppm
Type of Check		Pre-testing calibration	
Date of Check	25/07/2013	25/07/2013	25/07/2013
Time of Check	09:40	09:40	09:40
Test Reference	Tests 12-4	Tests 12-4	Tests 12-4
Zero reading at analyser	0 mg/m ³	0.00%	0.0 ppm
Span reading at analyser	1026 mg/m ³	20.96%	53.5 ppm
Zero check down line	0 mg/m ³	0.20%	0.0 ppm
Span check down line	1021 mg/m ³	20.96%	53.2 ppm
Type of Check		Post-testing calibration	
Date of Check	25/07/2013	25/07/2013	25/07/2013
Time of Check	11:10	11:10	11:10
Test Reference	Tests 12-4	Tests 12-4	Tests 12-4
Zero in air at analyser	0 mg/m ³	0.00%	0.3 ppm
Span in air at analyser	1027 mg/m ³	21.02%	54.1 ppm

Calibration Gases

Gas	Supplier	Cylinder No.	Nominal Conc.	Certified Conc.	Analytical Tolerance ± %
Carbon monoxide in Nitrogen	BOC	147389	800 ppm	817 ppm	2
Propane in synthetic air	BOC	137127	50 ppm	53.6 ppm	2
Oxygen	Fresh air	-	20.9%	-	-



Coventry Cremators 1 & 2 Abatement System Outlet

Data Log

24/07/13

Test 12 - 2

Time	Flue Gas °C	Meter °C	Flue Oxygen %v/v dry	CO mg/Nm³ c.	VOC mg/Nm³ c.	Pitot Head Pa
14:27	133	52.6	14.95	0.00	0.00	71.0
14:28	133	52.4	15.50	0.00	0.00	82.3
14:29	134	52.3	15.65	0.00	0.00	83.2
14:30	134	52.0	14.40	0.00	0.00	81.9
14:31	135	52.0	13.65	0.00	0.00	91.6
14:32	135	51.7	14.10	0.00	0.00	85.7
14:33	135	51.6	14.00	0.00	0.00	73.1
14:34	135	51.6	13.85	0.00	0.00	74.3
14:35	136	51.7	13.85	0.00	0.00	75.2
14:36	136	51.6	13.95	0.00	0.00	78.5
14:37	136	51.4	14.00	0.00	0.00	73.1
14:38	136	51.3	13.85	0.00	0.00	72.7
14:39	137	51.2	13.85	0.00	0.01	79.0
14:40	137	51.0	13.90	0.00	0.00	78.1
14:41	137	50.9	13.80	0.00	0.00	77.3
14:42	138	50.8	13.95	0.00	0.00	95.3
14:43	139	50.6	14.30	0.00	0.00	105.8
14:44	140	50.6	14.35	0.00	0.00	107.9
14:45	141	50.6	14.40	0.00	0.00	111.3
14:46	142	50.5	14.50	0.00	0.00	113.8
14:47	143	50.4	14.50	0.00	0.00	131.5
14:48	146	50.2	14.75	0.00	0.00	161.7
14:49	147	50.2	15.05	0.00	0.00	151.6
14:50	147	50.2	15.05	0.00	0.00	146.2
14:51	148	50.1	14.70	0.00	0.00	152.5
14:52	149	50.2	14.45	0.00	0.00	137.3
14:53	149	50.2	14.60	0.00	0.00	136.1
14:54	149	50.1	14.60	0.00	0.00	130.6
14:55	149	50.0	14.55	0.00	0.00	124.7
14:56	149	50.0	14.55	0.00	0.00	112.6
14:57	148	50.0	14.65	0.00	0.00	108.4
14:58	148	50.0	14.75	0.00	0.00	94.5
14:59	147	50.0	14.65	0.00	0.00	80.2
15:00	146	50.1	14.80	0.00	0.00	74.8
15:01	144	50.0	14.70	0.00	0.00	58.8
15:02	143	50.0	14.00	0.00	0.00	47.9
15:03	142	50.1	13.55	0.00	0.00	46.2
15:04	141	50.1	13.95	0.00	0.00	51.2
15:05	141	50.1	15.55	0.00	0.00	74.8
15:06	140	50.2	16.15	7.49	0.55	65.1
15:07	139	50.2	15.70	0.00	0.00	51.7



15:08	138	50.2	15.00	0.00	0.00	36.5
15:09	137	50.3	13.65	0.00	0.00	24.4
15:10	136	50.4	13.75	0.00	0.00	20.2
15:11	135	50.4	14.50	0.00	0.00	22.7
15:12	135	50.5	15.00	0.00	0.00	27.7
15:13	135	50.5	15.50	0.00	0.00	23.9
15:14	134	50.5	14.35	0.00	0.00	17.2
15:15	133	50.7	12.35	0.00	0.00	11.3
15:16	132	50.7	12.45	0.00	0.00	10.9
15:17	132	50.7	14.05	0.00	0.00	16.8
15:18	131	50.9	14.85	0.00	0.00	16.8
15:19	131	50.9	14.30	0.00	0.00	14.7
15:20	130	51.0	12.80	0.00	0.00	11.3
15:21	130	51.0	12.60	0.00	0.00	9.2
15:22	130	51.0	13.90	0.00	0.00	9.7
15:23	129	51.1	14.65	0.00	0.00	10.1
15:24	129	51.1	14.55	0.00	0.00	11.8
15:25	128	51.2	13.65	0.00	0.00	13.0
15:26	128	51.2	13.70	0.00	0.00	10.5
15:27	127	51.2	15.35	0.00	0.00	11.8
<hr/>						
Average	138	50.8	14.34	0.12	0.01	68.5

Average for first 30 mins of test	0.00	-
Average for second 30 mins of test	0.25	-
Average for first 60 mins of test	0.12	0.01



Coventry Cremators 1 & 2 Abatement System Outlet

Data Log

24/07/13

Test 12 - 3

Time	Flue Gas °C	Meter °C	Flue Oxygen %v/v dry	CO mg/Nm³ c.	VOC mg/Nm³ c.	Sample Point Pa
15:40	129	52.7	15.70	0.00	0.00	71.4
15:41	129	52.7	15.60	0.00	0.00	63.8
15:42	128	52.7	15.60	0.00	0.00	60.9
15:43	128	52.7	15.60	0.00	0.00	59.2
15:44	129	52.7	15.60	0.00	0.00	65.5
15:45	130	52.7	14.80	0.00	0.00	70.1
15:46	131	52.8	15.40	0.00	0.00	71.0
15:47	131	52.8	15.80	0.00	0.00	56.7
15:48	130	52.8	15.20	0.00	0.00	47.9
15:49	130	52.9	13.60	0.00	0.00	42.0
15:50	129	52.9	15.60	0.00	0.00	43.3
15:51	129	52.9	14.50	0.00	0.00	60.5
15:52	129	52.9	14.20	0.00	0.00	44.5
15:53	128	52.9	12.70	0.00	0.00	33.2
15:54	128	52.9	15.70	0.00	0.00	32.8
15:55	128	53.0	14.20	0.00	0.00	32.8
15:56	128	53.0	14.10	0.00	0.00	26.5
15:57	128	53.0	14.30	0.29	0.00	25.6
15:58	127	53.0	12.90	6.88	0.63	24.4
15:59	127	53.1	14.60	0.00	0.00	24.8
16:00	127	53.1	14.00	0.63	0.12	35.7
16:01	127	53.1	13.70	0.00	0.00	29.4
16:02	127	53.1	13.30	0.00	0.00	23.9
16:03	127	53.1	14.90	3.38	0.30	19.3
16:04	126	53.1	13.50	1.81	0.00	16.4
16:05	126	53.1	16.00	0.00	0.00	18.5
16:06	126	53.2	16.60	0.00	0.00	21.8
16:07	126	53.2	16.80	0.00	0.00	20.6
16:08	125	53.2	14.90	0.00	0.00	21.0
16:09	125	53.2	14.30	4.28	0.12	20.2
16:10	125	53.3	15.40	0.00	0.00	15.1
16:11	125	53.3	17.30	0.00	0.00	16.4
16:12	125	53.3	17.30	0.00	0.00	20.6
16:13	125	53.2	15.00	0.00	0.00	28.6
16:14	125	53.3	17.60	0.00	0.00	25.2
16:15	125	53.3	18.60	0.00	0.00	29.4
16:16	124	53.3	18.90	0.00	0.00	36.5
16:17	125	53.3	18.10	56.30	4.86	52.9
16:18	126	53.3	17.40	378.10	34.45	50.8
16:19	126	53.4	16.60	11.21	1.53	32.8
16:20	126	53.4	16.80	0.00	0.00	30.7



16:21	126	53.4	17.10	0.00	0.00	31.9
16:22	125	53.4	17.30	0.00	0.00	30.2
16:23	125	53.4	17.40	0.00	0.00	30.7
16:24	125	53.4	17.60	0.00	0.00	31.1
16:25	125	53.4	17.70	0.00	0.00	33.6
16:26	125	53.5	15.90	0.00	0.00	37.4
16:27	125	53.5	17.40	0.00	0.00	36.5
16:28	126	53.5	17.40	0.00	0.00	35.7
16:29	126	53.5	17.50	0.00	0.00	36.1
16:30	126	53.6	17.60	0.00	0.00	37.4
16:31	126	53.6	17.60	0.00	0.00	36.5
16:32	126	53.6	17.60	0.00	0.00	35.7
16:33	126	53.6	16.20	0.00	0.00	34.4
16:34	126	53.6	17.60	0.00	0.00	34.0
16:35	125	53.6	17.70	0.00	0.00	34.0
16:36	126	53.6	16.60	0.00	0.00	34.0
16:37	126	53.6	16.20	0.00	0.00	33.6
16:38	126	53.7	17.70	0.00	0.00	33.6
16:39	126	53.7	17.70	0.00	0.00	33.2
16:40	126	53.6	12.44	0.00	0.00	34.9
Average		127	53.2	15.95	7.59	0.69
						36.2

Average for first 30 mins of test	0.56	-
Average for second 30 mins of test	14.85	-
Average for first 60 mins of test	7.59	0.69



Coventry Cremators 1 & 2 Abatement System Outlet

Data Log

25/07/13

Test 12 - 4

<u>Time</u>	Flue Gas °C	Meter °C	Flue Oxygen %v/v dry	CO mg/Nm ³ c.	VOC mg/Nm ³ c.	Sample Point Pa
09:56	101	26.1	13.35	1.32	0.00	70.6
09:57	102	26.3	12.65	0.12	0.00	65.1
09:58	102	26.6	12.35	0.00	0.00	60.1
09:59	103	26.9	12.35	0.00	0.00	63.4
10:00	104	27.2	12.65	0.00	0.00	69.7
10:01	106	27.6	12.55	0.00	0.00	69.3
10:02	108	28.0	12.25	0.00	0.00	74.3
10:03	110	28.4	12.75	0.00	0.00	91.6
10:04	113	28.9	12.85	0.49	0.00	94.5
10:05	113	29.3	13.45	1.34	0.00	78.5
10:06	114	29.8	12.95	0.13	0.00	79.4
10:07	114	30.2	12.85	0.00	0.00	75.6
10:08	114	30.6	12.65	0.00	0.00	73.1
10:09	115	31.1	12.65	0.00	0.00	84.0
10:10	116	31.6	12.75	0.61	0.00	93.2
10:11	118	32.0	13.15	1.54	0.00	88.6
10:12	119	32.5	13.05	1.27	0.00	81.9
10:13	120	32.9	12.85	0.37	0.00	78.5
10:14	121	33.3	12.95	0.38	0.00	93.2
10:15	121	33.8	13.05	0.00	0.00	85.7
10:16	121	34.2	13.05	0.00	0.00	79.8
10:17	121	34.7	12.85	0.00	0.00	80.2
10:18	121	35.1	14.15	0.00	0.00	72.2
10:19	121	35.6	13.25	0.00	0.00	77.7
10:20	122	36.0	12.85	0.00	0.00	78.1
10:21	123	36.4	13.15	0.00	0.00	68.9
10:22	123	36.7	12.75	0.00	0.00	53.3
10:23	122	37.1	12.45	0.00	0.00	44.9
10:24	122	37.5	13.75	0.00	0.00	48.7
10:25	122	37.9	12.95	0.00	0.00	48.3
10:26	122	38.2	13.25	0.00	0.00	68.5
10:27	123	38.6	12.95	10.01	0.36	66.4
10:28	123	39.0	13.05	39.67	2.79	52.5
10:29	123	39.3	11.05	12.83	0.63	53.3
10:30	124	39.6	12.15	5.12	0.11	51.2
10:31	125	40.0	11.35	5.31	0.00	79.4
10:32	127	40.3	12.55	18.83	0.91	94.5
10:33	127	40.7	12.75	14.16	1.01	92.4
10:34	127	41.0	13.15	3.98	0.00	79.0
10:35	126	41.2	13.35	2.77	0.00	60.9
10:36	126	41.5	12.05	0.67	0.00	44.5



10:37	125	41.8	11.55	0.11	0.00	43.3
10:38	125	42.0	10.85	0.00	0.00	44.1
10:39	125	42.3	10.65	0.00	0.00	47.5
10:40	125	42.6	10.65	0.00	0.00	47.9
10:41	125	42.8	11.95	3.34	0.00	49.1
10:42	125	43.1	10.75	2.35	0.00	55.4
10:43	126	43.3	11.25	0.00	0.00	60.5
10:44	126	43.5	11.65	0.00	0.00	61.3
10:45	127	43.7	11.75	0.00	0.00	58.8
10:46	127	43.9	12.05	0.00	0.00	59.2
10:47	127	44.2	11.85	0.00	0.00	51.7
10:48	126	44.4	13.15	15.79	1.32	50.0
10:49	127	44.6	11.75	1.30	0.00	57.5
10:50	126	44.8	11.95	0.00	0.00	48.3
10:51	126	44.9	13.15	4.62	0.11	47.5
10:52	126	45.0	11.85	0.00	0.00	60.9
10:53	126	45.2	12.45	0.00	0.00	50.4
10:54	126	45.4	13.85	2.96	0.00	37.4
10:55	125	45.5	13.35	3.03	0.00	44.9
10:56	125	45.6	12.45	0.00	0.00	37.0
Average	120	37.3	12.52	2.53	0.12	65.2

Average for first 30 mins of test	0.24	-
Average for second 30 mins of test	4.90	-
Average for first 60 mins of test	2.53	0.12



Coventry Cremators 1 & 2 Abatement System Outlet

Total Particulate Matter and Hydrogen Chloride

Contract Coventry Crematorium, DEM0657
Date 24-25th July 2013
Location Cremators 1&2 Flue Gas Abatement System Outlet
Engineer(s) JB
Absorbent H₂O

Test Log	Test 12 - 2		Test 12 - 3		Test 12 - 4	
Barometric Pressure(kPa)	101.8		101.8		101.8	
Gas Meter Temperature(Deg C)	50.8		53.2		37.3	
Oxygen Concentration(%v/v dry)	14.34		15.95		12.52	
Flue Gas Volumetric Flow(Nm ³ /h dry)	2698		1986		2698	
Time	Start	End	Start	End	Start	End
Gas Meter Reading(Am ³ dry)	376.954	377.624	377.644	378.181	378.259	378.856
Absorber Weight(g)	3254.1	3294.2	3215.4	3247.8	3219.2	3255.1
Filter Reference	CO240713F1,2-2		CO240713F1,2-3		CO250713F1,2-4	
Filter Weight(g)	0.53915	0.53927	0.53355	0.53355	0.53818	0.53819
Probe Rinse Reference	CO240713R1&2		CO240713R1&2		CO250713R1&2	
Probe Rinse Weight(g)	77.6598	77.6599	77.6599	77.6599	77.6599	77.6599
Sample Reference HCl	CO240713H12-2		CO240713H12-3		CO250713H12-4 A&B	
Absorbent Volume(ml)	500		500		250	250
Absorbent(mg/l as HCl)	13		15		14	0.08
Blank(mg/l as HCl)	1.20		1.20		1.2	1.2

Calculation: General

Barometric Pressure(kPa)	101.8	101.8	101.8
Gas Meter temperature(Deg C)	50.8	53.2	37.3
Gas Volume Sampled(Am ³ dry)	0.670	0.537	0.597
Gas Volume Sampled(Nm ³ dry)	0.5677	0.4516	0.5279
Mass of Dry Gas(g @ 1292.8 g/Nm ³)	733.98	583.86	682.49
Change in Absorber Weight(g)	40.1	32.4	35.9
Water Vapour Volume(Nm ³ @ 803.9 g/Nm ³)	0.0499	0.0403	0.0447
Gas Volume(Nm ³ wet)	0.6176	0.4919	0.5726
Mass of Wet Gas(g)	774.08	616.26	718.39
Moisture Concentration(%v/v)	8.1	8.2	7.8
Moisture Concentration(%w/w)	5.2	5.3	5.0



Calculation: Particulate

Increase In Filter Weights(g)	0.00021	0.00000	0.00002
Particulate Emission(mg/Nm ³ dry)	0.37	0.00	0.03
Oxygen Concentration(%v/v dry)	14.34	15.95	12.52
Particulate Emission	0.56	0.00	0.04
(mg/Nm³ @ 11 %v/v Oxygen dry)			
Flue Gas Volumetric Flow(Nm ³ /h dry)	2698	1986	2698
Particulate Emission(g/h)	1.01	0.00	0.09
Required Sample Velocity(Nm/s)	7.79	5.73	7.79
Nozzle Used(mm)	5.0	5.0	5.0
Area of Nozzle(m ²)	0.00001963	0.00001963	0.00001963
Test Duration(mins)	60	60	60
Actual Sample Velocity(Nm/s)	8.03	6.39	7.47
Isokinetic Closure(%)	103	111	96
		103	

Calculation: HCl

Absorbent(mg/l as HCl)	13.00	15.00	14.08
Blank(mg/l as HCl)	1.2	1.2	1.2
Chloride Absorbed(mg/l as HCl)	11.8	13.8	12.88
Chloride Absorbed(mg as HCl)	5.90	6.90	3.22
HCl(mg)	5.90	6.90	3.22
HCl Emission(mg/Nm ³ dry)	10.39	15.28	6.10
Oxygen Concentration(%v/v dry)	14.34	15.95	12.52
HCl Emission	15.65	30.40	7.20
(mg/Nm³ @ 11 %v/v Oxygen dry)			
Flue Gas Volumetric Flow(Nm ³ /h dry)	2698	1986	2698
HCl Emission(g/h)	28.04	30.35	16.46



Coventry Cremators 1 & 2 Abatement System Outlet

Flue Gas Volumetric Flow

Contract Coventry Crematorium, DEM0657
Date 24-25th July 2013
Location Cremators 1&2 Flue Gas Abatement System Outlet
Engineer(s) JB

Test Log	Test 12 - 2	Test 12 - 3	Test 12 - 4
Flue Gas Temperature(Deg C)	138	127	120
Flue Gas Pitot Head Sample Points(Pa)	68.5	36.2	65.2
Flue Gas Pitot Head Duct Mean(Pa)	68.5	36.2	65.2
Flue Gas Moisture(%v/v)	8.1	8.2	7.8
Flue Gas Moisture(%w/w)	5.2	5.3	5.0
Flue Gas Duct Dimensions(mm)	350 mm Diameter Circular Stack		
Flue Gas Duct Area(m ²)	0.0962		

Calculation

Flue Gas Density(kg/m ³)	0.8417	0.8657	0.8805
Flue Gas Velocity(Am/s)	12.76	9.14	12.17
Flue Gas Volumetric Flowrate(Am ³ /h)	4419	3167	4215
Flue Gas Volumetric Flowrate(Am ³ /h dry)	4063	2907	3887
Flue Gas Volumetric Flowrate(Nm³/h dry)	2698	1986	2698



Coventry Cremators 1 & 2 Abatement System Outlet

Data Log

24/07/13

Test 12 - 1

Time -	Flue Gas °C	Meter °C	Flue O ₂ %v/v dry	Pitot Head Pa
10:46	118	26.6	10.20	37.4
10:47	118	26.8	10.60	37.0
10:48	118	27.0	10.00	44.1
10:49	119	27.4	8.20	50.0
10:50	120	27.9	11.30	55.9
10:51	121	28.4	12.70	62.2
10:52	122	29.0	14.60	82.7
10:53	123	29.5	12.70	81.1
10:54	123	30.0	11.90	69.7
10:55	123	30.5	15.30	71.8
10:56	123	31.1	13.80	76.0
10:57	123	31.6	12.30	76.4
10:58	123	32.1	12.40	73.9
10:59	124	32.6	14.30	86.9
11:00	126	33.1	13.70	100.0
11:01	127	33.6	13.00	99.5
11:02	128	34.0	13.90	99.5
11:03	128	34.4	14.40	88.6
11:04	128	34.9	13.30	101.6
11:05	128	35.4	13.10	98.7
11:06	128	35.8	14.60	93.7
11:07	128	36.3	12.70	104.6
11:08	128	36.7	11.00	96.6
11:09	129	37.1	11.60	83.6
11:10	128	37.5	12.10	70.6
11:11	128	37.8	11.90	70.1
11:12	128	38.2	10.50	61.3
11:13	128	38.6	11.50	65.5
11:14	128	38.9	10.80	73.5
11:15	129	39.3	13.00	101.6
11:16	129	39.6	11.80	74.8
11:17	128	39.9	11.20	55.0
11:18	128	40.2	10.90	48.7
11:19	128	40.5	10.70	47.5
11:20	128	40.8	11.00	53.8
11:21	128	41.1	11.80	54.6
11:22	128	41.3	12.20	57.5
11:23	128	41.6	13.30	60.5
11:24	129	41.9	14.80	92.4
11:25	129	42.1	12.90	70.1
11:26	128	42.4	11.50	65.5



11:27	129	42.7	13.10	78.1
11:28	129	43.0	11.50	73.1
11:29	130	43.2	13.10	84.8
11:30	130	43.4	11.70	76.0
11:31	130	43.7	12.30	79.0
11:32	131	43.9	12.90	97.0
11:33	132	44.1	13.60	102.5
11:34	131	44.2	12.30	83.2
11:35	131	44.4	12.50	81.9
11:36	131	44.6	13.50	91.6
11:37	131	44.8	13.80	75.6
11:38	130	45.0	12.50	53.8
11:39	129	45.2	11.90	44.5
11:40	129	45.4	12.00	52.9
11:41	129	45.5	11.30	50.8
11:42	129	45.6	12.90	50.0
11:43	128	45.7	12.30	39.1
11:44	129	45.9	12.70	48.7
11:45	129	46.0	12.30	49.1
11:46	129	46.2	12.70	56.7
11:47	129	46.3	13.30	63.8
11:48	129	46.5	13.50	64.7
11:49	129	46.6	13.70	62.6
11:50	129	46.7	14.00	64.7
11:51	129	46.8	15.90	71.8
11:52	128	46.9	16.90	53.3
11:53	128	47.0	16.00	40.7
11:54	127	47.2	12.40	32.3
11:55	127	47.3	11.20	37.0
11:56	127	47.5	12.50	31.5
11:57	127	47.5	12.50	31.5
11:58	127	47.6	11.70	37.8
11:59	127	47.7	15.00	38.2
12:00	127	47.6	12.60	36.5
12:01	127	47.7	14.00	38.2
12:02	126	47.8	14.60	31.1
12:03	126	47.7	11.70	42.0
12:04	126	47.7	12.80	39.1
12:05	127	47.7	12.20	45.8
12:06	128	47.7	13.60	55.4
12:07	129	47.7	14.00	77.3
12:08	129	47.7	15.20	77.7
12:09	128	47.6	14.40	57.5
12:10	128	47.5	13.90	47.0
12:11	127	47.5	13.80	44.5
12:12	128	47.6	15.00	80.2
12:13	130	47.6	16.20	119.3
12:14	131	47.7	15.40	96.6
12:15	131	47.7	15.60	81.5
12:16	132	47.7	12.20	81.1



12:17	131	47.6	12.80	60.5
12:18	130	47.7	11.50	47.0
12:19	129	47.7	12.00	41.6
12:20	129	47.8	11.10	42.0
12:21	129	47.8	12.40	53.8
12:22	129	47.8	10.80	54.6
12:23	129	47.8	12.10	55.9
12:24	130	47.8	11.90	56.3
12:25	131	47.8	11.50	71.4
12:26	132	47.7	14.00	107.9
12:27	133	47.7	12.80	105.8
12:28	132	47.8	12.40	80.6
12:29	132	47.8	11.50	71.8
12:30	132	47.9	13.70	82.3
12:31	132	47.9	14.10	86.5
12:32	132	48.0	12.70	84.4
12:33	132	48.0	13.00	68.0
12:34	131	48.0	13.00	65.1
12:35	131	48.0	12.00	59.6
12:36	130	48.0	12.50	48.7
12:37	130	48.0	11.10	47.5
12:38	129	48.0	12.10	37.0
12:39	129	48.0	10.40	43.3
12:40	129	48.0	12.00	37.8
12:41	129	48.0	11.20	45.8
12:42	129	48.1	11.80	44.5
12:43	130	48.1	13.50	63.0
12:44	130	48.0	13.10	75.2
12:45	130	48.0	13.10	57.5
12:46	129	48.0	13.50	42.8
12:47	129	48.0	14.90	53.3
12:48	129	48.0	15.40	65.9
12:49	128	48.1	16.30	52.9
12:50	128	48.1	14.60	49.6
12:51	130	48.2	14.20	89.9
12:52	132	48.2	14.90	81.9
12:53	131	48.3	14.90	55.4
12:54	130	48.4	14.50	42.8
12:55	130	48.4	14.50	40.3
12:56	129	48.4	13.90	42.0
12:57	129	48.5	13.50	47.5
12:58	129	48.6	14.20	49.6
12:59	129	48.5	14.10	47.5
13:00	130	48.6	13.90	66.8
13:01	131	48.6	14.60	77.7
13:02	132	48.6	14.90	77.7
13:03	132	48.6	14.10	79.0
13:04	133	48.7	14.40	82.7
13:05	133	48.7	14.60	84.4
13:06	133	48.7	14.80	86.1



13:07	133	48.7	14.50	86.1
13:08	134	48.7	15.90	87.4
13:09	134	48.8	16.30	99.5
13:10	134	48.8	16.50	105.4
13:11	134	48.9	16.60	101.2
13:12	134	48.9	16.60	97.9
13:13	134	48.9	16.20	97.4
13:14	134	48.9	16.40	101.6
13:15	133	49.0	15.40	96.2
13:16	133	49.0	16.50	86.9
13:17	133	49.0	16.80	91.6
13:18	133	49.0	16.90	92.8
13:19	132	49.0	15.80	88.6
13:20	132	49.1	16.10	77.7
13:21	131	49.1	16.00	74.3
13:22	131	49.0	17.10	81.9
13:23	132	49.0	17.40	90.7
13:24	132	49.0	16.20	83.6
13:25	131	49.0	16.10	62.6
13:26	130	49.0	14.00	52.9
13:27	129	49.1	14.90	34.0
13:28	128	49.1	12.50	23.9
13:29	128	49.1	15.40	18.5
13:30	127	49.0	19.90	22.3
13:31	128	49.1	13.70	22.3
13:32	127	49.0	13.20	17.2
13:33	127	49.0	13.40	22.3
13:34	127	49.0	14.00	24.4
13:35	126	49.0	15.80	37.4
13:36	126	49.0	17.00	47.5
13:37	127	49.1	15.70	56.7
13:38	127	49.1	16.20	41.6
13:39	127	49.2	16.50	51.7
13:40	128	49.3	14.00	59.6
13:41	128	49.3	12.80	46.6
13:42	127	49.4	14.00	32.3
13:43	127	49.4	13.90	42.8
13:44	126	49.5	15.50	33.6
13:45	126	49.6	16.10	34.9
13:46	126	49.7	13.40	50.4
13:47	127	49.8	12.50	50.0
13:48	127	49.8	13.60	40.3
13:49	127	49.9	10.40	39.5
13:50	127	50.0	12.90	32.3
13:51	127	50.0	12.70	49.6
13:52	128	50.1	13.30	67.6
13:53	127	50.1	12.70	58.4
13:54	127	50.2	12.80	57.5
13:55	127	50.3	12.20	44.5
13:56	127	50.4	11.90	54.6



13:57	127	50.4	12.10	48.3
13:58	128	50.5	13.00	58.0
13:59	128	50.6	13.10	47.5
14:00	128	50.6	12.90	39.9
14:01	128	50.7	13.20	54.6
14:02	129	50.7	14.00	60.5
14:03	129	50.8	14.30	69.7
14:04	128	50.9	14.60	58.0
14:05	128	51.0	14.20	47.0
14:06	127	51.0	13.60	38.2
14:07	127	51.1	13.80	35.7
14:08	127	51.1	13.80	46.6
14:09	128	51.2	14.90	45.4
14:10	128	51.3	14.30	40.7
14:11	129	51.4	15.10	53.3
14:12	128	51.4	15.30	41.6
14:13	128	51.5	15.30	53.3
<hr/>				
Average	129	45.6	13.53	62.3



Coventry Cremators 1 & 2 Abatement System Outlet

Mercury

Contract Coventry Crematorium, DEM0657
Date 24th July 2013
Location Cremators 1&2 Flue Gas Abatement System Outlet
Engineer(s) JB
Absorbent 4% K₂CR₂O₇ / 20% HNO₃ in H₂O

Test Log	Test 12 - 1	
Barometric Pressure(kPa)	101.8	
Gas Meter Temperature(Deg C)	45.6	
Oxygen Concentration(%v/v dry)	13.53	
Flue Gas Volumetric Flow(Nm ³ /h dry)	2542	
	Start	End
Time	10:46	14:13
Gas Meter Reading(Am ³ dry)	374.572	376.804
Absorber Weight(g)	3205.8	3387.4
Filter Reference	CO240713HgF12-1	
Filter Fraction Analysed	1	
Filter(µg as Hg)	0.05	
Filter Blank(µg as Hg)	0.01	
Probe Rinse Reference	Washed into Hg12-1A	
Probe Rinse Volume(ml)	0	
Probe Rinse(µg/l as Hg)	0	
Probe Rinse Blank(µg/l as Hg)	0	
Absorbent Reference	CO240713Hg12-1 A+B	
Absorbent Volume(ml)	300	250
Absorbent(µg/l as Hg)	29	0.5
Absorbent Blank(µg/l as Hg)	0.5	0.5

Calculation: General

Barometric Pressure(kPa)	101.8
Gas Meter Temperature(Deg C)	45.6
Gas Volume Sampled(Am^3 dry)	2.232
Gas Volume Sampled(Nm^3 dry)	1.9218
Mass of Dry Gas(g @ 1292.8 g/ Nm^3)	2484.45
Change in Absorber Weight(g)	181.6
Water Vapour Volume(Nm^3 @ 803.9 g/ Nm^3)	0.2259
Gas Volume(Nm^3 wet)	2.1477
Mass of Wet Gas(g)	2666.05
Moisture Concentration(%v/v)	10.5
Moisture Concentration(%w/w)	6.8

Calculation: Mercury

Filter(µg as Hg)	0.04
Probe Rinse(µg as Hg)	0.00
Absorbent(µg as Hg)	8.70
Total Mercury Sampled(µg)	8.74
Mercury Emission(µg/Nm ³ dry)	4.55
Oxygen Concentration(%v/v dry)	13.53
Mercury Emission (µg/Nm³ @ 11 %v/v Oxygen dry)	6.10
Flue Gas Volumetric Flowrate(Nm ³ /h dry)	2542
Mercury Emission(g/h)	0.012
Required Sample Velocity(Nm/s)	7.34
Nozzle Used(mm)	5.0
Area of Nozzle(m ²)	0.00001963
Test Duration(mins)	207
Actual Sample Velocity(Nm/s)	7.88
Isokinetic Closure(%)	107



Coventry Cremators 1 & 2 Abatement System Outlet

Flue Gas Volumetric Flow

Contract Coventry Crematorium, DEM0657
Date 24th July 2013
Location Cremators 1&2 Flue Gas Abatement System Outlet
Engineer(s) JB

Test Log	Test 12 - 1
----------	-------------

Flue Gas Temperature(Deg C)	129
Flue Gas Pitot Head Sample Points(Pa)	62.3
Flue Gas Moisture(%v/v)	10.5
Flue Gas Moisture(%w/w)	6.8
Flue Gas Duct Dimensions(mm)	350 mm Diameter Circular Stack
Flue Gas Duct Area(m ²)	0.0962

Calculation

Flue Gas Density(kg/m ³)	0.8562
Flue Gas Velocity(Am/s)	12.07
Flue Gas Volumetric Flowrate(Am ³ /h)	4179
Flue Gas Volumetric Flowrate(Am ³ /h dry)	3740
Flue Gas Volumetric Flowrate(Nm³/h dry)	2542



Coventry Cremators 3 & 4 Abatement System Outlet

Data Log

23/07/13


Test 34 - 1

Time	Flue Gas °C	Meter °C	Flue Oxygen %v/v dry	CO mg/Nm³ c.	VOC mg/Nm³ c.	Pitot Head Pa
08:37	80	25.3	18.25	12.49	0.00	122.2
08:38	81	25.5	17.10	5.24	0.00	118.4
08:39	82	25.8	15.65	16.21	0.00	119.7
08:40	82	26.1	14.95	2.60	0.00	102.9
08:41	83	26.5	14.55	0.64	0.00	100.8
08:42	85	26.9	14.80	7.60	0.00	154.1
08:43	87	27.3	15.60	12.81	0.00	197.4
08:44	88	27.8	15.90	10.85	0.00	168.0
08:45	88	28.3	15.75	6.38	0.00	173.0
08:46	88	28.8	15.65	6.06	0.00	175.6
08:47	88	29.3	15.50	5.95	0.00	187.7
08:48	89	29.9	15.45	4.66	0.00	198.7
08:49	91	30.4	15.45	4.38	0.00	225.1
08:50	93	30.9	15.45	3.59	0.00	257.0
08:51	95	31.4	15.60	2.92	0.00	310.4
08:52	96	31.9	15.75	3.98	0.00	306.6
08:53	96	32.3	15.85	2.51	0.00	246.5
08:54	96	32.8	15.85	1.38	0.00	256.2
08:55	96	33.2	15.80	1.35	0.00	289.8
08:56	96	33.7	15.80	2.51	0.00	257.0
08:57	96	34.1	16.20	1.74	0.00	237.7
08:58	95	34.6	16.20	3.43	0.00	177.2
08:59	95	35.0	15.70	1.74	0.00	186.5
09:00	96	35.5	16.00	1.12	0.00	248.2
09:01	96	35.8	16.50	1.97	0.00	201.6
09:02	95	36.3	16.10	3.43	0.00	149.5
09:03	94	36.6	15.55	1.12	0.00	177.2
09:04	95	37.0	15.75	0.00	0.00	216.7
09:05	95	37.4	16.05	0.60	0.00	192.4
09:06	94	37.8	15.75	1.03	0.00	150.8
09:07	94	38.1	15.50	0.00	0.00	196.6
09:08	96	38.5	15.65	0.00	0.00	260.0
09:09	97	38.8	15.80	0.00	0.00	260.0
09:10	97	39.1	15.90	0.00	0.00	239.0
09:11	97	39.4	16.00	0.00	0.00	254.9
09:12	97	39.8	16.05	0.00	0.00	232.7
09:13	97	40.1	16.35	0.00	0.00	211.3
09:14	95	40.4	16.35	0.00	0.00	160.4
09:15	93	40.7	14.90	0.00	0.00	137.3
09:16	93	41.0	14.50	0.00	0.00	158.3
09:17	94	41.2	15.75	0.00	0.00	189.8



09:18	95	41.6	16.25	0.00	0.00	153.3
09:19	94	41.9	15.70	0.21	0.00	105.8
09:20	93	42.1	14.80	0.17	0.00	93.7
09:21	93	42.3	14.50	0.00	0.00	129.8
09:22	94	42.6	14.95	0.00	0.00	187.7
09:23	94	42.8	15.45	0.00	0.00	202.0
09:24	94	43.1	15.55	0.00	0.00	176.4
09:25	95	43.3	15.35	0.00	0.00	163.4
09:26	94	43.5	15.10	0.00	0.00	144.9
09:27	94	43.8	14.95	0.00	0.00	136.1
09:28	94	44.0	14.90	0.00	0.00	128.9
09:29	93	44.2	15.10	0.00	0.00	113.0
09:30	92	44.5	15.05	0.00	0.00	111.7
09:31	91	44.6	14.45	0.00	0.00	100.8
09:32	92	44.8	14.10	0.00	0.00	76.0
09:33	92	45.1	14.30	0.00	0.00	84.0
09:34	92	45.3	14.70	0.31	0.00	72.2
09:35	92	45.4	14.95	1.15	0.00	70.6
09:36	92	45.6	14.70	1.17	0.00	77.3
09:37	91	45.8	15.35	0.76	0.00	67.2
Average		92	37.0	15.53	2.20	0.00

Average for first 30 mins of test	4.20	-
Average for second 30 mins of test	0.13	-
Average for first 60 mins of test	2.20	0.00



Coventry Cremators 3 & 4 Abatement System Outlet

Data Log

23/07/13

Test 34 - 2

Time -	Flue Gas °C	Meter °C	Flue Oxygen %v/v dry	CO mg/Nm ³ c.	VOC mg/Nm ³ c.	Sample Point Pa
09:53	96	48.8	16.50	7.16	0.00	164.2
09:54	96	48.9	16.80	4.02	0.00	144.1
09:55	95	49.0	16.81	5.27	0.00	104.6
09:56	96	49.1	17.10	33.24	1.53	143.6
09:57	96	49.2	16.60	61.51	2.63	152.9
09:58	96	49.2	17.00	68.85	3.47	142.0
09:59	95	49.3	17.40	59.45	4.21	138.6
10:00	95	49.4	16.20	42.04	1.93	157.9
10:01	96	49.5	17.00	35.61	2.18	174.3
10:02	96	49.6	17.20	50.63	2.04	192.8
10:03	98	49.7	17.30	80.93	4.90	210.4
10:04	99	49.8	17.70	65.70	4.41	226.0
10:05	99	49.9	18.30	71.95	4.08	209.6
10:06	97	50.0	17.50	68.71	4.43	151.6
10:07	97	50.1	17.20	37.78	0.57	168.8
10:08	97	50.2	17.90	36.62	1.75	219.7
10:09	96	50.3	18.00	59.05	2.85	173.0
10:10	96	50.5	17.10	52.95	1.93	128.5
10:11	96	50.7	16.60	22.48	0.00	151.6
10:12	98	50.7	17.40	21.73	0.00	208.7
10:13	98	50.8	18.60	28.03	0.37	228.9
10:14	97	50.9	18.10	37.26	0.00	159.2
10:15	95	51.0	16.80	31.77	0.00	117.2
10:16	96	51.1	16.70	18.22	0.00	175.6
10:17	97	51.1	16.90	17.79	0.00	198.2
10:18	98	51.2	17.50	61.91	4.00	246.1
10:19	100	51.2	18.50	51.05	2.42	254.5
10:20	99	51.3	16.80	45.89	0.99	184.4
10:21	98	51.4	17.80	22.30	0.27	152.9
10:22	98	51.5	17.30	11.06	0.00	168.0
10:23	98	51.5	16.90	24.26	0.00	225.5
10:24	99	51.6	16.60	40.29	1.16	276.4
10:25	99	51.6	17.30	24.93	0.31	236.5
10:26	99	51.7	17.40	13.90	0.00	218.0
10:27	100	51.7	17.00	8.97	0.00	236.0
10:28	100	51.8	16.80	5.54	0.00	252.8
10:29	99	51.9	17.50	4.08	0.00	217.1
10:30	98	52.0	17.50	2.88	0.00	179.3
10:31	97	52.1	16.60	1.73	0.00	160.9
10:32	97	52.2	16.90	0.46	0.00	176.0
10:33	97	52.2	17.50	0.49	0.00	136.9



10:34	97	52.2	17.60	0.58	0.00	131.9
10:35	97	52.2	16.70	1.19	0.00	149.1
10:36	97	52.3	17.20	0.47	0.00	146.6
10:37	96	52.3	18.00	0.53	0.00	117.6
10:38	95	52.4	17.70	1.01	0.00	111.7
10:39	95	52.4	18.70	0.61	0.00	124.7
10:40	95	52.4	16.10	80.04	2.52	127.3
10:41	96	52.5	17.90	10.05	0.00	188.2
10:42	99	52.5	17.80	556.55	53.28	262.1
10:43	98	52.5	15.40	544.57	42.34	189.8
10:44	98	52.5	16.80	11.29	0.00	155.0
10:45	97	52.6	15.90	12.95	0.00	132.7
10:46	97	52.6	16.40	8.87	0.00	168.8
10:47	97	52.6	17.10	4.15	0.00	163.4
10:48	96	52.6	17.10	3.62	0.00	159.6
10:49	97	52.6	16.60	5.94	0.00	144.5
10:50	98	52.7	14.90	6.18	0.00	186.1
10:51	99	52.7	15.90	5.76	0.00	217.1
10:52	99	52.6	16.00	7.68	0.00	191.9
10:53	98	52.6	12.44	3.22	0.00	171.8
<hr/>						
Average	97	51.2	17.03	42.68	2.47	177.1

Average for first 30 mins of test	39.85	-
Average for second 30 mins of test	45.62	-
Average for first 60 mins of test	42.68	2.47



Coventry Cremators 3 & 4 Abatement System Outlet

Data Log

23/07/13

Test 34 - 3

<u>Time</u>	Flue Gas °C	Meter °C	Flue Oxygen %v/v dry	CO mg/Nm ³ c.	VOC mg/Nm ³ c.	Sample Point Pa
11:24	97	52.6	16.75	20.14	0.32	164.6
11:25	97	52.4	16.55	8.23	0.00	157.9
11:26	97	52.3	16.75	5.03	0.00	160.4
11:27	96	52.2	17.05	5.43	0.00	160.9
11:28	97	52.0	16.55	4.57	0.00	176.0
11:29	97	51.9	16.85	3.44	0.00	154.1
11:30	98	51.9	16.45	20.57	0.32	198.7
11:31	99	51.8	16.05	39.39	2.47	197.4
11:32	98	51.7	17.05	25.33	0.33	189.8
11:33	98	51.7	17.55	15.74	0.00	177.7
11:34	97	51.8	17.35	6.73	0.00	164.2
11:35	97	51.7	17.55	5.94	0.00	150.4
11:36	96	51.6	17.35	5.61	0.00	135.2
11:37	97	51.6	17.25	9.00	0.00	160.9
11:38	98	51.4	17.55	14.55	0.00	176.0
11:39	99	51.3	17.45	10.38	0.00	202.4
11:40	98	51.4	16.85	12.53	0.00	160.4
11:41	97	51.3	17.55	19.90	0.00	154.1
11:42	96	51.3	17.75	18.95	0.00	139.0
11:43	96	51.3	17.65	18.37	0.00	135.7
11:44	96	51.3	16.45	11.40	0.00	121.8
11:45	96	51.4	17.35	11.77	0.00	131.0
11:46	97	51.4	17.35	10.37	0.00	157.1
11:47	98	51.3	17.35	9.25	0.00	197.4
11:48	98	51.3	16.95	4.53	0.00	166.3
11:49	97	51.2	17.55	1.19	0.00	171.4
11:50	97	51.2	17.65	1.22	0.00	205.8
11:51	97	51.2	17.05	0.00	0.00	206.6
11:52	97	51.1	17.15	0.00	0.00	159.6
11:53	97	51.1	17.55	0.00	0.00	149.5
11:54	98	51.1	17.45	0.00	0.00	174.3
11:55	97	51.1	16.85	0.00	0.00	149.5
11:56	96	51.1	17.85	0.00	0.00	115.1
11:57	95	51.2	17.95	0.00	0.00	125.2
11:58	95	51.3	16.95	0.00	0.00	118.9
11:59	95	51.4	17.65	0.00	0.00	92.0
12:00	94	51.4	18.35	0.00	0.00	94.5
12:01	95	51.4	17.75	0.00	0.00	103.3
12:02	95	51.5	17.75	0.00	0.00	90.3
12:03	95	51.5	19.05	0.00	0.00	94.1
12:04	94	51.6	18.75	0.00	0.00	100.8



12:05	94	51.6	17.85	0.00	0.00	106.7
12:06	93	51.6	19.25	0.00	0.00	94.5
12:07	94	51.7	18.85	0.00	0.00	146.2
12:08	96	51.7	16.85	0.00	0.00	155.8
12:09	95	51.8	18.25	0.00	0.00	110.9
12:10	95	51.9	19.25	0.00	0.00	125.6
12:11	96	52.0	17.95	0.00	0.00	178.9
12:12	96	52.0	18.35	0.00	0.00	162.1
12:13	95	52.0	18.65	0.00	0.00	135.2
12:14	95	52.2	18.75	0.00	0.00	152.0
12:15	95	52.2	18.15	0.00	0.00	148.3
12:16	96	52.3	18.75	0.00	0.00	152.5
12:17	96	52.3	18.45	0.00	0.00	150.8
12:18	97	52.4	17.65	0.00	0.00	146.2
12:19	96	52.4	18.75	0.00	0.00	118.4
12:20	96	52.4	18.05	0.00	0.00	177.2
12:21	96	52.5	17.45	0.00	0.00	171.4
12:22	96	52.5	17.35	0.00	0.00	158.3
12:23	96	52.5	17.25	0.00	0.00	156.2
12:24	97	52.6	17.25	0.00	0.00	156.2
Average	96	51.7	17.60	5.24	0.06	149.9

Average for first 30 mins of test	10.31	-
Average for second 30 mins of test	0.00	-
Average for first 60 mins of test	5.24	0.06



Coventry Cremators 3 & 4 Abatement System Outlet

Total Particulate Matter and Hydrogen Chloride

Contract Coventry Crematorium, DEM0657
Date 23rd July 2013
Location Cremators 3&4 Flue Gas Abatement System Outlet
Engineer(s) JB
Absorbent H₂O

Test Log	Test 34 - 1		Test 34 - 2		Test 34 - 3	
Barometric Pressure(kPa)	101.8		101.8		101.8	
Gas Meter Temperature(Deg C)	37.0		51.2		51.7	
Oxygen Concentration(%v/v dry)	15.53		17.03		17.60	
Flue Gas Volumetric Flow(Nm ³ /h dry)	4562		4676		4419	
Time	Start	End	Start	End	Start	End
Gas Meter Reading(Am ³ dry)	08:37	09:37	367.994	368.646	368.823	369.614
Absorber Weight(g)	3254.1	3294.2	3215.4	3247.8	3219.2	3235.1
Filter Reference	CO230713F3,4-1		CO230713F3,4-2		CO230713F3,4-3	
Filter Weight(g)	0.53702	0.53703	0.53545	0.53545	0.53691	0.53706
Probe Rinse Reference	CO230713R3&4		CO230713R3&4		CO230713R3&4	
Probe Rinse Weight(g)	76.2315	76.2315	76.2315	76.2315	76.2315	76.2315
Sample Reference HCl	CO230713H34-1		CO230713H34-2		CO230713H34-3 A&B	
Absorbent Volume(ml)	500		500		250	250
Absorbent(mg/l as HCl)	6.6		41		40	0.05
Blank(mg/l as HCl)	1.2		1.2		1.2	1.2

Calculation: General

Barometric Pressure(kPa)	101.8	101.8	101.8
Gas Meter temperature(Deg C)	37.0	51.2	51.7
Gas Volume Sampled(Am ³ dry)	0.652	0.791	0.786
Gas Volume Sampled(Nm ³ dry)	0.5770	0.6693	0.6641
Mass of Dry Gas(g @ 1292.8 g/Nm ³)	745.94	865.26	858.51
Change in Absorber Weight(g)	40.1	32.4	15.9
Water Vapour Volume(Nm ³ @ 803.9 g/Nm ³)	0.0499	0.0403	0.0198
Gas Volume(Nm ³ wet)	0.6269	0.7096	0.6839
Mass of Wet Gas(g)	786.04	897.66	874.41
Moisture Concentration(%v/v)	8.0	5.7	2.9
Moisture Concentration(%w/w)	5.1	3.6	1.8



Calculation: Particulate

Increase In Filter Weights(g)	0.00002	0.00000	0.00023
Particulate Emission(mg/Nm ³ dry)	0.03	0.00	0.35
Oxygen Concentration(%v/v dry)	15.53	17.03	17.60
Particulate Emission (mg/Nm³ @ 11 %v/v Oxygen dry)	0.05	0.00	1.05
Flue Gas Volumetric Flow(Nm ³ /h dry)	4562	4676	4419
Particulate Emission(g/h)	0.12	0.00	1.56
Required Sample Velocity(Nm/s)	13.17	13.50	12.76
Nozzle Used(mm)	4.0	4.0	4.0
Area of Nozzle(m ²)	0.00001257	0.00001257	0.00001257
Test Duration(mins)	60	60	60
Actual Sample Velocity(Nm/s)	12.75	14.79	14.68
Isokinetic Closure(%)	97	110	115
		107	

Calculation: HCl

Absorbent(mg/l as HCl)	6.60	41.00	40.05
Blank(mg/l as HCl)	1.2	1.2	1.2
Chloride Absorbed(mg/l as HCl)	5.4	39.8	38.85
Chloride Absorbed(mg as HCl)	2.70	19.90	9.71
HCl(mg)	2.70	19.90	9.71
HCl Emission(mg/Nm ³ dry)	4.68	29.73	14.63
Oxygen Concentration(%v/v dry)	15.53	17.03	17.60
HCl Emission (mg/Nm³ @ 11 %v/v Oxygen dry)	8.59	75.48	43.47
Flue Gas Volumetric Flow(Nm ³ /h dry)	4562	4676	4419
HCl Emission(g/h)	21.35	139.03	64.63



Coventry Cremators 3 & 4 Abatement System Outlet

Flue Gas Volumetric Flow

Contract Coventry Crematorium, DEM0657
Date 23rd July 2013
Location Cremators 3&4 Flue Gas Abatement System Outlet
Engineer(s) JB

Test Log	Test 34 - 1	Test 34 - 2	Test 34 - 3
Flue Gas Temperature(Deg C)	92	97	96
Flue Gas Pitot Head Sample Points(Pa)	173.8	177.1	149.9
Flue Gas Pitot Head Duct Mean(Pa)	173.8	177.1	149.9
Flue Gas Moisture(%v/v)	8.0	5.7	2.9
Flue Gas Moisture(%w/w)	5.1	3.6	1.8
Flue Gas Duct Dimensions(mm)	350 mm Diameter Circular Stack		
Flue Gas Duct Area(m ²)	0.0962		

Calculation

Flue Gas Density(kg/m ³)	0.9471	0.9404	0.9492
Flue Gas Velocity(Am/s)	19.16	19.41	17.77
Flue Gas Volumetric Flowrate(Am ³ /h)	6635	6722	6156
Flue Gas Volumetric Flowrate(Am ³ /h dry)	6107	6340	5978
Flue Gas Volumetric Flowrate(Nm³/h dry)	4562	4676	4419



Coventry Cremators 3 & 4 Abatement System Outlet

Data Log

23/07/13

Test 34-4

Time -	Flue Gas °C	Meter °C	Flue O ₂ %v/v dry	Pitot Head Pa
12:39	97	54.0	17.80	136.9
12:40	98	53.9	17.90	149.1
12:41	98	53.9	18.10	147.8
12:42	98	53.7	17.80	152.0
12:43	97	53.7	18.10	156.7
12:44	97	53.6	17.90	134.8
12:45	96	53.6	18.10	129.8
12:46	97	53.7	17.60	130.6
12:47	97	53.7	16.20	99.1
12:48	97	53.7	17.10	71.8
12:49	96	53.6	16.90	60.1
12:50	96	53.6	17.40	63.4
12:51	95	53.5	17.90	57.1
12:52	94	53.4	16.90	60.1
12:53	94	53.3	17.00	56.3
12:54	94	53.3	16.10	50.8
12:55	94	53.2	16.90	53.8
12:56	95	53.2	17.50	116.3
12:57	97	53.1	17.60	206.2
12:58	99	53.1	17.60	248.2
12:59	98	53.1	17.70	149.5
13:00	97	53.1	17.80	119.3
13:01	95	53.1	17.90	85.7
13:02	95	53.1	17.80	83.6
13:03	95	53.1	17.20	92.0
13:04	95	53.1	16.00	98.3
13:05	95	53.1	16.50	104.2
13:06	96	53.2	16.80	126.8
13:07	97	53.2	16.90	163.4
13:08	97	53.2	17.10	173.5
13:09	97	53.3	16.20	167.6
13:10	97	53.3	16.80	196.6
13:11	97	53.3	17.20	155.8
13:12	97	53.3	17.60	134.4
13:13	97	53.4	17.60	132.3
13:14	97	53.4	17.40	113.8
13:15	96	53.4	17.80	126.8
13:16	98	53.4	16.50	254.1
13:17	98	53.4	15.50	203.7
13:18	98	53.4	15.80	153.7
13:19	98	53.4	16.20	138.2



13:20	98	53.4	16.40	134.4
13:21	97	53.4	16.50	133.1
13:22	98	53.4	16.90	162.1
13:23	98	53.3	17.10	184.4
13:24	98	53.3	16.10	164.2
13:25	97	53.2	14.80	149.5
13:26	98	53.2	15.40	173.0
13:27	99	53.1	15.60	185.2
13:28	99	53.0	15.60	166.7
13:29	99	53.1	15.60	153.3
13:30	98	53.0	15.90	127.7
13:31	98	53.0	16.20	125.2
13:32	97	53.0	15.90	117.6
13:33	97	52.9	16.00	108.4
13:34	97	52.8	16.10	104.6
13:35	97	52.8	16.20	107.9
13:36	97	52.8	16.40	111.7
13:37	97	52.7	16.30	108.4
13:38	97	52.6	16.50	107.5
13:39	96	52.6	16.40	105.4
13:40	96	52.6	16.00	96.6
13:41	96	52.7	16.00	94.9
13:42	96	52.7	15.90	104.2
13:43	97	52.7	16.30	104.2
13:44	97	52.8	16.20	104.2
13:45	97	52.8	16.40	119.7
13:46	97	52.9	16.60	133.6
13:47	97	53.0	16.80	115.9
13:48	96	53.0	16.50	115.1
13:49	97	53.0	16.40	147.8
13:50	97	53.0	17.10	126.4
13:51	97	53.1	17.00	111.7
13:52	97	53.1	16.50	111.7
13:53	98	53.1	16.40	166.7
13:54	98	53.2	17.30	157.1
13:55	97	53.2	17.50	110.9
13:56	96	53.2	16.60	102.5
13:57	97	53.2	16.40	127.3
13:58	97	53.2	17.50	97.9
13:59	96	53.2	17.40	72.2
14:00	96	53.2	16.30	88.2
14:01	97	53.3	16.90	131.9
14:02	96	53.3	18.00	98.7
14:03	95	53.3	17.50	73.5
14:04	95	53.4	16.70	101.2
14:05	96	53.4	17.00	125.6
14:06	97	53.4	17.60	92.4
14:07	96	53.4	17.70	77.3
14:08	96	53.3	17.30	91.1
14:09	97	53.3	17.50	138.2



14:10	97	53.4	18.10	128.9
14:11	96	53.4	18.40	95.3
14:12	96	53.4	17.90	86.9
14:13	96	53.4	17.80	109.6
14:14	97	53.4	17.90	108.8
14:15	97	53.4	17.90	90.3
14:16	96	53.4	16.80	81.1
14:17	97	53.4	16.60	115.5
14:18	97	53.4	16.80	127.7
14:19	97	53.4	16.80	127.7
14:20	97	53.4	17.50	114.2
14:21	96	53.4	18.60	76.0
14:22	96	53.5	16.70	67.6
14:23	97	53.4	16.80	98.3
14:24	97	53.4	17.00	110.5
14:25	97	53.4	17.10	118.9
14:26	97	53.4	17.10	118.0
14:27	96	53.5	17.10	108.8
14:28	97	53.5	17.30	124.7
14:29	97	53.5	17.90	97.9
14:30	96	53.4	18.20	96.2
14:31	97	53.4	17.10	124.3
14:32	98	53.4	17.90	154.1
14:33	97	53.4	18.30	137.3
14:34	97	53.4	18.20	115.5
14:35	96	53.4	18.40	98.3
14:36	96	53.4	18.00	94.5
14:37	97	53.5	18.10	128.9
14:38	97	53.4	18.10	121.8
14:39	98	53.4	17.70	124.3
14:40	98	53.4	16.90	153.3
14:41	99	53.4	17.30	184.4
14:42	98	53.3	16.80	156.2
14:43	98	53.4	16.50	170.1
14:44	98	53.4	16.60	160.4
14:45	99	53.5	16.70	156.2
14:46	99	53.5	16.70	169.3
14:47	100	53.5	16.90	179.8
14:48	100	53.4	18.40	197.8
14:49	100	53.5	18.30	209.2
14:50	99	53.4	16.80	149.9
14:51	98	53.5	17.30	138.2
14:52	100	53.6	16.40	237.7
14:53	101	53.6	15.10	208.7
14:54	101	53.7	15.40	181.0
14:55	101	53.7	16.00	188.2
14:56	102	53.7	16.10	204.5
14:57	102	53.7	15.90	203.7
14:58	102	53.7	15.30	184.8
14:59	102	53.7	15.40	235.2



15:00	104	53.7	15.30	273.4
15:01	104	53.8	15.50	275.1
15:02	105	53.9	15.90	263.8
15:03	104	53.8	16.00	230.6
15:04	105	53.8	16.00	262.9
15:05	105	53.8	16.20	246.5
15:06	105	53.8	16.10	209.6
15:07	104	53.8	15.90	178.5
15:08	103	53.8	15.70	147.4
15:09	102	53.8	15.80	139.9
15:10	102	53.8	15.90	140.3
15:11	102	53.8	16.20	140.3
15:12	101	53.8	16.40	137.8
15:13	101	53.9	16.50	124.7
15:14	100	53.9	16.70	121.4
15:15	100	53.8	16.70	113.0
15:16	99	53.9	16.70	102.5
15:17	99	53.9	16.60	105.4
15:18	99	53.9	16.60	108.8
15:19	99	53.9	15.90	130.6
15:20	101	53.9	16.50	187.3
15:21	102	53.9	16.70	212.9
15:22	102	53.9	16.80	205.8
15:23	102	53.9	17.00	202.4
15:24	102	54.0	17.00	198.7
15:25	102	54.0	17.10	191.1
15:26	102	54.0	17.00	176.4
15:27	101	54.1	17.10	149.1
15:28	100	54.1	17.10	145.7
15:29	100	54.1	17.20	142.0
15:30	99	54.1	17.30	119.3
15:31	99	54.1	17.10	105.0
15:32	99	54.1	17.30	95.8
15:33	99	54.1	17.30	102.9
15:34	99	54.1	17.40	108.8
15:35	99	54.2	17.40	111.3
15:36	98	54.1	17.40	105.8
15:37	98	54.1	17.40	106.3
15:38	98	54.1	17.40	92.8
15:39	98	54.1	17.90	90.3
15:40	97	54.1	17.60	60.5
15:41	97	54.1	17.20	34.0
15:42	97	54.2	18.10	52.1
15:43	96	54.2	16.20	40.3
15:44	96	54.2	17.20	21.8
15:45	95	54.2	17.00	9.2
15:46	95	54.2	16.90	4.2
15:47	94	54.2	17.10	4.2
15:48	94	54.1	17.30	6.3
15:49	94	54.1	17.70	9.2



15:50	94	54.1	18.10	14.3
15:51	94	54.1	16.70	63.0
15:52	96	54.1	16.00	106.7
15:53	97	54.2	17.00	128.1
15:54	98	54.1	17.60	135.2
15:55	97	54.1	17.60	121.8
15:56	97	54.0	17.60	118.9
15:57	97	54.0	17.60	110.0
15:58	96	54.0	17.10	118.4
15:59	97	54.0	17.00	154.6
16:00	99	54.0	16.90	198.7
16:01	101	54.0	17.50	203.3
16:02	101	53.9	17.40	184.4
16:03	101	53.9	17.50	183.5
16:04	101	53.9	17.50	181.9
16:05	101	53.9	17.60	192.8
16:06	101	53.8	17.60	192.4
16:07	101	53.8	17.00	206.2
16:08	102	53.8	17.20	248.6
16:09	103	53.9	17.40	256.2
16:10	103	53.9	17.50	255.4
16:11	103	53.9	16.90	258.7
16:12	104	53.9	17.20	257.9
16:13	104	53.9	17.40	250.7
16:14	104	53.9	17.50	246.5
16:15	104	53.8	16.70	227.6
16:16	104	53.8	17.40	249.9
16:17	104	53.8	17.90	244.9
16:18	104	53.8	17.10	208.7
16:19	104	53.8	17.80	245.3
16:20	104	53.8	18.90	206.2
16:21	102	53.8	18.10	134.8
16:22	101	53.7	17.50	132.7
16:23	102	53.7	18.00	186.5
16:24	102	53.8	19.00	178.1
16:25	100	53.8	18.40	115.9
16:26	99	53.8	17.80	77.7
16:27	99	53.7	17.50	109.2
16:28	100	53.7	17.40	158.3
16:29	102	53.7	18.20	193.6
16:30	102	53.7	18.40	138.6
16:31	100	53.7	17.80	84.0
16:32	100	53.7	17.70	112.1
16:33	101	53.7	17.70	171.8
16:34	102	53.7	17.10	209.6
16:35	102	53.7	17.50	228.9
16:36	101	53.7	18.00	160.9
16:37	100	53.7	18.00	120.5
16:38	99	53.7	17.80	118.0
16:39	99	53.7	16.90	139.4



16:40	99	53.8	17.90	103.7
16:41	98	53.9	18.30	86.1
16:42	98	54.0	18.60	89.0
16:43	98	53.9	17.60	105.0
16:44	98	53.9	18.40	105.8
16:45	98	53.9	19.00	93.2
16:46	97	54.0	18.90	76.0
16:47	97	54.0	18.80	71.0
16:48	98	54.0	19.20	118.0
16:49	98	54.0	17.50	86.1
16:50	98	54.0	17.60	84.8
16:51	98	53.9	17.20	71.4
Average	98	53.6	17.10	136.2



Coventry Cremators 3 & 4 Abatement System Outlet

Mercury

Contract Coventry Crematorium, DEM0657
Date 23rd July 2013
Location Cremators 3&4 Flue Gas Abatement System Outlet
Engineer(s) JB
Absorbent 4% K₂Cr₂O₇ / 20% HNO₃ in H₂O

Test Log Test 34-4

Barometric Pressure(kPa)	101.8
Gas Meter Temperature(Deg C)	53.6
Oxygen Concentration(%v/v dry)	17.10
Flue Gas Volumetric Flow(Nm ³ /h dry)	3983

Time	Start	End
Gas Meter Reading(Am ³ dry)	371.224	374.424
Absorber Weight(g)	3254.8	3457.5
Filter Reference	CO230713HgF34-4	
Filter Fraction Analysed	1	
Filter(µg as Hg)	0.78	
Filter Blank(µg as Hg)	0.01	
Probe Rinse Reference	Washed into Hg4A	
Probe Rinse Volume(ml)	0	
Probe Rinse(µg/l as Hg)	0	
Probe Rinse Blank(µg/l as Hg)	0	
Absorbent Reference	CO230713Hg34-4 A+B	
Absorbent Volume(ml)	300	250
Absorbent(µg/l as Hg)	10	1.1
Absorbent Blank(µg/l as Hg)	0.5	0.5

Calculation: General

Barometric Pressure(kPa)	101.8
Gas Meter Temperature(Deg C)	53.6
Gas Volume Sampled(Am ³ dry)	3.200
Gas Volume Sampled(Nm ³ dry)	2.6882
Mass of Dry Gas(g @ 1292.8 g/Nm ³)	3475.34
Change in Absorber Weight(g)	202.7
Water Vapour Volume(Nm ³ @ 803.9 g/Nm ³)	0.2521
Gas Volume(Nm ³ wet)	2.9404
Mass of Wet Gas(g)	3678.04
Moisture Concentration(%v/v)	8.6
Moisture Concentration(%w/w)	5.5



Calculation: Mercury

Filter(µg as Hg)	0.77
Probe Rinse(µg as Hg)	0.00
Absorbent(µg as Hg)	3.18
Total Mercury Sampled(µg)	3.95
Mercury Emission(µg/Nm ³ dry)	1.47
Oxygen Concentration(%v/v dry)	17.10
Mercury Emission (µg/Nm³ @ 11 %v/v Oxygen dry)	3.79
Flue Gas Volumetric Flowrate(Nm ³ /h dry)	3983
Mercury Emission(g/h)	0.006
Required Sample Velocity(Nm/s)	11.50
Nozzle Used(mm)	4.5
Area of Nozzle(m ²)	0.00001590
Test Duration(mins)	252
Actual Sample Velocity(Nm/s)	11.18
Isokinetic Closure(%)	97



Coventry Cremators 3 & 4 Abatement System Outlet

Flue Gas Volumetric Flow

Contract Coventry Crematorium, DEM0657
Date 23rd July 2013
Location Cremators 3&4 Flue Gas Abatement System Outlet
Engineer(s) JB

Test Log	Test 34-4
----------	-----------

Flue Gas Temperature(Deg C)	98
Flue Gas Pitot Head Sample Points(Pa)	136.2
Flue Gas Moisture(%v/v)	8.6
Flue Gas Moisture(%w/w)	5.5
Flue Gas Duct Dimensions(mm)	350 mm Diameter Circular Stack
Flue Gas Duct Area(m ²)	0.0962

Calculation

Flue Gas Density(kg/m ³)	0.9305
Flue Gas Velocity(Am/s)	17.11
Flue Gas Volumetric Flowrate(Am ³ /h)	5927
Flue Gas Volumetric Flowrate(Am ³ /h dry)	5419
Flue Gas Volumetric Flowrate(Nm³/h dry)	3983



APPENDIX 2

Analysis Reports





Scientific Analysis Laboratories Ltd

Certificate of Analysis

Scientific Analysis Laboratories is a limited company registered in England and Wales (No 2514788) whose address is at Hadfield House, Hadfield Street, Manchester M16 9FE

Hadfield House
Hadfield Street
Cornbrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: 342734-1

Date of Report: 07-Aug-2013

Customer: Davies & Co (Engineering)
PO Box 11
Moor Road
Leeds
LS10 2DD

Customer Contact: Mr Steve Atherton

Customer Job Reference: DEM0657
Customer Purchase Order: 50000780
Date Job Received at SAL: 30-Jul-2013
Date Analysis Started: 31-Jul-2013
Date Analysis Completed: 07-Aug-2013

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs
All results have been reviewed in accordance with QP22



Report checked
and authorised by :
Kayleigh McCann
Project Manager

Issued by :
Kayleigh McCann
Project Manager

Validity unknown
Digitally signed by Kayleigh
McCann
Date: 2013-08-07 17:02:51 BST
Reason: Issue
Location: SAL

Page 1 of 2



SAL Reference:	342734						
Customer Reference:	DEM0657						
Filter	Analysed as Filter						
Miscellaneous							
Determinand							
SAL Reference	342734 010						
Customer Sample Reference	CO230713 HgF34-4						
Test Sample	AR						
Method	LOD						
Units	Symbol						
Mercury	CVAFS (HF Digest BS EN 13211)	0.01	µg	U	(195) 0.78	<0.01	0.05


SAL Reference:	342734								
Customer Reference:	DEM0657								
Impinger (4%K2Cr2O7/20%HNO3)	Analysed as Impinger (4%K2Cr2O7/20%HNO3)								
Miscellaneous									
Determinand									
SAL Reference	342734 013								
Customer Sample Reference	CO230713 Hg34-4A								
Test Sample	AR								
Method	LOD								
Units	Symbol								
Mercury	CVAFS (BS EN 13211)	0.5	µg/l	U	(195) 10	1.1	<0.5	(195) 29	<0.5

SAL Reference:	342734								
Customer Reference:	DEM0657								
Impinger(DI water)	Analysed as Impinger(DI water)								
Miscellaneous									
Determinand									
SAL Reference	342734 001								
Customer Sample Reference	CO230713 H34-1								
Test Sample	AR								
Method	LOD								
Units	Symbol								
Hydrogen Chloride	IC	0.05	mg/l	U	(13) 6.6	(13) 41	(13) 40	(13) <0.05	(13) 1.2

SAL Reference:	342734							
Customer Reference:	DEM0657							
Impinger(DI water)	Analysed as Impinger(DI water)							
Miscellaneous								
Determinand								
SAL Reference	342734 006							
Customer Sample Reference	CO240713 H12-2							
Test Sample	AR							
Method	LOD							
Units	Symbol							
Hydrogen Chloride	IC	0.05	mg/l	U	(13) 13	(13) 15	(13) 14	(13) 0.08

Index to symbols used in 342734-1

Value	Description
AR	As Received
13	Results have been blank corrected.
195	Due to levels found in the sample that are outside of the normal calibration range of the instrument, analysis was conducted on a diluted sample
U	Analysis is UKAS accredited





Particulate Weight Determination - Cremator 1&2 Abatement System

Filter / Rinse Reference		Clean Dry Weight g	Dirty Dry Weight g
CO240713FOB	3	0.5378	0.5378
CO240713F1,2-2	H4	0.53915	0.53927
CO240713F1,2-3	H5	0.53355	0.53355
CO250713F1,2-4	H6	0.53818	0.53819
CO240713ROB		77.36582	77.36482
CO240713R1&2	1	77.65984	77.65993
CO240713R1&2	2	77.65993	77.65993
CO250713R1&2	3	77.65993	77.65994

Particulate Weight Determination

Filter / Rinse Reference		Clean Dry Weight g	Dirty Dry Weight g
CO230713FOB	5	0.5416	0.5416
CO230713F3,4-1	H1	0.53702	0.53703
CO230713F3,4-2	H2	0.53545	0.53545
CO230713F3,4-3	H3	0.53691	0.53706
CO230713ROB		77.25641	77.25641
CO230713R3&4	1	76.23145	76.23146
CO230713R3&4	2	76.23146	76.23146
CO230713R3&4	3	76.23146	76.23154




APPENDIX 3


Details of Plant Operation During Testing



Coventry Crematorium Cremators 3 & 4
Emission Tests 23/07/2013
Plant Operation & Test Periods



Coventry Crematorium Cremators 1 & 2
Emission Tests 24/07/2013
Plant Operation & Test Periods



Coventry Crematorium Cremators 1 & 2
Emission Tests 25/07/2013
Plant Operation & Test Periods

