



Exova Catalyst, Unit C6, Emery Court, The Embankment Business Park, Heaton Mersey, Stockport, SK4 3GL
E: toby.campbell@exova.com
Your Exova Catalyst Contact: Toby Campbell (07825 130 074)

Stack Emissions Testing Report Commissioned by
Air Tech Environmental Consultancy Services

Installation Name & Address
Federal Mogul Sintered Products Ltd
Holbrook Lane
Holbrooks
Coventry
CV6 4BG

PPC Permit: PPC/197

Stack Reference
Main Stack

Dates of the Monitoring Campaign
13th September 2018

Job Reference Number
CAT-4402

Report Written by
Ian Baggley Team Leader MCERTS Level 2 MM 05 653 TE1 TE2 TE3 TE4

Report Approved by
Matthew Pendlebury Team Leader MCERTS Level 2 MM 04 535 TE1 TE2 TE3 TE4

Report Date
19th October 2018

Version
Version 4

Signature of Report Approver

CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Objectives	3
Monitoring Results	4
Monitoring Dates & Times	5
Process Details	6
Monitoring & Analytical Methods	7
Summary of Sampling Deviations	7
Sampling Location	8
Plant Photos / Sample Points	9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

Opinions and interpretations expressed herein are outside the scope of Exova Catalyst's ISO 17025 accreditation.

This test report shall not be reproduced, except in full, without the written approval of Exova Catalyst.

This version of the test report supersedes the previous version of the test report. Please destroy all previous versions to ensure no confusion arises from having multiple test reports in existence.



Executive Summary

(Page 1 of 7)

MONITORING OBJECTIVES

Federal Mogul Sintered Products Ltd, Coventry
Main Stack
13th September 2018

Overall Aim of the Monitoring Campaign

Exova Catalyst, in partnership with Air Tech Environmental Consultancy Services, were commissioned to carry out stack emissions testing on the Main Stack by Federal Mogul Sintered Products Ltd at Coventry.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

Special Requirements

There were no special requirements.

Target Parameters

Total Particulate Matter, Heavy Metals

Executive Summary

(Page 2 of 7)

MONITORING RESULTS

Federal Mogul Sintered Products Ltd, Coventry

Main Stack

13th September 2018

where MU = Measurement Uncertainty associated with the Result

Parameter	Concentration				Mass Emission			
	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Total Particulate Matter ¹	mg/m ³	0.22	0.65	20	g/hr	0.89	2.56	-
Heavy Metals ¹	mg/m ³	0.04	0.01	5	g/hr	0.14	0.05	-
Water Vapour	% v/v	0.91	0.06					
Stack Gas Temperature	°C	31.5						
Stack Gas Velocity	m/s	19.2	3.19					
Volumetric Flow Rate (ACTUAL)	m ³ /hr	4256	733					
Volumetric Flow Rate (REF) ¹	m ³ /hr	3949	680					

NOTE: VOLUMETRIC FLOW RATE & VELOCITY DATA TAKEN FROM THE PRELIMINARY VELOCITY TRAVERSE.

¹ Reference Conditions (REF) are: 273K, 101.3kPa, without correction for water vapour content.

Executive Summary

(Page 3 of 7)

MONITORING DATE(S) & TIMES

Federal Mogul Sintered Products Ltd, Coventry

Main Stack

13th September 2018

Parameter	Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins	
Total Particulate Matter	R1	mg/m ³	0.22	g/hr	0.89	13/09/2018	10:06 - 11:06	60
Heavy Metals	R1	mg/m ³	0.04	g/hr	0.14	13/09/2018	11:17 - 12:17	60
Velocity Traverse	R1					13/09/2018	09:55 - 10:01	

All results are expressed at the respective reference conditions.

Executive Summary

(Page 4 of 7)

PROCESS DETAILS

Federal Mogul Sintered Products Ltd, Coventry

Main Stack

13th September 2018

Standard Operating Conditions

Parameter	Value
Process Status	Normal Operation
Capacity (of 100%) and Tonnes / Hour	Standard Operating Capacity
Continuous or Batch Process	Induction Furnace and Mill Extraction
Feedstock (if applicable)	Aluminium Scrap
Abatement System	Bag Filter
Abatement System Running Status	On
Fuel	NA
Plume Appearance	None Visible

Executive Summary

(Page 5 of 7)

MONITORING & ANALYTICAL METHODS

Federal Mogul Sintered Products Ltd, Coventry

Main Stack

13th September 2018

Parameter	Monitoring				Analysis				MCERTS Testing	LOD (Average)
	Standard	Technical Procedure	ISO 17025 Testing	Testing Lab	Analytical Procedure	Analytical Technique	ISO 17025 Analysis	Analysis Lab		
Total Particulate Matter	EN 13284-1	CAT-TP-01	Yes	CAT	CAT-TP-03	Gravimetric	Yes	CAT	Yes	0.15 mg/m ³
Heavy Metals	EN 14385	CAT-TP-06	Yes	CAT	Section 21	ICP-MS	Yes	CLS	Yes	0.01 mg/m ³
Water Vapour	EN 14790	CAT-TP-05	Yes	CAT	CAT-TP-05	Gravimetric	Yes	CAT	Yes	0.10 % v/v
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41	Yes	CAT	Pitot Tube and Thermocouple				Yes	1.8 m/s

ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Exova Catalyst (CAT)	ISO 17025 Accreditation Number: 4279
Concept Life Sciences Ltd (CLS)	ISO 17025 Accreditation Number: 1549

SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
Total Particulate Matter, Velocity & Vol. Flow Rate	1	In order to maintain isokinetic sampling, a nozzle size smaller than that specified in the Standard was used.

Executive Summary

(Page 6 of 7)

SUITABILITY OF SAMPLING LOCATION

Duct Characteristics

Parameter	Units	Value
Type	-	Circular
Depth	m	0.28
Width	m	-
Area	m ²	0.06
Port Depth	cm	9
Orientation of Duct	-	Vertical
Number of Ports	-	2
Sample Port Size	-	4" BSP

Location of Sampling Platform

General Platform Information	Value
Permanent / Temporary Platform	Permanent
Inside / Outside	Outside

Platform Details

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	Yes
Platform has vertical base boards (approx. 0.25m high)	Yes
Platform has chains / self closing gates at top of ladders	Yes
There are no obstructions present which hamper insertion of sampling equipment	Yes
Safe Access Available	Yes
Easy Access Available	Yes

Sampling Location / Platform Improvement Recommendations

The sampling location meets all the requirements specified in EA Guidance Note M1 and EN 15259, and therefore there are no improvement recommendations.

EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

Sampling Plane Validation Criteria (from EN 15259)


Criteria in EN 15259	Units	Traverse 1	Required	Compliant
Lowest Differential Pressure	Pa	314	> 5 Pa	Yes
Mean Velocity	m/s	19.20	-	-
Lowest Gas Velocity	m/s	19.20	-	-
Highest Gas Velocity	m/s	19.20	-	-
Ratio of Above	: 1	1.00	< 3 : 1	Yes
Maximum Angle of Swirl	°	0	< 15°	Yes
No Local Negative Flow	-	Yes	-	Yes

Executive Summary


(Page 7 of 7)

PLANT PHOTOS / DIAGRAMS

①



SAMPLE POINTS



- where
- = isokinetic point sampled at
 - = isokinetic point not sampled at
 - = combustion gases sample point
 - = non-isokinetic sample point



APPENDICES

APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

STACK EMISSIONS MONITORING PERSONNEL

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	Ian Baggley	MCERTS Level 2	MM 05 653	TE1 TE2 TE3 TE4
Technician	Sean Kinahan	MCERTS Trainee	MM 18 1471	None

LIST OF EQUIPMENT

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	CAT 7.5	Horiba PG-250	-	Digital Manometer (1)	CAT 3.124
Control Box DGM (2)	-	Horiba PG-350E	-	Digital Manometer (2)	-
Box Thermocouples (1)	CAT 3.12	Servomex 5200 MP	-	Digital Temperature Meter	CAT 3.124
Box Thermocouples (2)	-	Eco Physics CLD 822Mh	-	Stopwatch	-
Umbilical (1)	CAT 3.12	ABB AO2020-URAS26	-	Barometer	CAT 13.29
Umbilical (2)	-	Testo 350 XL	-	Stack Thermocouple (1)	CAT 4.1064
Oven Box (1)	CAT 12.36	JCT JCC P1 Cooler	-	Stack Thermocouple (2)	CAT 4.1202
Oven Box (2)	-	Gasmet DX4000	-	Stack Thermocouple (3)	-
Heated Probe (1)	CAT 5.19	Gasmet Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	CAT 5.20	Bernath 3006 FID	-	1m Heated Line (2)	-
Heated Probe (3)	-	M&C PSS	-	1m Heated Line (3)	-
S-Pitot (1)	CAT 21P.79	Mass Flow Controller (1)	-	5m Heated Line (1)	-
S-Pitot (2)	CAT 21.P20	Mass Flow Controller (2)	-	15m Heated Line (1)	-
L-Pitot	-	Mass View (1)	-	20m Heated Line (1)	-
Site Balance	CAT 17.20	Mass View (2)	-	20m Heated Line (2)	-
500g / 1Kg Check Weights	CAT 17.20	Hioki 5043 (V)	-	Dual Channel Heater Controller	CAT 3.18
Last Impinger Arm	-	Easylogger EN-EL-12 Bit	-	Single Channel Heater Controller	-
Callipers	CAT 23.7	Bioaerosols Temperature Logger	-	Laboratory Balance	CAT 1.18 / 1.18a
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.26

METHODS & TECHNICAL PROCEDURES USED

Parameter	Standard	Technical Procedure
Total Particulate Matter	EN 13284-1	CAT-TP-01
Water Vapour	EN 14790	CAT-TP-05
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41

PRELIMINARY STACK SURVEY: CALCULATIONS

General Stack Details

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	0.28
Stack Width, W	m	-
Stack Area, A	m ²	0.06
Average Stack Gas Temperature, T _a	°C	21.0
Average Stack Gas Pressure	mmH ₂ O	32.0
Average Stack Static Pressure, P _{static}	kPa	0.21
Average Barometric Pressure, P _b	kPa	101.0
Average Pitot Tube Calibration Coefficient, C _p	-	0.84

Stack Gas Composition & Molecular Weights

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m ³ ρ	Conc kg/m ³ p _i
CO ₂ (Estimated)	-	1.50	1.49	0.0150	44.01	1.9635	0.0295
O ₂ (Estimated)	-	19.00	18.83	0.1900	32.00	1.4277	0.2713
N ₂	-	79.50	78.78	0.7950	28.01	1.2498	0.9936
Moisture (H ₂ O)	-	-	0.91	0.0091	18.02	0.8037	0.0073

Where: $\rho = M / 22.41$

$p_i = r \times \rho$

Calculation of Stack Gas Densities

Determinand	Units	Result
Dry Density (STP), P _{STD}	kg/m ³	1.2943
Wet Density (STP), P _{STW}	kg/m ³	1.2899
Dry Density (Actual), P _{Actual}	kg/m ³	1.2008
Average Wet Density (Actual), P _{ActualW}	kg/m ³	0.5983

Where: P_{STD} = sum of component concentrations, kg/m³ (not including water vapour)

P_{STW} = sum of all wet concentrations / 100 x density, kg/m³ (including water vapour)

$P_{Actual} = P_{STD} \times (T_{STP} / (P_{STP})) \times ((P_{static} + P_b) / T_a)$

$P_{ActualW} \text{ (at each sampling point)} = P_{STW} \times (T_s / P_s) \times (P_a / T_a)$

Calculation of Stack Gas Volumetric Flowrate, Q

Duct gas flow conditions	Units	Actual	REF ¹
Temperature	°C	21.0	0.00
Total Pressure	kPa	101.2	101.3
Moisture	%	0.91	0.91

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m ³ /hr	4256
Gas Volumetric Flowrate (STP, Wet)	m ³ /hr	3949
Gas Volumetric Flowrate (STP, Dry)	m ³ /hr	3913
Gas Volumetric Flowrate REF ¹	m ³ /hr	3949

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)

(1 of 1)

Parameter	Units	Value
Date of Survey	-	13/09/2018
Time of Survey	-	09:55 - 10:01
Atmospheric Pressure	kPa	101.0
Average Stack Static Pressure	Pa	210
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with Liquid Incline Manometer	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C _p	-	0.84
Number of Lines Available	-	1
Number of Lines Used	-	1

Sampling Line A

Traverse Point	Depth m	ΔP mmH ₂ O	Temp °C	Wet Density kg/m ³	Velocity m/s	Swirl °
<i>STATIC (Units: Pa)</i>		210.0				
Mean		32.0	21.0	1.197	19.20	
1	0.14	32.0	21.0	1.197	19.20	0.0

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	5.296	Pa
- Resolution	$u(res)$	0.52154	
- Calibration	$u(cal)$	10.254	
- Drift	$u(drift)$	1.096	
- Lack of Fit	$u(fit)$	15.176	
- Overall corrections to dynamic measurements	$u(C_f)$	27.048	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00002	-
- $\phi_{O_2,w}$	-	18.828	
- $\phi_{CO_2,w}$	-	1.486	
- Oxygen, dry	$u(\phi_{O_2,d})$	0.582	
- Carbon Dioxide, dry	$u(\phi_{CO_2,d})$	0.046	
- Water Vapour	$u(\phi_{H_2O})$	0.046	
- Oxygen, wet	$u(\phi_{O_2,w})$	0.576	
- Carbon Dioxide, wet	$u(\phi_{CO_2,w})$	0.046	
Standard uncertainty associated with the stack temperature	$u(T_c)$	1.500	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.772	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	5.296	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00645	-
Standard uncertainty associated with the local velocities	$u(v_i)$	1.628	Pa
Standard uncertainty associated with the mean velocity	$u(\bar{v})$	1.628	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	3.190	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	16.62	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	733.0	m ³ /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00772	
- $u^2(qV,w)$	-	139861	
- $u(qV,w)$	-	374.0	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	17.22	%

TOTAL PARTICULATE MATTER: RESULTS SUMMARY

Federal Mogul Sintered Products Ltd, Coventry
Main Stack

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	0.22	0.22
Uncertainty	±mg/m ³	0.65	0.65
Mass Emission	g/hr	0.89	0.89
Uncertainty	±g/hr	2.56	2.56

NOTE: Where the maximum Blank concentration is higher than the Sample concentration, the maximum Blank concentration has been reported.

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	1.51	1.51
Uncertainty	±% v/v	0.08	0.08

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	0.22	0.22

General Sampling Information

Parameter	Value
Standard	EN 13284-1
Technical Procedure	CAT-TP-01
Probe Material	Titanium
Filter Housing Material	Titanium
Positioning of Filter	In Stack
Filter Size and Material	47mm Glass Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

TOTAL PARTICULATE MATTER: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
Absolute pressure of stack gas, P_s			
Barometric pressure, P _b	mmHg	757.5	
Stack static pressure, P _{static}	mmH ₂ O	21.4	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	759.1	
Volume of water vapour collected, V_{wstd}			
Total mass collected in impingers (liquid trap)	g	-2.2	
Total mass collected in impingers (silica trap)	g	17.8	
Total mass of liquid collected, V _{lc}	g	15.6	
$V_{wstd} = (0.001246)(V_{lc})$	m ³	0.0194	
Volume of gas metered dry, V_{mstd}			
Volume of gas sample through gas meter, V _m	m ³	1.3761	
Gas meter correction factor, Y _d	-	0.9760	
Average dry gas meter temperature, T _m	°C	15.8	
Average pressure drop across orifice, ΔH	mmH ₂ O	48.4	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m ³	1.2712	
Moisture content, B_{w0} & R_{wv}			
$B_{w0} = V_{wstd} / (V_{mstd} + V_{wstd})$	m ³	0.0151	
B _{w0} as a percentage	% v/v	1.51	
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	1.51	
Volume of gas metered wet, V_{mstw}			
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m ³	1.2906	
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}			
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m ³	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m ³	N/A	
Molecular weight of dry gas stream, M_d			
CO ₂ (Estimated)	% v/v	0.06	
O ₂ (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N ₂	% v/v	79.14	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	28.84	
Molecular weight of stack gas (wet), M_s			
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.68	
Velocity of stack gas, V_s			
Pitot tube velocity constant, K _p	-	34.97	
Velocity pressure coefficient, C _p	-	0.84	
Average of velocity heads, ΔP _{avg}	mmH ₂ O	32.50	
Average square root of velocity heads, √ΔP	√mmH ₂ O	5.70	
Average stack gas temperature, T _s	°C	26.5	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (\sqrt{M_s}(P_s))$	m/s	19.64	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})			
Area of stack, A _s	m ²	0.06	
$Q_a = (60)(A_s)(V_s)$	m ³ /min	72.6	
Conversion factor (K/mm.Hg), C _f	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m ³ /min	66.1	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m ³ /min	65.1	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m ³ /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m ³ /min	N/A	
Percent isokinetic, %I			
Nozzle diameter, D _n	mm	4.98	
Nozzle area, A _n	mm ²	19.48	
Total sampling time, q	min	60	
$\%I = (4.6398E^6)(T_s + 273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	102.9	

TOTAL PARTICULATE MATTER: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1
Sampling Times	-	10:06 - 11:06
Sampling Dates	-	13/09/2018
Sampling Device	-	ISO
Volume Sampled (REF)	m ³	1.2906
Filter I.D. Number	-	47-53974
Start Filter Mass	g	0.14511
End Filter Mass	g	0.14506
Total Mass on Filter	g	-0.00005
Probe Rinse I.D. Number	-	PR-47-53974
Start Probe Rinse Mass	g	2.83483
End Probe Rinse Mass	g	2.83492
Total Mass in Probe Rinse	g	0.00009
Total Mass Collected	mg	0.04
Calculated Concentration	mg/m ³	0.03
Balance Uncertainty / LOD	mg/m ³	0.15

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1
Blank Dates	-	13/09/2018
Average Volume Sampled (REF)	m ³	1.2906
Filter I.D. Number	-	47-53927
Start Filter Mass	g	0.14651
End Filter Mass	g	0.14650
Total Mass on Filter	g	-0.00001
Probe Rinse I.D. Number	-	PR-47-53927
Start Probe Rinse Mass	g	2.49675
End Probe Rinse Mass	g	2.49705
Total Mass in Probe Rinse	g	0.00030
Total Mass Collected	mg	0.29
Calculated Concentration	mg/m ³	0.22
Balance Uncertainty / LOD	mg/m ³	0.15

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	22.4
Pre-Sampling Leak Rate	l/min	0.08
Post-Sampling Leak Rate	l/min	0.12
Allowable Leak Rate	l/min	0.45
Leak Test Acceptable	-	Yes

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	5.5
Allowable MU	%	20
MU Acceptable	%	Yes

Silica Gel (Concurrent Water Vapour)	Units	Run 1
Less than 50% Faded	%	Yes

Isokinetic Criterion Compliance	Units	Run 1
Isokinetic Variation	%	102.9
Allowable Isokinetic Range	%	95 - 115
Isokineticity Acceptable	-	Yes

Weighing Uncertainty Criteria	Units	Run 1
Overall Weighing Uncertainty	± mg	0.33
Overall Weighing Uncertainty	± mg/m ³	0.25
ELV [Daily ELV for IED]	mg/m ³	20.0
Allowable Weighing Uncertainty	mg/m ³	1.00
Weighing Uncertainty Acceptable	-	Yes

Filter Temperatures	Units	Run 1
Pre-Conditioning Temperature	°C	180
Post-Conditioning Temperature	°C	160
Maximum Filter Temperature	°C	32

Test Conditions	Units	Run 1
Ambient Temperature Recorded?	-	Yes

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1
Expected Sampling Rate	l/min	20.0
Pre-Sampling Leak Rate	l/min	0.10
Post-Sampling Leak Rate	l/min	0.12
Allowable Leak Rate	l/min	0.40
Leak Test Acceptable	-	Yes

Validity of Blank vs ELV	Units	Blank 1
Allowable Blank	mg/m ³	2.0
Blank Acceptable	-	Yes

Acetone / Water Rinse Blank	Units	Blank
Acetone / Water Rinse Value	mg/l	2.7
Allowable Blank	mg/l	10
Blank Acceptable	-	Yes

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
In order to maintain isokinetic sampling, a nozzle size smaller than that specified in the Standard was used.	x

TOTAL PARTICULATE MATTER: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V _m	1.38	uV _m	m ³	0.03
Sampled Gas Temperature	T _m	288.8	uT _m	K	2.00
Sampled Gas Pressure	p _m	101.2	uρ _m	kPa	0.50
Sampled Gas Humidity	H _m	0.00	uH _m	% v/v	1.00
Leak	L	0.54	uL	%	-
Mass of Particulate	m	0.19	um	mg	0.19
Uncollected Mass	UCM	0.29	uUCM	mg	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.69	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	0.54	≤2%
Mass of Particulate	%	1.12	<5% of ELV
Uncollected Mass	%	-	-

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient	
	Symbol	Units	Run 1	Run 1	
Sampled Volume (STP)	V _m	m ³	1.27	0.18	
Leak	L	mg/m ³	0.00	1.00	
Mass of Particulate	L _r	mg	0.19	1.18	
Uncollected Mass	UCM	mg	0.17	1.18	

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m ³	0.01
Leak	mg/m ³	0.00
Mass of Particulate	mg/m ³	0.22
Uncollected Mass	mg/m ³	0.20

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O ₂ Correction Factor	-	N/A
Stack Gas O ₂ Content	% v/v	N/A
MU for O ₂ Correction	-	N/A
Overall MU For O ₂ Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m ³	0.30
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.59
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.65
Reported Uncertainty	mg/m ³	0.65
Expanded uncertainty (95% confidence), without Oxygen Correction	%	261.3
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	287.4
Reported Uncertainty	%	287.4

HEAVY METALS: RESULTS SUMMARY

Federal Mogul Sintered Products Ltd, Coventry
Main Stack

Sample Runs

Parameter	Units	Run 1	Mean
Concentration	mg/m ³	0.04	0.04
Uncertainty	±mg/m ³	0.01	0.01
Mass Emission	g/hr	0.1	0.1
Uncertainty	±g/hr	0.1	0.1

Parameter	Units	Run 1	Mean
Water Vapour	% v/v	0.31	0.31
Uncertainty	±% v/v	0.03	0.03

Blank Runs

Parameter	Units	Blank 1	Maximum
Concentration	mg/m ³	0.00	0.00

General Sampling Information

Parameter	Value
Standard	EN 14385
Technical Procedure	CAT-TP-06
Name of Analytical Laboratory	CLS
Analytical Laboratory's Procedure	Section 21
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	28/09/2018
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Borosilicate Glass
Absorption Solution	Nitric Peroxide
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	1 / 1
Sample Point I.D.'s	A1

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

HEAVY METALS: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
Absolute pressure of stack gas, P_s			
Barometric pressure, P _b	mmHg	757.5	
Stack static pressure, P _{static}	mmH ₂ O	21.4	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	759.1	
Volume of water vapour collected, V_{wstd}			
Total mass collected in impingers (liquid trap)	g	0.0	
Total mass collected in impingers (silica trap)	g	3.2	
Total mass of liquid collected, V _{lc}	g	3.2	
$V_{wstd} = (0.001246)(V_{lc})$	m ³	0.0040	
Volume of gas metered dry, V_{mstd}			
Volume of gas sample through gas meter, V _m	m ³	1.4397	
Gas meter correction factor, Y _d	-	0.9760	
Average dry gas meter temperature, T _m	°C	21.8	
Average pressure drop across orifice, ΔH	mmH ₂ O	47.9	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m ³	1.3030	
Moisture content, B_{wo} & R_{wv}			
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m ³	0.0031	
B _{wo} as a percentage	% v/v	0.31	
Reported Water Vapour, checked with Tables in EN 14790, R _{wv}	% v/v	0.31	
Volume of gas metered wet, V_{mstw}			
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m ³	1.3069	
Volume of gas metered at Oxygen Reference Conditions, V_{mstd@X%O₂} & V_{mstw@X%O₂}			
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	
O ₂ Reference Factor wet (O _{2REFw}) = (21 - REF%O ₂) / (21 - ACT%O _{2w})	-	N/A	
O ₂ Reference Factor dry (O _{2REFd}) = (21 - REF%O ₂) / (21 - ACT%O _{2d})	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m ³	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m ³	N/A	
Molecular weight of dry gas stream, M_d			
CO ₂ (Estimated)	% v/v	0.06	
O ₂ (Estimated)	% v/v	20.80	
Total	% v/v	20.86	
N ₂	% v/v	79.14	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	28.84	
Molecular weight of stack gas (wet), M_s			
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.81	
Velocity of stack gas, V_s			
Pitot tube velocity constant, K _p	-	34.97	
Velocity pressure coefficient, C _p	-	0.84	
Average of velocity heads, ΔP _{avg}	mmH ₂ O	32.53	
Average square root of velocity heads, √ΔP	√mmH ₂ O	5.70	
Average stack gas temperature, T _s	°C	36.4	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (\sqrt{M_s}(P_s))$	m/s	19.93	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO₂}), Dry@O_{2REF} (Q_{stdO₂})			
Area of stack, A _s	m ²	0.06	
$Q_a = (60)(A_s)(V_s)$	m ³ /min	73.6	
Conversion factor (K/mm.Hg), C _f	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m ³ /min	64.9	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m ³ /min	64.7	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m ³ /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m ³ /min	N/A	
Percent isokinetic, %I			
Nozzle diameter, D _n	mm	4.98	
Nozzle area, A _n	mm ²	19.48	
Total sampling time, q	min	60	
$\%I = (4.6398E^6)(T_s+273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	106.1	

HEAVY METALS: SAMPLING DETAILS

(PAGE 1 OF 5)

Sample Runs

Parameter	Units	Run 1	
Sampling Times	-	11:17 - 12:17	
Sampling Dates	-	13/09/2018	
Sampling Device	-	ISO	
Volume Sampled (REF)	m ³	1.3069	
Cobalt			
Mass on Filter / in Rinse	µg	< 0.50	
Mass in Front Impingers	µg	0.51	
Mass in Back Impinger	µg	0.14	
Total Mass Collected	µg	1.15	
Calculated Concentration	mg/m ³	0.0009	
Reported Concentration	mg/m ³	0.0009	
Mass Emission	g/hr	0.00	
Chromium			
Mass on Filter / in Rinse	µg	2.00	
Mass in Front Impingers	µg	26.47	
Mass in Back Impinger	µg	12.39	
Total Mass Collected	µg	40.87	
Calculated Concentration	mg/m ³	0.0313	
Reported Concentration	mg/m ³	0.0313	
Mass Emission	g/hr	0.12	

HEAVY METALS: SAMPLING DETAILS

(PAGE 2 OF 5)

Sample Runs (continued)

Parameter	Units	Run 1	
Nickel			
Mass on Filter / in Rinse	µg	< 2.00	
Mass in Front Impingers	µg	2.04	
Mass in Back Impinger	µg	0.86	
Total Mass Collected	µg	4.90	
Calculated Concentration	mg/m ³	0.0037	
Reported Concentration	mg/m ³	0.0037	
Mass Emission	g/hr	0.01	

HEAVY METALS: SAMPLING DETAILS

(PAGE 3 OF 5)

Sample Runs (continued)

Parameter	Units	Run 1	
Heavy Metals Combined			
Total Mass Collected	µg	46.92	
Calculated Concentration	mg/m ³	0.0359	
Reported Concentration	mg/m ³	0.0359	

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1	
Blank Dates	-	13/09/2018	
Average Volume Sampled (REF)	m ³	1.3069	
Cobalt			
Mass on Filter / in Rinse	µg	< 0.50	
Mass in Front Impingers	µg	< 0.04	
Mass in Back Impinger	µg	< 0.03	
Total Mass Collected	µg	< 0.57	
Calculated Concentration	mg/m ³	< 0.0004	
Reported Concentration	mg/m ³	< 0.0004	

HEAVY METALS: SAMPLING DETAILS

(PAGE 4 OF 5)

Blank Runs (continued)

Parameter	Units	Blank 1	
Chromium			
Mass on Filter / in Rinse	µg	< 2.00	
Mass in Front Impingers	µg	< 0.10	
Mass in Back Impinger	µg	< 0.06	
Total Mass Collected	µg	< 2.17	
Calculated Concentration	mg/m ³	< 0.0017	
Reported Concentration	mg/m ³	< 0.0017	
Nickel			
Mass on Filter / in Rinse	µg	< 2.00	
Mass in Front Impingers	µg	< 0.42	
Mass in Back Impinger	µg	< 0.26	
Total Mass Collected	µg	< 2.68	
Calculated Concentration	mg/m ³	< 0.0020	
Reported Concentration	mg/m ³	< 0.0020	



HEAVY METALS: SAMPLING DETAILS

(PAGE 5 OF 5)

Blank Runs (continued)

Parameter	Units	Blank 1	
Heavy Metals Combined			
Total Mass Collected	µg	5.41	
Calculated Concentration	mg/m ³	0.0041	
Reported Concentration	mg/m ³	0.0041	

HEAVY METALS: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1
Mean Sampling Rate	l/min	23.4
Pre-Sampling Leak Rate	l/min	0.16
Post-Sampling Leak Rate	l/min	0.26
Allowable Leak Rate	l/min	0.47
Leak Test Acceptable	-	Yes

Absorption Efficiency	Units	Run 1
Cobalt	%	87.5
Chromium	%	69.7
Nickel	%	82.4
Allowable Absorption Efficiency	%	N/A
Absorption Efficiency Acceptable	-	Yes

Where the emissions are < 30% of the ELV, MID 14385 does not require the absorption efficiency requirement to be applied

Detection Limit	Units	Run 1
Cobalt	µg/m ³	0.46
Chromium	µg/m ³	1.72
Nickel	µg/m ³	2.27
Allowable Detection Limit	µg/m ³	5.0
Detection Limit Acceptable	-	Yes

Water Droplets	Units	Run 1
Are Water Droplets Present	-	No

MU (Concurrent Water Vapour)	Units	Run 1
Measurement Uncertainty (MU)	%	11.1
Allowable MU	%	20
MU Acceptable	%	Yes

HEAVY METALS: QUALITY ASSURANCE

(PAGE 2 OF 2)

Silica Gel (Concurrent Water Vapour)	Units	Run 1	
Less than 50% Faded	%	Yes	
Isokinetic Criterion Compliance	Units	Run 1	
Isokinetic Variation	%	106.1	
Allowable Isokinetic Range	%	95 - 115	
Isokineticity Acceptable	-	Yes	
Filter Temperatures	Units	Run 1	
Maximum Filter Temperature	°C	160	
Impingers Exit Temperature	Units	Run 1	
Maximum Temperature Recorded	°C	20	
Maximum Allowable Temperature	°C	30	
Exit Temperature Acceptable	-	Yes	
Test Conditions	Units	Run 1	
Ambient Temperature Recorded?	-	Yes	

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	20.0	
Pre-Sampling Leak Rate	l/min	0.12	
Post-Sampling Leak Rate	l/min	0.16	
Allowable Leak Rate	l/min	0.40	
Leak Test Acceptable	-	Yes	
Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m ³	0.50	
Blank Acceptable	-	Yes	

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
In order to maintain isokinetic sampling, a nozzle size smaller than that specified in the Standard was used.	x

HEAVY METALS: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value		Standard uncertainty		
	Symbol	Run 1	Symbol	Units	Run 1
Sampled Volume (Actual)	V _m	1.44	uV _m	m ³	0.03
Sampled Gas Temperature	T _m	294.8	uT _m	K	2.00
Sampled Gas Pressure	p _m	101.2	uρ _m	kPa	0.50
Sampled Gas Humidity	H _m	0.00	uH _m	% v/v	1.00
Leak	L	1.11	uL	%	-
Laboratory Result	L _r	15.0	uL _r	%	-

Measured Quantities	Uncertainty as a Percentage		Requirement of Standard
	Units	Run 1	
Sampled Volume (Actual)	%	2.00	≤2%
Sampled Gas Temperature	%	0.68	≤1%
Sampled Gas Pressure	%	0.49	≤1%
Sampled Gas Humidity	%	1.00	≤1%
Leak	%	1.11	≤2%
Laboratory Result	%	15.0	No Requirement

Measured Quantities	Uncertainty in Measurement Units			Sensitivity Coefficient
	Symbol	Units	Run 1	
Sampled Volume (STP)	V _m	m ³	1.30	0.03
Leak	L	mg/m ³	0.000	1.00
Laboratory Result	L _r	mg/m ³	0.005	1.00

Measured Quantities	Uncertainty in Result	
	Units	Run 1
Sampled Volume (STP)	mg/m ³	0.0009
Leak	mg/m ³	0.0002
Laboratory Result	mg/m ³	0.0054

Measured Quantities	Oxygen Correction Part of MU Budget	
	Units	Run 1
O ₂ Correction Factor	-	N/A
Stack Gas O ₂ Content	% v/v	N/A
MU for O ₂ Correction	-	N/A
Overall MU For O ₂ Measurement	%	N/A

Parameter	Units	Run 1
Combined uncertainty	mg/m ³	0.005
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.011
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.012
Reported Uncertainty	mg/m ³	0.012
Expanded uncertainty (95% confidence), without Oxygen Correction	%	29.9
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	32.8
Reported Uncertainty	%	32.8