

Site Specific Protocol (SSP)

commissioned by Airtech ECS Ltd

Operator Name

Federal-Mogul Coventry Ltd | Tenneco

Operator Address

Holbrook Lane
Holbrooks, Coventry
CV6 4BG
PPC Permit PPC/197

Monitoring Organisation Name & Address

Atesta Ltd
Unit 2, Asher Court, Lyncastle Way
Appleton, Warrington
WA4 4ST

SSP Written By

Matt Pendlebury | Technical Support Manager
MCERTS Level 2 | MM 04 535 | TE1 TE2 TE3 TE4 | expires on 31/03/2026

SSP Approved By

Alastair Wolff | Managing Director
MCERTS Level 2 | MM 04 566 | TE1 TE2 TE3 TE4 | expires on 30/06/2025



Name, Date and Signature of SSP Acceptor

Customer Acceptance - I confirm that I have read and I understand the contents of this SSP and I am happy for the monitoring to proceed

CHECK FOR EMAIL ACCEPTANCE IF NOT
SIGNED

Job Reference: JOB-1341

SSP Date | Version Number

04/11/2024 | Version 1

Planned Dates of the Monitoring Campaign

02/12/2024

Atesta Ltd Primary Contact

Alastair Wolff | m: 07506 729 226

e: alastair.wolff@atesta.com



info@atesta.com

T: 0800 970 8945

atesta.com

Part 1a: Summary of Release Points Covered in this SSP

Table of Release Points

	release point name	duct shape	duct dimensions	typical velocity m/s	typical temp °C	typical water vapour %
1	Main Stack	Circular	Diameter = 0.28 m	18.9	24.0	1.0

Part 1b: Contact Details | Monitoring Personnel | Analysis Laboratories

Operator Contact Details

operator name & address
Federal-Mogul Coventry Ltd Tenneco
Holbrook Lane
Holbrooks, Coventry
CV6 4BG
PPC Permit PPC/197

primary site contact
James Denny
t: 02476 584 545
e: james.denny@tenneco.com

alternative site contact
Katy Nixon
t: 01562 888 108
e: katy.nixon@airtechcs.com

Previous Campaign Information / Monitoring Dates

information	details
Job number from the previous monitoring campaign	JOB-911
Dates of the previous monitoring campaign	06/12/2023
Planned dates of this monitoring campaign ¹	02/12/2024

¹ If the monitoring dates change at late notice, it may be that the SSP is not re-issued. The final test report/s will be issued with the actual dates of the monitoring campaign.

Monitoring Personnel

site campaign manager
Brian Jacob

name	position	MCERTS level number expiry	MCERTS technical endorsements	mobile phone number
Brian Jacob	Senior Team Leader	MCERTS Level 2 MM 06 693 17/08/2025	TE1 TE2 TE3 TE4	07399 934 211
Ben Kudilil	Technician	MCERTS Level 1 MM 23 1781 26/05/2028	-	07939 979 639

Please note that on rare occasions, it may be necessary to change the monitoring personnel from those listed in the table above. In this event, the personnel attending the site would hold the correct and relevant MCERTS qualifications for the monitoring to be undertaken. Names and details would be made available to the client before arrival on site (to facilitate inductions / security checks / permits to work etc.). If a change is made at very late notice, for example in the event of illness, it may be that the SSP is not re-issued in time for the monitoring team's attendance on site. The final test report/s will be issued with the names of the personnel who performed the monitoring campaign.

Analysis Laboratories

laboratory	ISO 17025 accreditation number	laboratory short name	laboratory phone number
Atesta North West	10706	ATA	0800 970 8945
RPS Laboratories Salford	0605	RPS	0161 872 2443

Part 2: Monitoring Objectives | Sampling Location

Main Stack

The monitoring objective is to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

Sampling Location Photos



Sampling Location

duct shape	duct orientation	duct dimensions	duct area	platform access	platform type location	Power	Lighting	Water
Circular	Vertical	Diameter = 0.28 m	0.06 m ²	Ladder	Permanent Outside with shelter available in nearby building	240V	No	Yes

NOTE: Water should be available on site, it does not have to be available at the sampling location.

summary of all sample port sizes available
4" BSP

sample ports lines information	value
primary sample port size	4" BSP
primary sample port depth cm	9
primary sample ports correctly located	Yes
primary sample ports number of available sampling lines	2
number of sampling lines to be used minimum required (ISO / Traverse)	1 1
number of sampling points to be used per line minimum required (ISO / Traverse)	1 1
total number of sampling points to be used minimum required (ISO / Traverse)	1 1
total number of sampling points to be used (instrumental)	1

EN 15259 sampling plane criteria	result	compliant
lowest differential pressure Pa	305	Yes
ratio of gas velocities	1 : 1	Yes
maximum angle of swirl °	< 15	Yes
no local negative flow	Yes	Yes

A homogeneity test is not required for this release point. Any point (nominally 1/3 to 1/2 way into the duct) may be used for gaseous pollutant sampling.

Part 2: Sampling Facility Requirements | Health & Safety | Expected Monitoring Deviations | Notes

Main Stack

Sampling Location / Facility Requirements (EN 15259)

sampling facility requirements in EN 15259	compliant / non-compliant
permanent sampling platform related statements	
- sampling platform has 2 levels of handrails (approximately 0.5m and 1.0m high)	Yes
- sampling platform has vertical base boards (approximately 0.25m high)	Yes
- sampling platform has chains or self closing gates at the top of ladder runs	Yes
- there is sufficient platform depth to access all sampling points without equipment overhanging guard rails	Yes
general sampling facility statements	
- the access to the sampling location is safe	Yes
- there is sufficient work area to manipulate the probe & operate measuring instruments	Yes
- the sampling plane is in a section of duct with constant shape and cross-sectional area	Yes
- the sample ports are located correctly for the size and shape of the duct according to EN 15259 A	Yes For grid sampling (including velocity traverses)
- the sample ports are located correctly for the size and shape of the duct according to EN 15259 B	Yes For single point sampling (including instrumental and single point manual sampling)

general statement on the conformity of the suitability of the sampling location
The sampling location meets the requirements specified in EN 15259, which enables the sampling of all test parameters to be performed without the need to report any sampling location related monitoring deviations.

Health & Safety Considerations | Expected Monitoring Deviations | Further Notes & Comments

health & safety considerations	expected monitoring deviations	further notes / comments
There are no further health and safety considerations.	No monitoring deviations are expected.	N/A

Part 2: Monitoring Methods

Main Stack

Monitoring Methods

MANUAL METHODS PERIODIC

test parameter	number of tests blanks	reporting units	emission limit (ELV)	expected emission (reporting units)	projected LOD (reporting units)	reference method	technical procedure	capture media analysis technique	analysis lab accred status (NA = Non-Accredited)	sample duration (mins)	expected sample flow rate (l/min)	expected sample volume (m³)	estimated MU (%)	accred. status of test	reference conditions (STP = 273K, 101.3kPa)
Total Particulate Matter	1 1	mg/m³	20	0.85	0.12	EN 13284-1	TP-01	Filter + Acetone / Water Rinse Gravimetric	ATA MCERTS	60	15	0.91	10	MCERTS	STP, wet
Sulphur Dioxide	1 1	mg/m³	-	0.054	0.022	EN 14791	TP-10	0.3% H ₂ O ₂ IC	RPS MCERTS	60	15	0.91	10	MCERTS	STP, wet
Chromium, Cobalt & Nickel	1 1	mg/m³	5	0.015	0.0022	EN 14385	TP-05a	Filter HNO ₃ H ₂ O ₂ ICP-MS	RPS MCERTS	60	15	0.91	19	MCERTS	STP, wet
Water Vapour	Concurrent	% v/v	-	1	0.5	EN 14790	TP-03	H ₂ O + Silica Gel Gravimetric	ATA MCERTS	Concurrent	Concurrent	Concurrent	10	MCERTS	actual
Velocity & Flow Rate Traverse	1	m/s	-	19	1	EN 16911-1 TR 17078	TP-04a	Pitot + Thermocouple Calculation	ATA MCERTS	-	-	-	10	MCERTS	actual

Part 2: Process & Operating Conditions | Typical Velocity Profile

Main Stack

Process & Operating Conditions

process & operating conditions information	details
type of process	Melting of ferrous alloys using electrical induction furnaces
batch or continuous process	Batch
fuel type	N/A
feedstock	Metal ingots
typical load / throughput of plant	2 electrical induction furnaces of capacity 50 kg and 300 kg
typical stack temperature, oxygen & water vapour content	Temperature: 24°C O ₂ : 21% v/v H ₂ O: 1% v/v
details of any unusual process occurrences	TBC on day of testing
details of abatement systems	AAF Fabripulse M6-168 bag filtration unit
details of CEMS installed	N/A
operating conditions required for the report	To be provided on the day of testing

Typical Velocity Profile (Source: Previous Testing Campaign)

Line A				
static pressure = 240 Pa				
Pt	ΔP Pa	Temp °C	Vel m/s	Swirl °
1	305.0	24.0	18.9	< 15

Part 3: Post-Test SSP Sign Off

Monitoring deviations encountered during the monitoring exercise

Following completion of the sampling campaign the Site Campaign Manager (SCM), or Job Reviewer, signs against one of the statements below:

Statement 1: No deviations required	Atesta signature / initials	date
I, as the Site Campaign Manager / Job Reviewer, certify that all testing performed followed the monitoring programme as laid out in this SSP. No deviations (unless specified in the original SSP and approved by the client) were required.		

Statement 2: Deviations were required	Atesta signature / initials	date
It was necessary to deviate from the monitoring programme as detailed in this SSP. All deviations are listed above. The client was happy for the testing to proceed / continue on this basis.		

client signature / initials	date
CHECK FOR EMAIL ACCEPTANCE IF NOT SIGNED	