Report for Periodic Monitoring of Emissions to Atmosphere

Part 1:

Executive Summary

Permit Number:

PPC/028

Operator:

Atritor Limited

Installation:

Edgewick Park Industrial Estate, Coventry

Emission Point:

PMA 1 Main Scrubber Exhaust

Monitoring Date:

31st August 2010



1709



Contract Reference:

FTBS 12390

Operator:

Atritor Limited

Address:

Edgewick Park Industrial Estate

Canal Road Coventry CV6 5RD

Monitoring Organisation:

RPS Consultants Ltd

Address:

Grafton Building, Caswell Science and Business Park, Caswell,

Towcester, NN12 8EO

Report Date:

14th October 2010

Report Approved By:

Richard Carter

Position:

Consultant

MCERTS Registration No.:

MM07 861

Signature:

RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

Reference No.: FTBS 12390 Visit No.: Annual (2010)

CONTENTS

Part 1: Executive Summary

3
4
•••
∠
•••
(

Monitoring Objectives

At the request of Mr B. Percival of Atritor Ltd., RPS Health, Safety and Environment conducted air emission monitoring at the Edgewick Park Industrial Estate site, Coventry in August 2010

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for comparison with the limits specified in the air emission criteria for this site.

The parameters requested for monitoring at each emission point and the actual monitoring conducted are detailed below.

Table 1

Parameters Requested to be Monitored	PMA 1 – Main Scrubber Exhaust
Total Particulate Matter	1
Specific Requirements	Normal Operating Conditions

Notes:

✓ Represents the actual parameters monitored

* Represent parameters requested but not actually monitored

Reference No.: FTBS 12390 Visit No.: Annual (2010)

Report Issue No.: 2 - Page 3 of 6 October 2010

Monitoring Results

Table 2 - Monitoring Results from the PMA 1 - Main Scrubber Exhaust at Atritor Ltd., Coventry in August 2010

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (mg/m³)#	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	50	16	mg/m³	± 1.8	wet gas, without correction for oxygen	31-Aug-10	11:50 – 14:51 β	BS-EN 13284-1 2001	MCERTS	See Table 3
Linear velocity within Scrubber unit	9 (maximum)	4.4*	m/sec	-	-	31-Aug-10	•	BS-EN 13284-1 2001	MCERTS	See Table 3
Efflux Velocity at Stack Exhaust Exit	15 (minimum)	15.1@	m/sec	•	-	31-Aug-10	-	BS-EN 13284-1 2001	MCERTS	See Table 3

Notes:

The uncertainty associated with the quoted result is at the 95% confidence interval.

- * Figure calculated from volumetric flow rate at sample plane and cross sectional area of scrubber unit.
- @ Figure calculated from volumetric flow rate at sample plane and cross sectional area of duct at exit point.
- β Actual sampling time was 60 minutes

Operating Information

Table 3 – Operating Information During Monitoring of the PMA 1 – Main Scrubber Exhaust at Atritor Ltd., Coventry in August 2010

Parameter	Result			
Sample Date	31 st August 2010			
Process Type	Batch process 11:50 – 12:20 - Knocking out 14:15 – 14:35 - Melting 14:35 – 14:51 - Pouring			
Process Duration	~ 1.5 hours			
If 'Batch', was monitoring carried out over the whole batch?	Yes			
If 'No', give details	•			
Abatement/Operational?	Wet Scrubber / Yes			
Fuel Type	N/A			
Feedstock	White Iron			
Load	N/K			
Throughput	N/K			
Continuous Rating	N/A			

Reference No.: FTBS 12390

Visit No.: Annual (2010)

Report Issue No.: 2 - Page 5 of 6
October 2010

Monitoring Deviations

Table 4 - Monitoring Deviations During Monitoring of the PMA 1 - Main Scrubber Exhaust at Atritor Ltd., Coventry in August 2010

Substance Deviations	Monitoring Deviations	Other Relevant Issues
	Due to the position of the current sample position (upstream of the fan) the pump of the sample train had to be started shortly before the probe was inserted into the duct. This is a deviation from the procedural requirements of BSEN 13284.	

Reference No.: FTBS 12390 Report Issue No.: 2 - Page 6 of 6 Visit No.: Annual (2010) October 2010

Report for Periodic Monitoring of Emissions to Atmosphere

Part 2:

Supporting Information

Permit Number:

PPC/028

Operator:

Atritor Limited

Installation:

Edgewick Park Industrial Estate, Coventry

Emission Point:

PMA 1 Main Scrubber Exhaust

Monitoring Date:

31st August 2010



1709



1709

Contract Reference:

FTBS 12390

Operator:

Atritor Limited

Address:

Edgewick Park Industrial Estate

Canal Road Coventry CV6 5RD

Monitoring Organisation:

RPS Consultants

Address:

Grafton Building, Caswell Science and Business Park, Caswell,

Towcester, NN12 8EQ

Report Date:

30th September 2010

Report Approved By:

Richard Harvey

Position:

Principle Consultant

MCERTS Registration No.:

MM02 020

Signature:

RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

CONTENTS

Part 2: Supporting Information

APPENDIX 1: General Information	3
Monitoring Organisation Staff Details	4
Monitoring Organisation Method Details	5
APPENDIX 2: Emission Point PMA 1 Main Scrubber Exhaust	6
Stack Gas Measurements	7
Reportable Blank Results	9
Certificate of Analyses	10

APPENDIX 1: General Information

Reference No.: FTBS 12390 Report Issue No.: 1 - Page 3 of 11
Visit No.: Annual (2010) September 2010

Monitoring Organisation Staff Details

Table 5

Site Team	Position	MCERTS Level	Technical Endorsements	TE Expiry Dates	MCERTS Registration Number	
			1	13/06/13		
Richard Carter	Consultant	2	2	2	03/12/13	MM 07 861
			3	13/12/14	191191 07 801	
			4	18/03/14		
			1	10/09/12		
Edwin Powell	Compulsons	2	2	10/09/12	MAA 05 621	
	Consultant		3	10/09/12	MM 05 621	
			4	10/09/12		

Report Author	Position	MCERTS Level	Technical Endorsements	TE Expiry Dates	MCERTS Registration Number
	Consultant	2	1	10/09/12	
Edwin Powell			2	10/09/12	MM 05 621
	Consultant		3	10/09/12	MM 05 621
			4	10/09/12	

Report Reviewer	Position	MCERTS Level	Technical Endorsements	TE Expiry Dates	MCDRTS Registration Number
Dishard Harris	Principal	2	1 2	20/11/12 09/03/15	10102020
Richard Harvey	Consultant 2	2	3 4	20/03/11 07/12/10	MM 02 020

Reference No.: FTBS 12390

Report Issue No.: 1 - Page 4 of 11

Visit No.: Annual (2010)

Report Issue No.: 1 - Page 4 of 11

September 2010

Monitoring Organisation Method Details

Table 6

Emission Parameter	Standard Method	Monitoring Procedure No.	Monitoring Accreditation Status	Analysis Technique	Analysis Procedure No.	Analytical Laboratory	Analysis Accreditation Status
Practical Considerations Prior to Monitoring	N/A	RPSCE/1/1	MCERTS	N/A	N/A	N/A	N/A
Gas Flows	BS-EN 13284- 1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Gas Temperatures	BS-EN 13284- 1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Total Particulate Matter	BS EN 13284- 1:2001	RPSCE/1/7c	MCERTS	Gravimetric	D9	RPS Laboratories, Manchester	UKAS

Atritor Limited

APPENDIX 2: Emission Point PMA 1 Main Scrubber Exhaust

Report Issue No.: 1 - Page 6 of 11 September 2010 Reference No.: FTBS 12390 Visit No: Annual (2010)

Stack Gas Measurements

Table 7 - Temperature and Velocity Profile

Results of Gas Flows and Gas Temperatures Measured from the PMA 1 - Main Scrubber Exhaust at Atritor Ltd., Coventry on the 31st August 2010

Traverse		Sample	Line A			Sample	Line B	
Point (m)	T(°C)	ΔP (mm H ₂ O)	Neg. Flow?	Spin <15°	T (°C)	ΔP (mm H ₂ O)	Neg. Flow?	Spin <15°
0.26	15	5.4	No	<15°	15	19	No	<15°
0.53	15	7.0	No	<15°	15	20	No	<15°

Barometric pressure (kPa)	100.9
Static Pressure (mm H ₂ O)	-ve 240
Stack Dimension Ø (m)	0.70 x 0.76

Reference No.: FTBS 12390 Report Issue No.: 1 - Page 7 of 11 Visit No: Annual (2010) September 2010

Table 8 - Gas Measurements (continued)

Results of Total Particulate Matter and General Emission Parameters Measured from the PMA 1 – Main Scrubber Exhaust at Atritor Ltd., Coventry on the 31st August 2010

Emission Parameter	Units	Mean Result					
Sample Date	-	31st Aug 2010					
Sample Period	-	11:50 – 14:51 β					
Barometric Pressure	kPa	100.9					
Internal Area Of Duct	m ²	0.53					
Isokinetic Ratio	%	109					
Stack Moisture Content	%	0.9					
Stack Temperature	°C	17					
Gas Velocity (as measured at sampling plane)	m/sec	12					
Volumetric Flowrate (as measured)	m³/sec	6.6					
Volumetric Flowrate (at reference conditions)	m³/sec*	6.1					
Total Particulate Matter Mass Emission	kg/hr	0.35					
Total Particulate Matter Concentration	mg/m³*	16					

Notes:

Reference No.: FTBS 12390 Visit No: Annual (2010)

^{*} Reference conditions expressed as 273 K, 101.3 kPa, wet gas, without correction for oxygen

β Actual sampling time was 60 minutes

Reportable Blank Results

Table 9 - Results of the Reportable Blank Concentrations for Total Particulate Matter taken for the PMA 1 - Main Scrubber Exhaust at Atritor Ltd., Coventry in August 2010

Emission Parameter	Sample Date	Units*	Blank Concentration
Total Particulate Matter	31st Aug 2010	mg/m³	0.43

Notes:

Reference No.: FTBS 12390

Visit No: Annual (2010)

Report Issue No.: 1 - Page 9 of 11

September 2010

^{*} Reference conditions expressed as 273 K, 101.3 kPa, wet gas, without correction for oxygen.

Certificates of Analyses

Total particulate matter





			Test Certificate		Date 13/03/2010
Chent	RPS Towcest	ė.	On	der No.	ETBS12390
	Grafton Buildi	ng	Ce	rtificate No.	WK 10:4602
	Caswell Science & Technology Park Caswell, Transaster Northants				
				ue No.	1
	NN12 8EQ				
Contacs	Edwin Pow	ell	Da	te Received	03/09/2010
Description	2 filtern A 2 sa	obilions for TPA!	Te	chnique	Gravimetric
Sample No.	614739	061497			Method
Total particulate matte	ા	17.04 mg			D9(U)
Sample No.	614740	T119217			Method
Total particulate matter	il .	3.5 mg			D9(U)
Sample No	614741	064329			Method
Total particulate matte	Y	<0.04 mg			D9(U)
Sample No.	614742	T119216			Method

0.5 mg

Page 1 of 2

D9(U)

RPS Laboratories Ed. Unit 12. Waters Edge Business Park, Modwen Road, Salford, M5 3EZ. Tet. (0161) 872-2443, Fax: (0161) 877-3359.

Reference No.: FTBS 12390 Visit No: Annual (2010)



Test Certificate

Client

RPS Towcester

Certificate No.

WK10 4602

fsaud Na.

Tested By

Carl Hayes

Date

13/09/2010

Approved By

13/09/2010

Operations Manager

For and on authority of RPS Laboratories Ltd. RPS Laboratoria and conducts apply: a copy is available on request

Method Symbols

(U) Analysis a UKAS Actionated

INF Analysia o not UKAS Accepted

Concentration values impared and pomiliare provided to assist with interpretation only they are not covered by the property

CAAS NORMANIN

ANNARE CONTROLLER OF SOMEON SO INCRESES

This document may not be regard and other than in fat enters with the water regions of the issuing calculating

Page 2 of 2

RPS Laboratories Ltd. Unit 32, Waters Edge Business Park, Modwen Road, Sulford, M5 3EZ Tel: (0161) 872 2413 Fav: (0161) 877 3959

Reference No.: FTBS 12390 Visit No: Annual (2010)

Report Issue No.: 1 - Page 11 of 11 September 2010